

PROJECT MANUAL

HVAC Upgrade for Emery SR Seminary Castle Dale UT Stake

915 N. Center Street
Castle Dale, Utah 84513

Project No. 504-8931-21010101

**Project
Engineer:** VBFA
Consulting Engineers
181 East 5600 South
Murray, Utah 84107
Phone (801) 530-3148

Mechanical
Engineer: VBFA (John Alexander)
181 East 5600 South
Murray, Utah 84107
Phone (801) 530-3148

Electrical
Engineer: VBFA (Lewis Wong)
181 East 5600 South
Murray, Utah 84107
Phone (801) 530-3148

Architectural
Consultant: Knell Architects (Roger Knell)
45 East 300 North
Provo, Utah 84606
Phone (801) 373-6134

March 2022

INTRODUCTORY INFORMATION

BLANK PAGE

TABLE of CONTENTS

PROCUREMENT AND CONTRACTING REQUIREMENTS GROUP

INTRODUCTORY INFORMATION

PROJECT TITLE PAGE
TABLE OF CONTENTS

DIVISION 00: PROCUREMENT AND CONTRACTING REQUIREMENTS

PROCUREMENT REQUIREMENTS SUBGROUP

00 1000 SOLICITATION

INVITATION TO BID

00 2000 INSTRUCTIONS FOR PROCUREMENT

INSTRUCTIONS TO BIDDERS

00 3000 AVAILABLE INFORMATION

EXISTING ASBESTOS INFORMATION

00 4000 PROCUREMENT FORMS AND SUPPLEMENTS

CONTRACTOR BID FORM FOR GENERAL CONTRACT WORK (U.S.)

00 4500 REPRESENTATIONS AND CERTIFICATIONS

CONSTRUCTION MATERIAL ASBESTOS REPRESENTATION

CONTRACTING REQUIREMENTS SUBGROUP

00 5000 CONTRACTING FORMS AND SUPPLEMENTS

SMALL PROJECT AGREEMENT BETWEEN OWNER AND CONTRACTOR (US)

00 7000 CONDITIONS OF THE CONTRACT

SUPPLEMENTARY CONDITIONS FOR SMALL PROJECT AGREEMENT BETWEEN OWNER AND CONTRACTOR (US)

SPECIFICATIONS GROUP

GENERAL REQUIREMENTS SUBGROUP

DIVISION 01: GENERAL REQUIREMENTS

- 01 1000 SUMMARY
- 01 1200 MULTIPLE CONTRACT SUMMARY
- 01 1400 WORK RESTRICTIONS
- 01 3000 ADMINISTRATIVE REQUIREMENTS
- 01 3100 PROJECT MANAGEMENT AND COORDINATION
- 01 3300 SUBMITTAL PROCEDURES
- 01 3500 SPECIAL PROCEDURES
- 01 4000 QUALITY REQUIREMENTS
- 01 4301 QUALITY ASSURANCE – QUALIFICATIONS
- 01 4523 TESTING AND INSPECTING SERVICES
- 01 4546 DUCT TESTING, ADJUSTING, AND BALANCING
- 01 5000 TEMPORARY FACILITIES AND CONTROLS
- 01 6100 PRODUCT REQUIREMENTS
- 01 6200 PRODUCT OPTIONS
- 01 6400 OWNER-FURNISHED PRODUCTS
- 01 6600 DELIVERY, STORAGE, AND HANDLING REQUIREMENTS
- 01 7000 EXECUTION REQUIREMENTS
- 01 7400 CLEANING AND WASTE MANGEMENT
- 01 7700 CLOSEOUT PROCEDURES
- 01 7800 CLOSEOUT SUBMITTALS

FACILITY CONSTRUCTION SUBGROUP

DIVISION 02: EXISTING CONDITIONS

02 4000 DEMOLITION AND STRUCTURE MOVING

- 02 4119 SELECTIVE STRUCTURE DEMOLITION

DIVISION 03: CONCRETE

03 1000 CONCRETE FORMING AND ACCESSORIES

- 03 1113 STRUCTURAL CAST-IN-PLACE CONCRETE FORMING
- 03 1511 CONCRETE ANCHORS

03 2000 CONCRETE REINFORCING

- 03 2100 REINFORCEMENT BARS

03 3000 CAST-IN-PLACE CONCRETE

- 03 3111 CAST-IN-PLACE STRUCTURAL CONCRETE
- 03 3517 CONCRETE SEALER-FINISHING
- 03 3923 MEMBRANE CONCRETE CURING

03 6000 GROUTING

- 03 6213 NON-METALLIC NON-SHRINK GROUT

DIVISION 04: NOT USED

DIVISION 05: METALS

05 0500 COMMON WORK RESULTS OF METALS

05 0503 SHOP-APPLIED METAL COATINGS
05 0523 METAL FASTENINGS

05 5000 METAL FABRICATIONS

05 5214 GALVANIZED STEEL PIPE AND TUBE RAILINGS

DIVISION 06: WOOD, PLASTICS, AND COMPOSITES

06 0500 COMMON WORK RESULTS OF WOOD, PLASTICS, AND COMPOSITES

06 0573 PRESERVATIVE WOOD TREATMENT

06 1000 ROUGH CARPENTRY

06 1011 WOOD FASTENINGS
06 1100 WOOD FRAMING

06 2000 FINISH CARPENTRY

06 2001 COMMON FINISH CARPENTRY REQUIREMENTS
06 2024 DOOR, FRAME, AND FINISH HARDWARE INSTALLATION
06 2210 MISCELLANEOUS WOOD TRIM

06 4000 ARCHITECTURAL WOODWORK

06 4001 COMMON ARCHITECTURAL WOODWORK REQUIREMENTS
06 4512 ARCHITECTURAL WOODWORK WOOD TRIM

DIVISION 07: THERMAL AND MOISTURE PROTECTION

07 2000 THERMAL PROTECTION

07 2116 BLANKET INSULATION

07 6000 FLASHING AND SHEET METAL

07 6310 STEEP SLOPE ROOF FLASHING: Asphalt Shingles

07 9000 JOINT PROTECTION

07 9213 ELASTOMERIC JOINT SEALANTS

DIVISION 08: OPENINGS

08 0100 OPERATION AND MAINTENANCE OF OPENINGS

08 0601 HARDWARE GROUP AND KEYING SCHEDULES

08 1000 DOORS AND FRAMES

08 1213 HOLLOW METAL FRAMES
08 1429 FLUSH WOOD DOORS: FACTORY-FINISHED, CLEAR

08 7000 HARDWARE

08 7101 COMMON FINISH HARDWARE REQUIREMENTS
08 7102 HANGING DEVICES
08 7103 SECURING DEVICES
08 7106 CLOSING DEVICES
08 7109 ACCESSORIES

DIVISION 09: FINISHES

09 0500 COMMON WORK RESULTS FOR FINISHES

09 0503 FLOORING SUBSTRATE PREPARATION

09 2000 PLASTER AND GYPSUM BOARD

09 2900 GYPSUM BOARD

09 6000 FLOORING

09 6816 SHEET CARPET: BACK CUSHION, DIRECT GLUE

09 9000 PAINTS AND COATINGS

09 9001 COMMON PAINTING AND COATING REQUIREMENTS
09 9112 EXTERIOR PAINTED FERROUS METAL
09 9113 EXTERIOR PAINTED GALVANIZED METAL
09 9121 INTERIOR PAINTED POURED CONCRETE
09 9123 INTERIOR PAINTED GYPSUM BOARD, PLASTER
09 9124 INTERIOR PAINTED METAL
09 9324 INTERIOR CLEAR-FINISHED HARDWOOD
09 9413 INTERIOR TEXTURED FINISHING

DIVISIONS 10 THRU 19: NOT USED

FACILITY SERVICES SUBGROUP

DIVISIONS 20 THRU 22: NOT USED

DIVISION 23: HEATING, VENTILATING, AND AIR-CONDITIONING

23 0500 COMMON WORK RESULTS FOR HVAC

- 23 0501 COMMON HVAC REQUIREMENTS
- 23 0529 HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT
- 23 0553 IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT
- 23 0713 DUCT INSULATION
- 23 0719 HVAC PIPING INSULATION
- 23 0933 ELECTRIC AND ELECTRONIC CONTROL SYSTEM FOR HVAC

23 1000 FACILITY FUEL SYSTEMS

- 23 1123 FACILITY NATURAL GAS PIPING

23 2000 HVAC PIPING AND PUMPS

- 23 2300 REFRIGERANT PIPING
- 23 2600 CONDENSATE DRAIN PIPING

23 3000 HVAC AIR DISTRIBUTION

- 23 3001 COMMON DUCT REQUIREMENTS
- 23 3114 LOW-PRESSURE METAL DUCTS
- 23 3123 UNDERGROUND DUCTS
- 23 3300 AIR DUCT ACCESSORIES
- 23 3316 FIRE DAMPERS
- 23 3713 DIFFUSERS REGISTERS AND GRILLES
- 23 3723 HVAC GRAVITY VENTILATORS

23 4000 HVAC AIR CLEANING DEVICES

- 23 4100 AIR FILTERS

23 5000 CENTRAL HEATING EQUIPMENT

- 23 5135 AIR PIPING
- 23 5417 GAS-FIRED FURNACES

23 6000 CENTRAL COOLING EQUIPMENT

- 23 6214 COMPRESSOR UNITS: AIR CONDITIONING (5 TONS OR LESS)

DIVISIONS 24 & 25: NOT USED

DIVISION 26: ELECTRICAL

26 0500 COMMON WORK RESULTS FOR ELECTRICAL

- 26 0501 COMMON ELECTRICAL REQUIREMENTS
- 26 0519 LINE-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES
- 26 0523 CONTROL-VOLTAGE ELECTRICAL CABLES
- 26 0526 GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS
- 26 0533 RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS SCHEDULE
- 26 0613 ELECTRICAL EQUIPMENT MOUNTING HEIGHT SCHEDULE

26 2000 LOW-VOLTAGE ELECTRICAL TRANSMISSION

- 26 2417 CIRCUIT-BREAKER PANELBOARDS
- 26 2726 WIRING DEVICES
- 26 2816 ENCLOSED SWITCHES AND CIRCUIT BREAKERS

26 5000 LIGHTING

- 26 5100 INTERIOR LIGHTING
- 26 5200 EMERGENCY LIGHTING

DIVISIONS 27 THRU 29: NOT USED

SITE AND INFRASTRUCTURE SUBGROUP

DIVISION 30: NOT USED

DIVISION 31: EARTHWORK

31 0500 COMMON WORK RESULTS FOR EARTHWORK

- 31 0501 COMMON EARTHWORK REQUIREMENTS

31 1000 SITE CLEARING

- 31 1100 CLEARING AND GRUBBING
- 31 1123 AGGREGATE BASE

31 2000 EARTH MOVING

- 31 2213 ROUGH GRADING
- 31 2216 FINE GRADING
- 31 2316 EXCAVATION

DIVISION 32: EXTERIOR IMPROVEMENTS

32 3000 SITE IMPROVEMENTS

- 32 3113 CHAIN LINK FENCES AND GATES

32 8000 IRRIGATION

- 32 8423 UNDERGROUND SPRINKLERS

DIVISIONS 33 THRU 39: NOT USED

END OF TABLE OF CONTENTS

BIDDING REQUIREMENTS

FOR SMALL PROJECTS (U.S.)

BLANK PAGE

INVITATION TO BID (U.S.)

1. CONTRACTORS INVITED TO BID THE PROJECT:

- a. BC Builders (801) 509-0757
- b. Broderick & Henderson (801) 225 9213
- c. Dynamic Construction (801) 318 9711
- d. Gines Construction (801) 263-9800
- e. Majestic Builders (801) 798 2162
- f. Oasis Builders (801) 466 1000
- g. Painter Building (801)556-9794
- h. Stone River Construction (801) 636 3217
- i. Warner Construction (801) 794-0024

2. PROJECT:

Castle Dale (Emery) SR Seminary (HVAC)
Castle Dale UT Stake
Property Number: 504-8931
Project Number: 504-8931-21010101

3. LOCATION:

915 N. Center Street
Castle Dale, Utah 84513

4. OWNER:

Corporation of the Presiding Bishop of
The Church of Jesus Christ of Latter-day Saints, a Utah corporation sole
c/o
American Fork Project Management Office
110 East Main Street
American Fork, UT 84003

5. CONSULTANT:

VBFA (John Alexander)
181 East 5600 South
Murray, Utah 84107
Telephone (801) 530-31487
jalexander@vbfa.com

6. DESCRIPTION OF PROJECT:

- A. Replace 4 existing gas-fired furnace systems. Add 2 additional furnace system to provide better zone control. Various duct modifications for new zoning systems including some underground duct. Upgrade Automatic Temperature Controls. New mechanical room, some carpet replacement, extend exterior concrete equipment pad and fencing.
- B. Products or systems may be provided under a Value Managed Relationship (VMR) the

Owner has negotiated with the supplier. VMR products and systems are indicated as such in the Specifications.

7. **TYPE OF BID:** Bids will be on a lump-sum basis. Segregated bids will not be accepted.
8. **TIME OF SUBSTANTIAL COMPLETION:** The time limit for substantial completion of this work will be 120 calendar days and will be as noted in the Agreement.
9. **BID OPENING:** Bids to be submitted on the *ConsLog* website and will be publicly opened via a *ConsLog* video conference meeting on **Tuesday, March 22, 2022 at 2:00 PM MDT**. Invitations to the *ConsLog* web conference shall be emailed to all invited contractors.
10. **BIDDING DOCUMENTS:**
 - A. Electronic copies of bidding documents will be sent by e-mail to invited bidders who confirm their intention of providing project Bid.
 - B. Bidding Documents can also be provided at the Pre-Bid Conference if requested. Documents are to be returned complete and in good condition on day of bid opening.
11. **BIDDER'S QUALIFICATIONS:** Bidding by the Contractors will be by invitation only.
12. **OWNER'S RIGHT TO REJECT BIDS:** Owner reserves the right to reject any or all bids and to waive any irregularity therein.

END OF DOCUMENT

INSTRUCTIONS TO BIDDERS (U.S.)

1. DOCUMENTS:

- A. Bidding Documents include Bidding Requirements and proposed Contract Documents. Proposed Contract Documents consist of:
 - 1) Agreement Between Owner and Contractor for Small Project (U.S.)
 - 2) Other documents included by reference
 - 3) Addenda.
- B. Bidding Requirements are those documents identified as such in proposed Project Manual.
- C. Addenda are written or graphic documents issued prior to execution of the Contract which modify or interpret the Bidding Documents. They become part of the Contract Documents as noted in the Agreement Between Owner and Contractor for Small Project (U.S.) upon execution of the Agreement by Owner.

2. BIDDER'S REPRESENTATIONS:

- A. By submitting a bid proposal, bidder represents that
 - 1) Bidder has carefully studied and compared Bidding Documents with each other. Bidder understands the Bidding Documents and the bid is fully in accordance with the requirements of those documents,
 - 2) Bidder has thoroughly examined the site and any building located thereon, has become familiar with local conditions which might directly or indirectly affect contract work, and has correlated its personal observations with requirements of proposed Contract Documents, and
 - 3) Bid is based on materials, equipment, and systems required by Bidding Documents without exception.

3. BIDDING DOCUMENTS:

- A. Copies
 - 1) Owner will provide the Bidding Documents as set forth in the Invitation to Bid.
 - 2) Partial sets of Bidding Documents will not be issued.
- B. Interpretation or Correction of Bidding Documents
 - 1) Bidders will request interpretation or correction of any apparent errors, discrepancies, and omissions in the Bidding Documents.
 - 2) Corrections or changes to Bidding Documents will be made by written Addenda.
- C. Substitutions and Equal Products
 - 1) Equal products may be approved upon compliance with Contract Document requirements.
 - 2) Base bid only on materials, equipment, systems, suppliers or performance qualities specified in the Bidding documents.
 - 3) Where a specified product is identified as a "quality standard", products of other manufacturers that meet the performance, properties, and characteristics of the specified "quality standard" may be used without specific approval as a substitute.
- D. Addenda. Addenda will be sent to bidders and to locations where Bidding Documents are on file no later than 24 hours prior to bid opening.

4. BIDDING PROCEDURES:

- A. Form and Style of Bids
 - 1) Owner's Bid Form is for reference only. Official bid must be submitted through

ConsLog.

- 2) Bid will be complete and executed by authorized representative of Bidder.
- 3) Do not delete from or add to the information requested on bid form.

B. Submission of Bids

- 1) Bids to be submitted on the *ConsLog* website and will be publicly opened via a *ConsLog* video conference meeting.
- 2) It is bidder's sole responsibility to see that its bid is received at or before the specified time. Bids received after specified bid opening time may be returned to bidders unopened.
- 3) No oral, facsimile transmitted, telegraphic, or telephonic bids, modifications, or cancellations will be considered.

C. Modification or Withdrawal of Bid

- 1) Bidder guarantees there will be no revisions or withdrawal of bid amount for 45 days after bid opening.
- 2) Prior to bid opening, bidders may withdraw bid through *ConsLog*.
- 3) Prior to bid opening, bidder may acknowledge any or all Addenda through *ConsLog*.

5. CONSIDERATION OF BIDS:

A. Opening Of Bids - See Invitation to Bid.

B. Acceptance Of Bid

- 1) No bidder will consider itself under contract after opening and reading of bids until Owner accepts Contractor's Bid Proposal by executing same.
- 2) Bidder's past performance, organization, subcontractor selection, equipment, and ability to perform and complete its contract in manner and within time specified, together with amount of bid, will be elements considered in award of contract.

6. FORM OF AGREEMENT BETWEEN OWNER AND CONTRACTOR:

A. Agreement form will be "Agreement Between Owner and Contractor for Small Project (U.S.)" provided by Owner.

7. MISCELLANEOUS:

A. Pre-Bid Conference: A pre-bid conference will be held at the site (915 N. Center Street, Castle Dale, Utah) on **Thursday, March 10, 2022 at 1:00 PM.**

B. Examination Schedule for Existing Building and Site

1. Contact local FM group for access to building between Pre-Bid Conference and Bid Date. Price UT FM Group, James Lisonbee, (435) 724-2318.

END OF DOCUMENT

INFORMATION AVAILABLE TO BIDDERS (U.S.)

1. ASBESTOS-CONTAINING MATERIAL (ACM)

- A. The building upon which work is being performed has been examined for asbestos-containing material. There is no known ACM in the area of construction. If the Contractor encounters material that is suspected to be ACM, the Contractor shall immediately discontinue work and contact the Owner and Architect immediately.

END OF DOCUMENT

BLANK PAGE

BID FORM (for reference only)

FOR GENERAL CONTRACT WORK (U.S.)

PROJECT IDENTIFICATION:

Castle Dale Emery SR Seminary (HVAC)
Castle Dale UT Stake
Project Number: 504-8931-21010101

OWNER:

Corporation of the Presiding Bishop of the Church of Jesus Christ of Latter-day Saints, a Utah corporation
sole ("Owner")
Meetinghouse Project Management Office
50 E North Temple Street, COB 12
Salt Lake City, UY 84150-0012

CONSULTANT:

VBFA

BID

1. In submitting this Bid, Bidder represents that:
 - a. If this Bid is accepted, Bidder will enter into an agreement with Owner to perform and furnish the Work described in the Bidding Documents for the Bid Price and within the Time of Substantial Completion indicated in this Bid and in accordance with the other terms and conditions of the Contract Documents.
 - b. Bidder has carefully examined the Bidding Documents consisting of the Project Manual containing the Bidding Requirements, the Conditions of the Contract, and the Specifications, entitled _____, the Drawings entitled _____ and dated _____, and including sheets numbered _____, and addenda numbers _____.
 - c. Bidder has examined the site of the work, existing conditions, and all other conditions affecting the work on the above-named Project.
 - d. Bidder has carefully correlated the information known to Bidder and information and observations obtained from visits to the site with the Bidding Documents.
 - e. Bidder is familiar with federal, State, and local laws and regulations applicable to Project.
 - f. Bidder guarantees there will be no revisions or withdrawal of bid amount for forty-five (45) days after the bid opening.
2. Bidder hereby proposes to furnish all materials, labor, equipment, tools, transportations, services, licenses, fees, permits, etc., required by said documents to complete the Work described by the Contract Documents for the lump-sum of: _____ Dollars (\$ _____).
3. Bidder agrees to achieve substantial completion of the Work within the number of days indicated in the Invitation to Bid.

RESPECTFULLY SUBMITTED:

_____	Signature	
_____	Printed name	
_____	Title	
_____	Company name	
_____	Business Address	
_____	City, State, and Zip Code	
_____	Telephone	Fax
_____	Contact Email Address	

Date _____

License No. _____

BLANK PAGE

**SMALL PROJECT AGREEMENT
BETWEEN OWNER AND CONTRACTOR
Fixed Sum (U.S.)**

The Church of Jesus Christ of Latter-day Saints, a Utah corporation sole ("Owner") and _____ ("Contractor") enter into this *Small Project Agreement Between Owner and Contractor (U.S.)* ("Agreement") and agree as follows:

1. **Property/Project.**

Property/Project Number: _____
Property Address ("Project Site"): _____
Project Type: _____
Project Name ("Project"): _____
Stake Name: _____

2. **Scope of Work.** Contractor will furnish all labor, materials, tools, and equipment necessary to complete the Work in accordance with the Contract Documents. The Work is all labor, materials, tools, equipment, construction, and services required by the Contract Documents (the "Work").

3. **Contract Documents.** Contract Documents consist of:

- a. This Agreement;
- b. Supplementary Conditions for Small Project Agreement Between Owner and Contractor (U.S.);
- c. The Specifications (Division 01 and Divisions _____);
- d. Drawings entitled and dated _____;
- e. Addendum No. with date(s) _____;
- g. All written Field Changes, written Construction Change Directives and written Change Orders when prepared and signed by Owner and Contractor.

4. **Compensation.** Owner will pay Contractor for performance of Contractor's obligations under the Contract Documents the sum of _____ Dollars (\$ _____) (the "Contract Sum"). This Contract Sum includes all labor, materials, equipment, tools, costs, expenses, work and services of Contractor and its subcontractors necessary to perform the Work in accordance with the terms of this Agreement, including without limitation travel, communications, and copying costs.

5. **Payment.**

- a. If the Contract Sum is over \$100,000 or if otherwise requested by Owner, Contractor will submit to Owner a schedule of values which allocates the Contractor's Bid Proposal Amount to various portions of the Work. This schedule, when accepted by Owner will be used as a basis for reviewing Contractor's payment requests.
- b. Not more than once each month, Contractor will submit a payment request to Owner. Owner will pay Contractor for work completed within thirty (30) days after Owner receives:
 - 1) Contractor's payment request for work to date;
 - 2) a certification by Contractor that Contractor has paid for all labor, materials, and equipment relating to the Work covered by prior payment requests and that Contractor will pay for all labor, materials, and equipment relating to the Work covered by the current payment request; and
 - 3) releases of all mechanics' liens and claims of subcontractors, laborers, or material suppliers who supplied labor and/or materials for the Work covered by the payment request.
 - 4) updated Construction Schedule.
- c. Owner may modify or reject the payment request if, in Owner's opinion, the Work for which payment is requested is not acceptable or is less complete than represented on the payment request.
- d. Contractor will timely pay subcontractors their portion of fees and expenses that Owner has paid to Contractor.

FORM OF AGREEMENT

6. **Extras and Change Orders.** Owner may order changes in the Work by altering, adding to, or deducting from the Work. In the event of such a change, the Contract Sum and/or the time of completion will be adjusted to reflect the change by means of a written Change Order signed by Contractor and Owner. Contractor will not commence work on any change until either: (a) Contractor and Owner have executed a Change Order; or (b) Owner has issued a written order for the change acknowledging that there is a dispute regarding the compensation adjustment relating to the change. If Contractor proceeds with a change in the Work without complying with the preceding sentence, Contractor agrees that it will not be entitled to any additional compensation for such change.
7. **Warranty and Correction of Work.** For all Work, services, labor, materials, products, and equipment provided under the Contract Documents, Contractor provides and extends to Owner all statutory, common law, and standard industry warranties as well as those warranties set forth in Owner's Contract Documents. Unless a longer period is specified by Owner's Contract Documents or otherwise, Contractor, at a minimum and in addition to all other warranties, warrants all Work under the Contract Documents for at least one year. Specifically, and without limitation, Contractor will promptly correct at its own expense:
- a. any portion of the Work which
 - 1) fails to conform to the requirements of the Contract Documents, or
 - 2) is rejected by the Owner as defective or because it is damaged or rendered unsuitable during installation or resulting from failure to exercise proper protection.
 - b. any defects due to faulty materials, equipment, or workmanship which appear within a period of one year from the date of completion of the Work or within such longer period of time as may be prescribed by law or the terms of any applicable special warranty required by the Contract Documents.
8. **Time of Completion.** Contractor will complete the Work and have it ready for Owner's inspection within _____ (_____) calendar days from Notice to Proceed issued by Owner. Time is of the essence. If Contractor is delayed at any time in the progress of the Work by any act or neglect of Owner, or by changes in the Work, or by strikes, lockouts, unusual delay in transportation, unavoidable casualties, or acts of nature beyond Contractor's control, then the time for completion will be extended by the time that completion of the Work is delayed. However, Contractor expressly waives any damages for any such delays.
9. **Owner Provided Items.** Owner may provide furnishings, equipment, and/or other items for the Project. Contractor will install items furnished by Owner and/or receive, store, and protect such items on site until the date Owner accepts the Project.
10. **Product Requirements.** Contractor will provide products that comply with Contract Documents, are undamaged, and, unless otherwise indicated, are new and unused at time of installation. Contractor will provide products complete with accessories, trim, finish, safety guards, and other devices and details needed for complete installation and for intended use and effect.
11. **Permits, Surveys, and Taxes.** Contractor will obtain and pay for all permits and licenses, and also pay any applicable taxes. Contractor will also obtain and pay for any surveys it needs to perform the Work.
12. **Independent Contractor Relationship.** Contractor is not an agent or employee of Owner but is an independent contractor.
13. **Comply with Laws.** Contractor will comply, and ensure that all subcontractors comply, with all applicable laws, ordinances, rules, regulations, covenants, and restrictions.
14. **Indemnity and Hold Harmless.**
- a. Contractor will indemnify and hold harmless Owner and Owner's representatives, employees, agents, architects, and consultants from and against any and all claims, liens, damages, liability, demands, costs, judgments, awards, settlements, causes of action, losses and expenses (collectively "Claims" or "Claim"), including but not limited to attorney fees, consultant fees, expert fees, copy costs, and other expenses, arising out of or resulting from performance of or failure to perform the Work, attributable to bodily injury, sickness, disease, or death, or to injury to or destruction of real or personal property, including loss of use resulting therefrom, except to the extent that such liability arises out of the negligence of Owner, its

representatives, agents, and employees. This indemnity includes, without limitation, indemnification of Owner from all losses or injury to Owner's property, except to the extent that such loss or injury arises out of the negligence of Owner, its representatives, agents, and employees. This indemnity applies, without limitation, to include Claims occurring both during performance of the Work and/or subsequent to completion of the Work. In the event that any Claim is caused in part by a party indemnified hereunder, that party will bear the cost of such Claim to the extent it was the cause thereof. In the event that a claimant asserts a Claim for recovery against any party indemnified hereunder, the party indemnified hereunder may tender the defense of such Claim to Contractor. If Contractor rejects such tender of defense and it is later determined that the negligence of the party indemnified hereunder did not cause all of the Claim, Contractor will reimburse the party indemnified hereunder for all costs and expenses incurred by that party in defending against the Claim. Contractor will not be liable hereunder to indemnify any party for damages resulting from the sole negligence of that party.

- b. In addition to the foregoing, Contractor will be liable to defend Owner in any lawsuit filed by any Subcontractor relating to the Project. Where liens have been filed against Owner's property, Contractor (and/or its bonding company which has issued bonds for the Project) will obtain lien releases and record them in the appropriate county and/or local jurisdiction and provide Owner with a title free and clear from any liens of Subcontractors. In the event that Contractor and/or its bonding company are unable to obtain a lien release, Owner in its absolute discretion may require Contractor to provide a bond around the lien or a bond to discharge the lien, at Contractor's sole expense.
- c. In addition to the foregoing, Contractor will indemnify and hold Owner harmless from any claim of any other contractor resulting from the performance, nonperformance or delay in performance of the Work by Contractor.
- d. The indemnification obligation herein will not be limited by a limitation on the amount or type of damages, compensation or benefits payable by or for Contractor or a Subcontractor under workers compensation acts, disability benefit acts, or other employee benefit acts.

15. **Work Restrictions.** Contractor will ensure that Contractor, its agents, employees, and subcontractors:

- a. Do not use or consume alcohol, or cannabis, or illegally use drugs, on the Project Site or enter on or perform any Work on the Project Site while under their influence.
- b. Do not smoke or vape anything on the Project Site. Do not use tobacco in any form on the Project Site.
- c. Do not perform Work on the Project Site on Sundays except for emergency work.
- d. Refrain from using profanity or being discourteous or uncivil to others on the Project Site or while performing Work under this Agreement.
- e. Do not view or allow pornographic or other indecent materials on the Project Site.
- f. Do not play obnoxious and/or loud music on the Project Site. Do not play any music within existing facilities.
- g. Refrain from wearing immodest, offensive, or obnoxious clothing, while on the Project Site.
- h. Do not bring weapons on the Project Site.

16. **Safety Hazards.** Contractor will ensure that no work or services will be performed that may pose an undue safety hazard to Contractor, Contractor's employees, or any other person.

17. **Contractor's Insurance.** Prior to performing any work, Contractor will obtain and maintain during the term of this Agreement the following insurance:

- a. Workers Compensation Insurance or evidence of exemption.
- b. Employers Liability Insurance with minimum limits of the greater of \$500,000 E.L. each accident, \$500,000 E. L. disease-each employee, \$500,000 E.L. disease-policy limit or as required by the law of the state in which the Project is located.
- c. Commercial General Liability Insurance – ISO Form CG 00 01 (12/07) or equivalent Occurrence policy which will provide primary coverage to the additional insureds (the Owner and the Architect) in the event of any Occurrence, Claim, or Suit with:
 - 1) Limits of the greater of: Contractor's actual coverage amounts or the following:
 - a) \$2,000,000 General Aggregate;
 - b) \$2,000,000 Products - Comp/Ops Aggregate;
 - c) \$1,000,000 Personal and Advertising Liability;
 - d) \$1,000,000 Each Occurrence; and

- e) \$50,000 Fire Damage to Rented Premises (Each Occurrence)
- 2) Endorsements attached to the General Liability policy including the following or their equivalent:
 - a) ISO Form CG-25-03 (05/09), Amendment of Limits of Insurance (Designated Project or Premises) describing the Agreement and specifying limits as shown above.
 - b) ISO Form CG 20 10 (07/04), Additional Insured – Owners, Lessees, Or Contractors (Form B), naming Owner and Architect as additional insureds.
- d. Automobile Liability Insurance, with:
 - 1) Combined Single Limit each accident in the amount of no less than \$500,000; and
 - 2) Coverage applying to "Any Auto" or its equivalent.

Contractor will provide evidence of these insurance coverages to Owner by providing an ACORD 25 (2010/05) Form or its equivalent: (1) listing Owner as the Certificate Holder and Additional Insured on the general liability and any excess liability policies, (2) listing the insurance companies providing coverage (all companies listed must be rated in A.M. Best Company Key Rating Guide-Property-Casualty and each company must have a rating of B+ Class VII or higher), (3) attaching the endorsements set forth above for the Certificate of Liability Insurance, and (4) bearing the name, address and telephone number of the producer and signed by an authorized representative of the producer. (The signature may be original, stamped, or electronic.) Notwithstanding the foregoing, Owner may, in writing and at its sole discretion, modify these insurance requirements.

- 18. Resolution of Disputes.** In the event there is any dispute arising under the Contract Documents which cannot be resolved by agreement between the parties, either party may submit the dispute with all documentation upon which it relies to Director of Architecture, Engineering, and Construction, 50 East North Temple, Salt Lake City, Utah 84150, who will convene a dispute resolution conference within thirty (30) days. The dispute resolution conference will constitute settlement negotiations and any settlement proposal made pursuant to the conference will not be admissible as evidence of liability. In the event that the parties do not resolve their dispute pursuant to the dispute resolution conference, either party may commence legal action to resolve the dispute. Any such action must be commenced within six (6) months from the first day of the dispute resolution conference or be time barred. Submission of the dispute to the Director as outlined above is a condition precedent to the right to commence legal action to resolve any dispute. In the event that either party commences legal action to adjudicate any dispute without first submitting the dispute to the Director, the other party will be entitled to obtain an order dismissing the litigation without prejudice and awarding such other party any costs and attorney fees incurred by that party in obtaining the dismissal, including without limitation copy costs, and expert and consultant fees and expenses. Pending final resolution of a dispute hereunder, Contractor will proceed diligently with the performance of its obligations pursuant to this Agreement.
- 19. Termination by Contractor.** In the event Owner materially breaches any term of the Contract Documents, Contractor will promptly give Written Notice of the breach to Owner. If Owner fails to cure the breach within ten (10) days of the Written Notice, Contractor may terminate this Agreement by giving Written Notice to Owner and recover from Owner the percentage of the Contract Sum represented by the Work completed on the Project site as of the date of termination together with any out of pocket loss Contractor has sustained with respect to materials and equipment as a result of the termination prior to completion of the Work, less any offsets. Contractor will not be entitled to unearned profits or any other compensation or damages as a result of the termination and hereby waives any claim therefor. Contractor will provide to Owner all warranty, as built, inspection, and other close out documents as well as materials that Contractor has in its possession or control at the time of termination. Without limitation, Contractor's indemnities and obligations as well as all warranties relative to Work provided through the date of termination survive a termination hereunder.
- 20. Termination by Owner for Cause.** Should Contractor fail to timely provide Owner with the certificates of insurance, make a general assignment for the benefit of its creditors, fail to apply enough properly skilled workmen or specified materials to properly prosecute the Work in accordance with Contractor's schedule, or otherwise materially breach any provision of the Contract Documents, then Owner may, without any prejudice to any other right or remedy, give Contractor Written Notice thereof. If Contractor fails to cure its default within ten (10) days, Owner may terminate this Agreement by giving Written Notice to Contractor. In such case, Owner may, in Owner's sole discretion, take legal assignment of subcontracts and other contractual

rights of Contractor and/or take possession of the premises and all materials, tools, equipment, and appliances thereon, and finish the Work by whatever method Owner deems expedient. Contractor will not be entitled to receive any further payment until the Work is finished. If the unpaid balance of the Contract Sum exceeds the expense of finishing the Work, including compensation for additional administrative, architectural, consultant, and legal services (including without limitation attorney fees, expert fees, copy costs, and other expenses), such excess will be paid to Contractor, less any offsets. If such expense exceeds the unpaid balance, Contractor will pay the difference to Owner. Contractor will provide to Owner all warranty, as built, inspection, and other close out documents as well as materials that Contractor has in its possession or control at the time of termination. Without limitation, Contractor's indemnities and obligations as well as all warranties relative to Work provided through the date of termination survive a termination hereunder.

21. **Termination by Owner for Convenience.** Notwithstanding any other provision contained in the Contract Documents, Owner may, without cause and in its absolute discretion, terminate this Agreement at any time. In the event of such termination, Contractor will be entitled to recover from Owner the percentage of the Contract Sum equal to the percentage of the Work which Owner and/or its architect determines has been completed on the Project site as of the date of termination together with any out of pocket loss Contractor has sustained with respect to materials and equipment as a result of the termination prior to completion of the Work, less any offsets. Contractor will not be entitled to unearned profits or any other compensation as a result of the termination and hereby waives any claim therefor. Contractor will provide to Owner all warranty, as built, inspection, and other close out documents as well as materials that Contractor has in its possession or control at the time of termination. Owner may, in Owner's sole discretion, take legal assignment of subcontracts and other contractual rights of Contractor. Without limitation, Contractor's indemnities and obligations as well as all warranties relative to Work provided through the date of termination survive a termination hereunder.
22. **Enforcement.** In the event either party commences legal action to enforce or rescind any term of this Agreement, the prevailing party will be entitled to recover its attorney fees, costs and legal expenses, including without limitation all copy costs and expert and consultant fees and expenses, incurred in that action and on all appeals, from the other party.
23. **Ownership of Materials, Products, and Intellectual Property Rights.** Owner will retain ownership and intellectual property rights in all plans, designs, drawings, documents, concepts, and materials provided by or on behalf of Owner to Contractor and to all work products of Contractor and its subcontractors for products, services, and Work provided under this Agreement, such products, services, and Work of Contractor and its subcontractors constituting works made for hire. Neither Contractor nor its subcontractors will reuse any portion of such items provided by Owner or work products developed by Contractor or its subcontractors for Owner pursuant to this Agreement or disclose any such items to any third party without the prior written consent of Owner. Owner may withhold its consent in its absolute discretion. Contractor shall obtain the written agreement of each of its subcontractors to the terms of this section prior to permitting the subcontractor to perform any services contemplated by this Agreement.
24. **Comply with Intellectual Property Rights of Others.** Contractor represents and warrants that no Work or services (with its means, methods, goods, and services attendant thereto), provided to Owner will infringe or violate any right of any third party and that Owner may use and exploit such Work, means, methods, goods, and services without liability or obligation to any person or entity (specifically and without limitation, such Work, means, methods, goods, and services will not violate rights under any patent, copyright, trademark, or other intellectual property right or application for the same).
25. **Ownership and Use of Renderings and Photographs.** Renderings, photographs, and/or other images of or representing the services, Work, or any improvement on or relative to the Project Site, whether created before, during, or at completion of construction (and whether created by Owner, Contractor, or Contractor's subcontractors), are the property of the Owner. Contractor hereby transfers and assigns to Owner all ownership and intellectual property rights that Contractor and/or its subcontractors may have in and to all such renderings, photographs, and other images. The Owner reserves all rights including copyrights and other intellectual property rights to such renderings, photographs, and other images. No such renderings, photographs, or other images shall be used or distributed without written consent of the Owner.

26. **Public Statements.** Contractor will not make any statements or provide any information to the media about the Project or Work without the prior written consent of Owner. If Contractor receives any requests for information from media, Contractor will refer such requests to Owner.
27. **Confidentiality.** Contractor shall ensure that Contractor and its subcontractors, and the employees, agents and representatives of Contractor and its subcontractors, maintain in strict confidence, and shall use and disclose only as authorized by Owner all Confidential Information of Owner that Contractor receives in connection with the performance of this Agreement. Notwithstanding the foregoing, Contractor may use and disclose any information to the extent required by an order of any court or governmental authority, but only after it has notified Owner and Owner has had an opportunity to obtain reasonable protection for such information in connection with such disclosure. For purposes of this Agreement, "Confidential Information" means:
- The name or address of any affiliate, customer or contractor of Owner or any information concerning the transactions of any such person with Owner;
 - Any contracts, agreements, business plans, budgets or other financial information, renderings, photographs, and materials provided by Owner, relating to the Work or any improvement on the Project Site to the extent such has not been made available to the public by the Owner;
 - Any other information that is marked or noted as confidential at the time of its disclosure.
28. **No Commercial Use of Transaction or Relationship.** Without the prior written consent of Owner, which Owner may grant or withhold in its sole discretion, neither Contractor nor Contractor's affiliates, officers, directors, agents, representatives, shareholders, members, subcontractors, or employees shall make any private commercial use of their relationship to Owner or the Project, including, without limitation:
- By referring to the Owner or Project verbally or in any sales, marketing or other literature, letters, client lists, press releases, brochures or other written materials except as may be necessary for Contractor to perform Contractor's obligations under the terms of this Agreement;
 - By using or allowing the use of any photographs of the Work or Project or any part thereof, or of any service mark, trademarks or trade names or other intellectual property now or which may hereafter be associated with, owned by or licensed by Owner, in connection with any work, service or product; or
 - By contracting with or receiving money or anything of value from any person or commercial entity to facilitate such person or entity obtaining any type of commercial identification, advertising or visibility in connection with the Owner or Project.
- Notwithstanding the foregoing, Contractor may include a reference to Owner or the Project in a professional résumé or other similar listing of Contractor's references without seeking Owner's written consent in each instance, provided that such reference to Owner or the Project is included with at least several other similar references to projects of different owners and is given no more prominence than such other references.
29. **Entire Agreement.** This Agreement contains the entire and integrated agreement between the parties hereto and supersedes all prior negotiations, representations, or agreements, either written or oral, relating to the Project. This Agreement may be amended only by a writing signed by both parties. This Agreement will not be construed to create a contractual relationship of any kind between any persons or entities other than Owner and Contractor.
30. **Assignment.** Contractor will not assign any right or obligation hereunder without the prior written consent of the Owner, which consent may be granted or withheld in Owner's absolute discretion.
31. **Governing Law.** The parties acknowledge that the Contract Documents have substantial connections to the State of Utah. The Contract Documents will be deemed to have been made, executed, and delivered in Salt Lake City, Utah. To the maximum extent permitted by law, (i) the Contract Documents and all matters related to their creation and performance will be governed by and enforced in accordance with the laws of the State of Utah, excluding conflicts of law rules, and (ii) all disputes arising from or related to the Contract Documents will be decided only in a state or federal court located in Salt Lake City, Utah and not in any other court or state. Toward that end, the parties hereby consent to the jurisdiction of the state and federal courts located in Salt Lake City, Utah and waive any other *venue* to which they might be entitled by virtue of domicile, habitual residence, place of business, or otherwise.

32. **Effective Date.** The effective date of this Agreement is the date indicated by Owner's signature.

OWNER:

The Church of Jesus Christ of Latter-day Saints,
a Utah corporation sole

CONTRACTOR:

Signature:

Signature:

Print Name:

Print Name:

Title:

Title:

Address:

Address:

Telephone No:

Telephone No:

Facsimile No:

Facsimile No:

Email:

Email:

Effective Date:

Fed. I.D. or SSN:

Reviewed By:

License No:
Date Signed:

FORM OF AGREEMENT

SUPPLEMENTARY CONDITIONS

FOR SMALL PROJECT AGREEMENT BETWEEN OWNER AND CONTRACTOR (U.S.)

ITEM 1 - GENERAL

1. Conditions of the Small Project Agreement Between Owner and Contractor (U.S.) apply to each Division of the Specifications.
2. Provisions contained in Division 01 apply to all Divisions of the Specifications.

ITEM 2 - LIQUIDATED DAMAGES PAYABLE TO OWNER

This section may be included as a separate additional paragraph to the Small Project Agreement Between Owner and Contractor (U.S.), at Owner's discretion:

Delay in Completion of the Work. For each day after the expiration of the designated Time of Completion that Contractor has not completed the Work, Contractor will pay Owner the amount of Two-Hundred Fifty dollars (\$250) per day as liquidated damages for Owner's loss of use and the added administrative expense to Owner to administer the Project during the period of delay. In addition, Contractor will reimburse Owner for any additional Architect's fees, attorneys' fees, expert fees, consultant fees, copy costs, and other expenses incurred by Owner as a result of the delay. Owner may deduct any liquidated damages or reimbursable expenses from any money due or to become due to Contractor. If the amount of liquidated damages and reimbursable expenses exceeds any amounts due to Contractor, Contractor will pay the difference to Owner within ten (10) days after receipt of a written request from Owner for payment.

ITEM 3 - STATE SPECIFIC SUPPLEMENTARY CONDITIONS

Utah

UTAH STATE SALES TAX:

Add the following to the Small Project Agreement Between Owner and Contractor (U.S.):

1. Contractors should be exempt on purchases of material installed or converted into real property to be used by the Owner. The Contractor will furnish each vendor with a completed Exemption Certificate Form TC-721. The certificate will be prepared by the Contractor for each vendor in order to obtain the exemption.
2. The Owner's tax exempt number is 11871701-002-STC.

UTAH NOTICE OF INTENT TO OBTAIN FINAL COMPLETION:

Add the following to the Small Project Agreement Between Owner and Contractor (U.S.):

- A. Contractor shall file with the State Construction Registry, on its own behalf and/or on behalf of Owner, a notice of intent to obtain final completion at least 45 days before the day on which the Owner or Contractor files or could file a notice of completion under Utah Code Ann. Section 38-1a-506 if:
 1. The completion of performance time under the original contract for construction work is greater than 120 days;
 2. The total original construction contract price exceeds \$500,000; and
 3. The original contractor or owner has not obtained a payment bond in accordance with Utah Code Ann. Section 14-2-1.

UTAH NOTICE OF COMPLETION:

Add the following to the Small Project Agreement Between Owner and Contractor (U.S.):

- A. Within five (5) calendar days of final completion of the Project and in compliance with Section 38-1a-507 Utah Code Annotated, Contractor shall file with the State Construction Registry, and copy to Owner, a notice of completion which shall include, without limitation, the following:
1. The name, address, telephone number, and email address of the person filing the notice of completion;
 2. The name of the county in which the Project and/or Project site is located;
 3. The date on which final completion is alleged to have occurred;
 4. The method used to determine final completion; and
 5. One of the following:
 - a. The tax parcel identification number of each parcel included in the Project and/or Project site;
 - b. The entry number of a preliminary notice on the same project that includes the tax parcel identification number of each parcel included in the Project and/or Project site; or
 - c. The entry number of the building permit issued for the Project.
- B. Notwithstanding any other provision of the Contract Documents to the contrary, Contractor and Owner agree that any breach or failure to comply with this Section by the Contractor will constitute a breach of contract and the Contractor will be liable for any direct, indirect, or consequential damages to the Owner flowing from this breach.

UTAH STATE PROGRESS PAYMENTS AND FINAL PAYMENT:

Replace paragraph 5 of the Small Project Agreement Between Owner and Contractor (U.S.) with the following:

5. Payment

- a. If the Contractor's Bid Proposal Amount is over \$100,000, Contractor will submit to Owner a schedule of values which allocates the Contractor's Bid Proposal Amount to various portions of the Work. This schedule, when accepted by Owner, will be used as a basis for reviewing Contractor's payment requests.
- b. Progress Payments: Not more than once each month, Contractor will submit a payment request to Owner. Owner will pay Contractor progress payments for work completed within fifteen (15) days after Owner receives:
 1. Contractor's progress payment request for work to date;
 2. A certification by Contractor that Contractor has paid for all labor, materials, and equipment relating to the Work covered by prior payment requests and that Contractor will pay for all labor, materials, and equipment relating to the Work covered by the current payment request; and
 3. Conditional Waiver and Release Upon Progress Payment documents submitted by Contractor (in content complying with Utah Code § 38-1a-802) executed by each of the subcontractors performing work and/or providing materials covered by the Contractor's progress payment request.
- c. Final Payment: Owner will make full and final payment of the Contract Sum due within thirty (30) days of the completion of all of the following requirements:
 1. Contractor has submitted its final payment request;
 2. Contractor has submitted a certification that Contractor has paid for all labor, materials, and equipment relating to the Work covered by prior payment requests and that Contractor will pay for all labor, materials, and equipment relating to the Work covered by the final payment request; and
 3. Contractor has submitted Waiver and Release Upon Final Payment documents (in content complying with Utah Code § 38-1a-802) executed by each of the subcontractors performing work and/or providing materials covered by the Contractor's final payment request.

Acceptance of final payment by Contractor or any Subcontractor will constitute a waiver of claims by the payee except for those claims previously made to Owner in writing and identified by Contractor in its affidavit as still pending.

If the aggregate of previous payments made by Owner exceeds the amount due Contractor, Contractor will reimburse the difference to Owner.

- d. Owner may modify or reject any payment request if, in Owner's opinion, the Work for which payment is requested is not acceptable or is less complete than represented on the payment request.

- e. Upon receipt of any payment from Owner, Contractor will pay to each Subcontractor the amount paid to Contractor on account of such Subcontractor's portion of the Work.
- f. Contractor will maintain a copy of each payment request at the Project site for review by the Subcontractors.
- g. No payment made, either in whole or in part, by Owner will be construed to be an acceptance of defective or improper materials or workmanship.

ITEM 4 - AMOUNT FOR PERMITS AND FEES

Include in the bid the sum of **\$4,000.00** to be used as the amount for permits and fees to Emery County. Once the exact amount of permits and fees is known, the amount will be adjusted up or down by change order. The Owner will then receive a credit back or the Contractor will receive an extra.

END OF DOCUMENT

DIVISION 01**SECTION 01 0000****GENERAL REQUIREMENTS: R&I PROJECT****01 1000 SUMMARY****01 1200 MULTIPLE CONTRACT SUMMARY****01 1400 WORK RESTRICTIONS****01 3000 ADMINISTRATIVE REQUIREMENTS****01 3100 PROJECT MANAGEMENT AND COORDINATION****01 3300 SUBMITTAL PROCEDURES****01 3500 SPECIAL PROCEDURES****01 4000 QUALITY REQUIREMENTS****01 4301 QUALITY ASSURANCE – QUALIFICATIONS****01 4523 TESTING AND INSPECTING SERVICES****01 4546 DUCT TESTING, ADJUSTING, AND BALANCING****01 5000 TEMPORARY FACILITIES AND CONTROLS****01 6100 COMMON PRODUCT REQUIREMENTS****01 6200 PRODUCT OPTIONS****01 6400 OWNER-FURNISHED PRODUCTS****01 6600 DELIVERY, STORAGE, AND HANDLING REQUIREMENTS****01 7000 EXECUTION REQUIREMENTS****01 7400 CLEANING AND WASTE MANAGEMENT****01 7700 CLOSEOUT PROCEDURES****01 7800 CLOSEOUT SUBMITTALS****SECTION 01 1000 SUMMARY****A. Work Covered By Contract Documents:**

1. Provisions contained in Division 01 apply to all other sections and divisions of Specifications. All instructions contained in Specifications are directed to Contractor. Unless specifically provided otherwise, all obligations set forth in Specifications are obligations of Contractor.
2. Comply with applicable laws and regulations.

B. Work By Owner:

1. Owner will furnish and install some portions of the Work with its own forces. Complete the Work necessary to accommodate the Work to be performed by Owner before scheduled date for performance of such Work.
2. Owner may provide furnishings and/or equipment for Project. Contractor will receive, store, and protect such items on site until the date Owner accepts Project.

SECTION 01 1200 MULTIPLE CONTRACT SUMMARY**A. Separate Contracts:**

1. Contracts may be issued by Owner for performance of certain construction operations at Project site.
2. Contractor will afford other contractors reasonable opportunity to place and store their materials and equipment on site and to perform their work and will properly connect and coordinate its work with theirs where applicable:

SECTION 01 1400 WORK RESTRICTIONS**A. Project Conditions:**

1. During construction period, Contractor will have use of premises for construction operations. Contractor will ensure that Contractor, its employees, subcontractors, and employees comply with following requirements:
 - a. Confine operations to areas within Contract limits shown on Drawings. Do not disturb portions of site beyond Contract limits.
 - b. Do not allow alcoholic beverages, illegal drugs, or persons under their influence on Project Site.
 - c. Do not allow use of tobacco in any form on Project Site.

- d. Do not allow pornographic or other indecent materials on site.
 - e. Do not allow work on Project Site on Sundays except for emergency work.
 - f. Refrain from using profanity or being discourteous or uncivil to others on Project Site or while performing The Work.
 - g. Wear shirts with sleeves, wear shoes, and refrain from wearing immodest, offensive, or obnoxious clothing, while on Project Site.
 - h. Do not allow playing of obnoxious and loud music on Project Site. Do not allow playing of any music within existing facilities.
 - i. Do not build fires on Project Site.
 - j. Do not allow weapons on Project Site, except those carried by law enforcement officers and/or other uniformed security personnel who have been retained by Owner or Contractor to provide security services.
2. Existing Facilities:
- a. If Owner will occupy existing building, reasonably accommodate use of existing facilities by Owner.

SECTION 01 3000 ADMINISTRATIVE REQUIREMENTS

A. Administrative Requirements:

1. Coordination:
 - a. Coordinate construction activities to ensure efficient and orderly installation of each part of the Work.
 - b. Coordinate construction operations that are dependent upon each other for proper installation, connection, and operation.
 - c. Coordinate construction activities to ensure that operations are carried out with consideration given to conservation of energy, water, and materials.

SECTION 01 3100 PROJECT MANAGEMENT AND COORDINATION

A. Multiple Contract Coordination:

1. Contractor shall be responsible for coordination of Temporary Facilities and Controls, Construction Waste Management and Disposal services, and Final Cleaning for entire Project unless directed otherwise by Owner's Representative for those who perform work on Project from Notice to Proceed to date of Substantial Completion.

B. Project Meetings And Conferences:

1. Attend preconstruction conference and organizational meeting scheduled by Architect or Owner Representative at Project site or other convenient location.
2. Be prepared to discuss items of significance that could affect progress, including such topics as:
 - a. Construction schedule, equipment deliveries, general inspection of tests, preparation of record documents and O&M manuals, project cleanup, security, shop drawings, samples, use of premises, work restrictions, and working hours.
2. Pre-Installation Conferences.
 - a. Attend pre-installation conferences specified in Contract Document.

SECTION 01 3300 SUBMITTAL PROCEDURES

A. Submittal Procedure:

1. Coordination: Coordination preparation and processing of submittals with performance of construction activities. Transmit each submittal sufficiently before performance of related construction activities to avoid delay.
2. Process Time: Allow sufficient review time so installation will not be delayed by time required to process submittals.
3. Identification: Place permanent label or title block on each submittal for identification. Include name of entity that prepared each submittal on label or title block.
4. Transmittal: Package each submittal appropriately for transmittal and handling.

B. Action Submittals:

1. Product Data: Submit product data, as required by individual Sections of Specifications.
2. Shop Drawings: Submit shop drawings for review and designate (stamp) approval of shop drawings.

3. Samples: Samples used for comparison with actual component to be installed. Samples when accepted will be used for quality comparisons throughout course of construction.

C. Informational Submittals:

1. Informational submittals are design data, test reports, certificates, manufacturer's instructions, manufacturer's field reports, and other documentary data affirming quality of products and installations.
 - a. Return copies or PDF files marked with action taken and with corrections or modifications required.

D. Closeout Submittals:

1. Submittals that occur during project closeout.

SECTION 01 3500 SPECIAL PROCEDURES

A. Quality Assurance:

1. Hot Work Permit (Available from Owner's Representative):
 - a. Required for doing hot work involving open flames or producing heat or sparks such as:
 - 1) Brazing.
 - 2) Cutting.
 - 3) Grinding.
 - 4) Soldering.
 - 5) Thawing pipe.
 - 6) Torch applied roofing.
 - 7) Welding.

SECTION 01 4000 QUALITY REQUIREMENTS

A. Administrative Requirements:

1. Conflicting Requirements:
 - a. If compliance with two or more standards is specified and standards establish different or conflicting requirements for minimum quantities or quality levels, comply with most stringent requirement.
2. Minimum Quantity or Quality Levels:
 - a. Quantity or quality level shown or specified shall be the minimum provided or performed. Actual installation may comply exactly with minimum quantity or quality specified, or it may exceed minimum within reasonable limits.
3. Submit to Owner permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, and similar documents, correspondence, and records establishing compliance with standards and regulations bearing upon performance of the Work.

B. Quality Assurance:

1. Testing and inspecting services are used to verify compliance with requirements specified or indicated. These services do not relieve Contractor of responsibility for compliance with Contract Document requirements.
2. Quality Assurance Services: Activities, actions, and procedures performed before and during execution of the Work to verify compliance and guard against defects and deficiencies and substantiate that proposed construction will comply with requirements. Owner or Owner's designated representative(s) will perform quality assurance to verify compliance with Contract Documents.
3. Notify Owner immediately if asbestos-containing materials or other hazardous materials are encountered while performing the Work.

C. Quality Control:

1. Quality Control Services:
 - a. Quality Control will be sole responsibility of Contractor.
 - 1) Tests, inspections, procedures, and related actions during and after execution of the Work to evaluate that actual products incorporated into the Work and completed construction comply with requirements performed by Contractor.
 - a) They do not include inspections, tests or related actions performed by Architect or Owner Representative, governing authorities or independent agencies hired by Owner or Architect.

- b) Quality assurance performed by Owner will be used to validate Quality Control performed by Contractor.
- 2) Where services are indicated as Contractor's responsibility, engage qualified Testing Agency to perform these quality control services:
 - a) Contractor will not employ same testing entity engaged by Owner, without Owner's written approval.

D. Repair And Protection:

1. On completion of testing, inspecting, sample taking, and similar services, repair damaged construction and restore substrates and finishes.
2. Protect construction exposed by or for Quality Assurance and Quality Control activities.
3. Repair and protection are Contractor's responsibility, regardless of assignment of responsibility for Quality Assurance and Quality Control Services.

SECTION 01 4301 QUALITY ASSURANCE - QUALIFICATIONS

A. Qualifications: Qualifications in this Section establish minimum qualification levels required; individual Specification Sections specify additional requirements:

1. Fabricator / Supplier / Installer Qualifications:
 - a. Firm experienced in producing products similar to those indicated for this Project and with record of successful in-service performance, as well as sufficient production capacity to produce required units:
 - 1) Where heading '*VMR (Value Managed Relationship) Suppliers / Installers*' is used to identify list of specified suppliers or installers, Owner has established relationships that extend beyond requirements of this Project. No other suppliers / installers will be acceptable. Follow specified procedures to preserve relationships between Owner and specified suppliers / installers and advantages that accrue to Owner from those relationships.
 - 2) Where heading '*Acceptable or Approved Suppliers / Installers / Fabricators*' is used to identify list of specified suppliers / installers / fabricators, use only one of listed suppliers / installers / fabricators. No others will be acceptable.
2. Factory-Authorized Service Representative Qualifications:
 - a. Authorized representative of manufacturer who is trained and approved by manufacturer to inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
3. Installer Qualifications:
 - a. Firm or individual experienced in installing, erecting, or assembling work similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with record of successful in-service performance.
4. Manufacturer Qualifications:
 - a. Firm experienced in manufacturing products or systems similar to those indicated for this Project and with record of successful in-service performance, as well as sufficient production capacity to produce required units.
5. Manufacturer's Field Services Qualifications:
 - a. Experienced authorized representative of manufacturer to inspect field-assembled components and equipment installation, including service connections.
6. Professional Engineer Qualifications:
 - a. Professional engineer who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing engineering services of kind indicated:
 - 1) Engineering services are defined as those performed for installations of system, assembly, or products that are similar to those indicated for this Project in material, design, and extent.
7. Specialists:
 - a. Certain sections of Specifications require that specific construction activities will be performed by entities who are recognized experts in those operations:
 - 1) Specialists will satisfy qualification requirements indicated and will be engaged for activities indicated.
 - 2) Requirement for special will not supersede building codes and regulations governing the Work.
8. Testing Agency Qualifications:
 - a. Independent Testing Agency with experience and capability to conduct testing and inspecting indicated, as documented according to ASTM E329; and with additional qualifications specified in

individual Sections; and where required by authorities having jurisdiction, that is acceptable to authorities.

- b. Testing Laboratory:
 - 1) AASHTO Materials Reference Laboratory (AMRL) Accreditation Program.
 - 2) Cement and Concrete Reference Laboratory (CCRL).
 - 3) Nationally Recognized Testing Laboratory (NRTL): Nationally recognized testing laboratory according to 29 CFR 1910.7.
 - 4) National Voluntary Laboratory (NVLAP): Testing Agency accredited according to National Institute of Standards and Technology (NIST) Technology Administration, U. S. Department of Commerce Accreditation Program.

SECTION 01 4523 TESTING AND INSPECTION SERVICES

A. Submittals:

1. Certificates: Testing Agency will submit certified written report of each inspection, test, or similar service.
2. Tests and Evaluation Reports:
 - a. Testing Agency or Agencies will prepare logs, test reports, and certificates applicable to specific tests and inspections and deliver copies to Owner's Representative and to each of following if involved on project: Architect, Consulting Engineers (Engineer of Record), General Contractor, Authorities Having Jurisdiction (if required).
3. Testing Agency:
 - a. Qualifications of Testing Agency management, personnel, inspector and technicians designated to project.
 - b. Provide procedures for non-destructive testing, equipment calibration records, personnel training records, welding inspection, bolting inspection, shear connector stud inspection, and seismic connection inspections.

B. Quality Assurance:

1. Owner or Owner's designated representative(s) will perform quality assurance. Owner's quality assurance procedures may include observations, inspections, testing, verification, monitoring and any other procedures deemed necessary by Owner to verify compliance with Contract Documents.
2. Owner will employ independent Testing Agencies to perform certain specified testing, as Owner deems necessary.
3. Certification:
 - a. Product producers and associations, which have instituted approved systems of quality control and which have been approved by document approval agencies, are not required to have further testing.
 - b. Concrete mixing plants, plants producing fabricated concrete and wood or plywood products certified by agency, lumber, plywood grade marked by approved associates, and materials or equipment bearing underwriters' laboratory labels require no further testing and inspection.
4. Written Practice for Quality Assurance:
 - a. Testing Agency will maintain written practice for selection and administration of inspection personnel, describing training, experience, and examination requirements for qualification and certification of inspection personnel.
 - b. Written practice will describe testing agency procedures for determining acceptability of structure in accordance with applicable codes, standards, and specifications.
 - c. Written practice will describe Testing Agency inspection procedures, including general inspection, material controls, visual welding inspection, and bolting inspection.

C. Quality Control:

1. Quality Control will be sole responsibility of Contractor. Contractor will be responsible for testing, coordination, start-up, operational checkout, and commissioning of all items of the Work included in Project. All costs for these services will be included in Contractor's cost of the Work.
2. Notify results of all Testing and Inspection performed by Contractor's independent Testing Agencies to Architect and/or Owner's Representative within 24 hours of test or inspection having been performed:
 - a. Testing and Inspection Reports will be distributed as follows:
 - 1) 1 copy to Owner's Representative.
 - 2) 1 copy to Architect.
 - 3) 1 copy to Consulting Engineer(s) (Engineer of Record).
 - 4) 1 copy to Authorities Having Jurisdiction (if required).
3. Contractor's Responsibility:

- a. Owner's employment of an independent Testing Agency does not relieve Contractor of Contractor's obligation to perform the Work in strict accordance with requirements of Contract Documents.
- b. Tests and inspections that are not explicitly assigned to Owner are responsibility of Contractor.
- c. Cooperate with Testing Agency(s) performing required inspections, tests, and similar services and provide reasonable auxiliary services as requested. Notify Testing Agency before operations to allow assignment of personnel. Auxiliary services required include but are not limited to:
 - 1) Providing access to the Work and furnishing incidental labor, equipment, and facilities deemed necessary by Testing Agency to facilitate inspections and tests at no additional cost to Owner.
 - 2) Taking adequate quantities of representative samples of materials that require testing or helping Testing Agency in taking samples.
 - 3) Providing facilities for storage and curing of test samples, and delivery of samples to testing laboratories.
 - 4) Providing Testing Agency with preliminary design mix proposed for use for materials mixes that require control by Testing Agency.
- d. For any requested inspection, Contractor will complete prior inspections to ensure that items are ready for inspection.
- e. All Work is subject to testing and inspection and verification of correct operation.
- f. Comply:
 - 1) Upon completion of Testing Agency's inspection, testing, sample-taking, and similar services, repair damaged construction and restore substrates and finishes to eliminate deficiencies, including deficiencies in visual qualities of exposed finishes.
 - 2) Comply with Contract Documents in making such repairs.
- g. Data:
 - 1) Furnish records, drawings, certificates, and similar data as may be required by testing and inspection personnel to assure compliance with Contract Documents.
- h. Defective Work (Non-Conforming Work): Non-conforming Work as covered in General Conditions applies, but is not limited to following requirements Protection:
 - 1) Where results of inspections, tests, or similar services show that the Work does not comply with Contract Document requirements, correct deficiencies in the Work promptly to avoid work delays.
 - 2) Where testing personnel take cores or cut-outs to verify compliance, repair prior to acceptance.
 - 3) Contractor will be responsible for any and all costs incurred resulting from inspection that was scheduled prematurely or retesting due to failed tests.
 - 4) Remove and replace any Work found defective or not complying with contract document requirements at no additional cost to Owner.
 - 5) Should test return unacceptable results, Contractor will bear all costs of retesting and re-inspection as well as cost of all material consumed by testing, and replacement of unsatisfactory material and/or workmanship.
- i. Protection:
 - 1) Protect construction exposed by or for quality assurance and quality control service activities, and protect repaired construction.
- j. Scheduling: Contractor is responsible for scheduling times for inspections, tests, taking samples, and similar activities:
 - 1) Schedule testing and inspections in advance so as not to delay the Work and to eliminate any need to uncover the Work for testing or inspection.
 - 2) Notify Testing Agency and Architect or Owner as noted in Sections in Division 01 thru Division 50 prior to any time required for such services.
 - 3) Incorporate adequate time for performance of all inspections and correction of noted deficiencies.
 - 4) Schedule sequence of activities to accommodate required services with minimum of delay.
 - 5) Schedule sequence of activities to avoid necessity of removing and replacing construction to accommodate testing and inspections.
- k. Test and Inspection Log:
 - 1) Provide system of tracking all field reports, describing items noted, and resolution of each item. Prepare record of tests and inspections. Include following requirements:
 - (a) Date test or inspection was conducted.
 - (b) Description of the Work tested or inspected.
 - (c) Date test or inspection results were transmitted to Architect or Owner Representative.
 - (d) Identification of Testing Agency or inspector conducting test or inspection.

- 2) Maintain log at Project site. Post changes and modifications as they occur. Provide access to test and inspection log for Architect's or Owner's reference during normal working hours.

D. Tests And Inspections - General:

1. Testing specifically identified to be conducted by Owner, will be performed by an independent entity and will be arranged and paid for by Owner.
2. Individual Sections in Division 01 through Division 50 indicate if Owner will provide testing and inspection of the Work of that Section.
3. Owner may engage additional consultants for testing, air balancing, commissioning, or other special services:
 - a. Activities of any such Owner consultants are in addition to Contractor testing of materials or systems necessary to prove that performance is in compliance with Contract requirements.
 - b. Contractor must cooperate with persons and firms engaged in these activities.
4. Tests include but not limited to those described in detail in 'Field Quality Control' in Part 3 of Individual Sections in Divisions 01 through Division 50.
5. Taking Specimens:
 - a. Only testing laboratory shall secure, handle, transport, or store any samples and specimens for testing.
6. Scheduling Testing Agency:
 - a. Contractor will coordinate the Work and facilitate timeliness of such testing and inspecting services so as not to delay the Work.
 - b. Contractor will notify Testing Agency and Architect or Owner Representative to schedule tests and / or inspections.

E. Testing Agency Services And Responsibility:

1. Testing Agency, including independent testing laboratories, will be licensed and authorized to operate in jurisdiction in which Project is located:
 - a. Approved Testing Agency Qualifications: Requirements of Section 01 4301 apply.
2. Testing and Inspection Services:
 - a. Testing Agency will not release, revoke, alter, or increase Contract Document requirements or approve or accept any portion of the Work.
 - b. Testing Agency will not give direction or instruction to Contractor.
 - c. Testing Agency will have full authority to see that the Work is performed in strict accordance with requirements of Contract Documents and directions of Owner's Representative and/or Architect.
 - d. Testing Agency will not provide additional testing and inspection services beyond scope of the Work without prior approval of Owner's Representative and/or Architect.
3. Testing Agency Duties:
 - a. Independent Testing Agency engaged to perform inspections, sampling, and testing of materials and construction specified in individual specification Sections will cooperate with Architect or Owner Representative and Contractor in performance of its duties and will provide qualified personnel to perform required inspections and tests.
 - b. Testing Agency will test or obtain certificates of tests of materials and methods of construction, as described herein or elsewhere in technical specification.
 - c. Testing Agency will provide management, personnel, equipment, and services necessary to perform testing functions as outlined in this section.
 - d. Testing Agency must have experience and capability to conduct testing and inspecting indicated by ASTM standards and that specializes in types of tests and inspections to be performed.
 - e. Testing Agency will comply with requirements of ASTM E329, ASTM E543, ASTM C1021, ASTM C1077, ASTM C1093, ASTM D3666, ASTM D3740, and other relevant ASTM standards.
 - f. Testing Agency must calibrate all testing equipment at reasonable intervals (minimum yearly) with accuracy traceable to either National Bureau of Standards or accepted values of natural physical constants.
 - g. Welding Procedure Review: Testing Agency will provide review and approval or rejection of all welding procedures to be used and verify compliance with all reference standard requirements.
4. Testing and Inspection Reports:
 - a. Conduct and interpret tests and inspections and state in each report whether tested and inspected Work complies with or deviates from requirements.
 - b. Laboratory Reports: Testing Agency will furnish reports of materials and construction as required, including:
 - 1) Description of method of test.

- 2) Identification of sample and portion of the Work tested:
 - (a) Description of location in the Work of sample.
 - (b) Time and date when sample was obtained.
 - (c) Weather and climatic conditions at time when sample was obtained.
- 3) Evaluation of results of tests including recommendations for action.
- c. Inspection Reports:
 - 1) Testing Agency will furnish "Inspection at Site" reports for each site visit documenting activities, observations, and inspections.
 - 2) Include notation of weather and climatic conditions, time and date conditions and status of the Work, actions taken, and recommendations or evaluation of the Work.
- d. Reporting Testing and Inspection (Conforming Work):
 - 1) Submit testing and inspection reports as required within twenty four (24) hours of test or inspection having been performed.
- e. Reporting Testing and Inspection Defective Work (Non-Conforming Work):
 - 1) Testing Agency, upon determination of irregularities, deficiencies observed or test failure(s) observed in the Work during performance of its services of test or inspection having been performed, will:
 - (a) Verbally notify results to Architect, Contractor, and Owner's Representative within one hour of test or inspection having been performed (if Defective Work (Non-Conforming Work) is incorporated into project).
 - (b) Submit written inspection report and test results as required within twenty four (24) hours of test or inspection having been performed.
- f. Final Report:
 - 1) Submit final report of tests and inspections at Substantial Completion, which identify unresolved deficiencies.

F. Architect's Responsibility:

1. Architect Duties:
 - a. Notify Owner's Representative before each test and/or inspection:

G. Field Quality Control:

1. Field Tests And Inspections:
 - a. Field Test and Inspection requirements are described in detail in 'Field Quality Control' in Part 3 Execution' of individual Sections in Division 01 thru Division 49.

SECTION 01 4546 DUCT TESTING, ADJUSTING, AND BALANCING

- A. See full section at end of General Requirements section.

SECTION 01 5000 TEMPORARY FACILITIES AND CONTROLS

A. Administrative Requirements:

1. Contractor is responsible for security of materials, tools, and equipment. Do not permit others to use building keys provided by Owner. Safeguard building and contents while the Work is being performed and secure building when the Work is finished for day.
2. Provide protection, operate temporary facilities, and conduct construction in ways and by methods that comply with environmental regulations and reduce possibility that air, waterways, and subsoil might be contaminated or polluted, or that other undesirable effects might result:
 - a. Avoid use of tools and equipment that produce harmful noise.
 - b. Restrict use of noisemaking tools and equipment to hours that will minimize complaints from persons or firms near site.
 - c. Protect the Work, materials, apparatus, and fixtures from injury due to weather, theft, and vandalism.
3. Existing restroom facilities may be used by Contractor. Clean restrooms and portions of existing building used in accessing restrooms daily. If existing facilities are not usable, provide and maintain temporary sanitary toilet.

B. Temporary Barriers And Enclosures:

1. Protect existing trees and plants. Remove and replace vegetation that dies or is damaged beyond repair due to construction activities.
2. Erect adequate barricades, warning signs, and lights necessary to protect persons from injury or harm.

3. Provide temporary enclosures at exterior building openings for security and protection from weather, theft, and vandalism. Erect and maintain dust-proof partitions and enclosures as required to prevent spread of dust and fumes to occupied portions of building.
4. Proprietary Camera Services: In its absolute discretion, and with or without notice to Contractor, Owner may provide from time to time, but is not obligated to provide, one or more cameras on or about Project site and/or signage or notices of the same:
 - a. If provided by Owner, such camera(s) and/or signage and notices are solely for Owner's benefit and convenience and shall not be for benefit of Contractor, Subcontractor(s) or for any third person.
 - b. Owner shall have no liability, obligation, or responsibility to Contractor, Subcontractors, or any third person relative to such camera(s), signage, or notices, or absence of camera(s), signage, or notices, including without limitation, installation, maintenance, operation, repair, testing, functionality, capacity, recording, monitoring, posting, etc., of the same (hereafter 'Proprietary Camera Services').
 - c. Contractor, with Owner's prior consent (which shall not be unreasonably withheld), may relocate such camera(s), signage, or notices as necessary to not unreasonably, materially and physically interfere with work at Project Site.
 - d. Contractor's obligations under Contract Documents, including but not limited to, Contractor's obligation for security of Project Site, are not modified by Owner's opportunity to provide, actually providing, or not providing Proprietary Camera Services and/or signage or notices regarding the same.
 - e. This Specification Section does not preclude Contractor from providing its own camera(s), signage, or notices pursuant to terms and conditions of this Agreement. Neither does this Section reduce, expand or modify any other right or obligation of Owner pursuant to terms of this Agreement.

C. Utilities:

1. Electrical Power: Owner will provide electric power for construction activities within limits available at existing facility.
2. Fire Protection: Exercise caution to avoid fire damage: Do not build fires on site.
3. Heating, Cooling, And Ventilation:
 - a. Permanent mechanical system may be operated upon following conditions:
 - 1) Do not interfere with normal set-back temperature patterns except as approved by Project Manager.
 - 2) Do not operate system when the Work causing airborne dust is occurring or when dust caused by such Work is present without first installing temporary filtering system.
4. Lighting: Existing lighting system may be used by Contractor.
5. Water Service: Contractor will use existing water supply for construction purposes to extent of existing facilities.

SECTION 01 6100 COMMON PRODUCT REQUIREMENTS

A. Administrative Requirements:

1. Provide products that comply with Contract Documents, are undamaged, and, unless otherwise indicated, are new and unused at time of installation. Provide products complete with accessories, trim, finish, safety guards, and other devices and details needed for complete installation and for intended use and effect.

SECTION 01 6200 PRODUCT OPTIONS

A. Product selection is governed by Contract Documents and governing regulations, not by previous Project experience. Procedures governing product selection include:

1. Substitutions And Equal Products:
 - a. Generally speaking, substitutions for specified products and systems, as defined in Uniform Commercial Code, are not acceptable. However, equal products may be approved upon compliance with Contract Document requirements.
 - b. Approved Products / Manufacturers / Suppliers / Installers:
 - 1) Category One:
 - (a) Owner has established 'Value Managed Relationships' that extend beyond requirements of this Project. No substitutions or equal products will be allowed on this Project.
 - (b) Follow specified procedures to preserve relationships between Owner and specified manufacturers / suppliers and advantages that accrue to Owner from those relationships.
 - 2) Category Two:

- (a) Owner has established National Contracts that contain provisions extending beyond requirements of this Project. No substitutions or equal products will be allowed on this Project.
- (b) Follow specified procedures to preserve relationships between Owner and specified manufacturers / suppliers and advantages that accrue to Owner from those relationships.
- 3) Category Three:
 - (a) Specified products are provided to Church Projects under a National Account Program. Use these products to preserve advantages that accrue to Owner from those programs. No substitutions or equal products will be allowed on this Project.
- 4) Category Four:
 - (a) Provide only specified products available from manufacturers listed. No substitutions, private-labeled, or equal products, or mixing of manufacturers' products is allowed on this Project.
 - (b) In Sections where lists recapitulating Manufacturers previously mentioned in Section are included under heading '*Manufacturers*' or '*Approved Manufacturers*', this is intended as convenience to Contractor as listing of contact information only. It is not intended that all manufacturers in list may provide products where specific products and manufacturers are listed elsewhere in Section.
- c. Acceptable Products / Manufacturers / Suppliers / Installers:
 - 1) Type One: Use specified products / manufacturers unless approval to use other products / manufacturers has been obtained from Architect or Owner Representative by Addendum.
 - 2) Type Two: Use specified products / manufacturers unless approval to use other products and manufacturers has been obtained from Architect or Owner Representative in writing before installing or applying unlisted or private-labeled products.
 - 3) Use 'Equal Product Approval Request Form' to request approval of equal products, manufacturers, or suppliers before bidding or before installation, as noted in individual Sections.
- d. Quality / Performance Standard Products / Manufacturers:
 - 1) Class One: Use specified product / manufacturer or equal product from specified manufacturers only.
 - 2) Class Two: Use specified product / manufacturer or equal product from any manufacturer.
 - 3) Products / manufacturers used will conform to Contract Document requirements.

SECTION 01 6400 OWNER-FURNISHED PRODUCTS

A. Administrative Requirements:

- 1. Install items furnished by Owner or receive and store in safe condition items purchased directly by Owner according to requirements of Contract Documents.

SECTION 01 6600 DELIVERY, STORAGE, AND HANDLING REQUIREMENTS

A. Administrative Requirements:

- 1. Deliver, store, and handle products according to manufacturer's recommendations, using means and methods that will prevent damage, deterioration, and loss, including theft.

B. Delivery, Storage, and Handling:

- 1. Delivery and Acceptable Requirements:
 - a. Deliver, store, and handle products according to manufacturer's recommendations, using means and methods that will prevent damage, deterioration, and loss, including theft.
 - b. Coordinate delivery with installation time to ensure minimum holding time for items that are flammable, hazardous, easily damaged, or sensitive to deterioration, theft, and other losses.
 - c. Deliver products to site in manufacturer's original sealed container or other packaging system, complete with labels and instructions for handling, storing, unpacking, protecting, and installing.
 - d. Inspect products upon delivery to ensure compliance with Contract Documents, and to ensure that products are undamaged and properly protected.
- 2. Storage and Handling Requirements:
 - a. Store products at site in manner that will simplify inspection and measurement of quantity or counting of units.
 - b. Store heavy materials away from Project structure so supporting construction will not be endangered.

- c. Store products subject to damage by elements above ground, under cover in weather tight enclosure, with ventilation adequate to prevent condensation. Maintain temperature and humidity within range required by manufacturer's instructions.

SECTION 01 7000 EXECUTION REQUIREMENTS

A. Administrative Requirements:

1. Require installer of each major component to inspect both substrate and conditions under which the Work is to be done:
 - a. Notify Owner in writing of unsatisfactory conditions.
 - b. Do not proceed until unsatisfactory conditions have been corrected.

B. Common Installation Provisions:

1. Provide attachment and connection devices and methods necessary for securing the Work:
 - a. Secure the Work true to line and level.
 - b. Allow for expansion and building movement.
2. Recheck measurements and dimensions before starting each installation.
3. Design, furnish, and install all shoring, bracing, and sheathing as required for safety and for proper execution of the Work and, unless otherwise required, remove same when the Work is completed.
4. Where mounting heights are not shown, install individual components at standard mounting heights recognized within industry or local codes for that application. Refer questionable mounting height decisions to Owner for final decision.

C. Protection:

1. Cover and protect furniture, equipment, and fixtures from soiling and damage when demolition the Work is performed in rooms and areas from which such items have not been removed.

D. Completion Inspection:

1. Upon 100 percent completion of Project, Contractor will request Substantial Completion Inspection.
2. Owner will conduct Substantial Completion Inspection in presence of Contractor and furnish list of items to be corrected.
3. Contractor will notify Owner in writing when items have been corrected.

SECTION 01 7400 CLEANING AND WASTE MANAGEMENT

A. Disposal Of Waste:

1. Except for items or materials to be salvaged, recycled, or otherwise reused, remove waste materials from Project site and legally dispose of them in landfill or incinerator acceptable to authorities having jurisdiction:
 - a. Except as otherwise specified, do not allow waste materials that are to be disposed of accumulate on-site.
 - b. Remove and transport debris in manner that will prevent spillage on adjacent surfaces and areas.
2. Burning: Do not burn waste materials.
3. Disposal: Transport waste materials off Owner's property and legally dispose of them.

B. Progress Cleaning:

1. Keep premises broom-clean during progress of the Work.
2. During handling and installation, protect construction in progress and adjoining materials in place. Apply protective covering where required to ensure protection from soiling, damage, or deterioration until Substantial Completion.
3. Clean and maintain completed construction as frequently as necessary throughout construction period.
4. Remove waste materials and rubbish caused by employees, subcontractors, and contractors under separate contract with Owner and dispose of legally.

C. Final Cleaning:

1. Clean each surface or unit to condition expected in normal, commercial-building cleaning and maintenance program. Comply with manufacturer's instructions. Remove all rubbish from under and about building and leave building clean and habitable.

2. In addition to general cleaning noted above, perform cleaning for all trades at completion of the Work in areas where construction activities have occurred.
3. If Contractor fails to clean up, Owner may do so and charge cost to Contractor.

SECTION 01 7700 CLOSEOUT PROCEDURES

A. General:

1. Closeout process consists of three specific project closeout inspections. Contractor shall plan sufficient time in construction schedule to allow for required inspections before expiration of Contract Time.
2. Contractor shall conduct his own inspections of The Work and shall not request closeout inspections until The Work of the contract is reasonably complete and correction of obvious defects or omissions are complete or imminent.
3. Date of Substantial Completion shall not occur until completion of construction work, unless agreed to by Architect / Owner's Representative and included on Certificate of Substantial Completion.

B. Preliminary Closeout Review:

1. When Architect, Owner and Contractor agree that project is ready for closeout, Pre-Substantial Inspection shall be scheduled. Preparation of floor substrate to receive carpeting and any work which could conceivably damage or stain carpet must be completed, as carpet installation will be scheduled immediately following this inspection.
2. Prior to this inspection, completed test and evaluation reports for HVAC system and font, where one occurs, are to be provided to Project Manager, Architect, and applicable consultants.
3. Architect, Owner and Contractor review completion of punch list items. When Owner and Architect confirm that Contractor has achieved Substantial Completion of The Work, Owner, Architect and Contractor will execute Certificate of Substantial Completion that contains:
 - a. Punch list of items requiring completion and correction will be created.
 - b. Time frame for completion of punch list items will be established, and date for Substantial Completion Inspection shall be set.

C. Substantial Completion Inspection:

1. When Architect, Owner and Contractor agree that project is ready for Substantial Completion, an inspection is held. Punch list created at Pre-Substantial Inspection is to be substantially complete.
2. Prior to this inspection, Contractor shall discontinue or change over and remove temporary facilities from the site, along with construction tools, mock-ups and similar elements.
3. Architect, Owner and Contractor review completion of punch list items. When Owner and Architect confirm that Contractor has achieved Substantial Completion of The Work, Owner, Architect and Contractor will execute Certificate of Substantial Completion that contains:
 - a. Date of Substantial Completion.
 - b. Punch List Work not yet completed, including seasonal and long lead items.
 - c. Amount to be withheld for completion of Punch List Work.
 - d. Time period for completion of Punch List Work.
 - e. Amount of liquidated damages set forth in Supplementary Conditions to be assessed if Contractor fails to complete Punch List Work within time set forth in Certificate.
4. Contractor shall present Closeout Submittals to Architect and place tools, spare parts, extra stock, and similar items required by Contract Documents in locations as directed by Facilities Manager.

D. Final Acceptance Meeting:

1. When punch list items except for any seasonal items or long lead items which will not prohibit occupancy are completed, Final Acceptance Meeting is held.
2. Owner, Architect and Contractor execute Owner's Project Closeout - Final Acceptance form, and verify:
 - a. All seasonal and long lead items not prohibiting occupancy, if any, are identified, with committed to completion date and amount to be withheld until completion.
 - b. Owner's maintenance personnel have been instructed on all system operation and maintenance as required by the Contract Documents.
 - c. Final cleaning requirements have been completed.
3. If applicable, once any seasonal and long lead items are completed, Closeout Inspection is held where Owner and Architect verify that The Work has been satisfactorily completed, and Owner, Architect and Contractor execute Closeout portion of the Project Closeout - Final Acceptance form.
4. When Owner and Architect confirm that The Work is satisfactorily completed, Architect will authorize final payment.

SECTION 01 7800 CLOSEOUT SUBMITTALS**A. Administrative Requirements:**

1. Project Record Documents:
 - a. Do not use record documents for construction purposes:
 - 1) Protect from deterioration and loss in secure, fire-resistive location.
 - 2) Provide access to record documents for reference during normal Working hours.
 - b. Maintain clean, undamaged set of Drawings. Mark set to show actual installation where installation varies from the Work as originally shown. Give particular attention to concealed elements that would be difficult to measure and record at later date:
 - 1) Mark record sets with red erasable pencil. Use other colors to distinguish between variations in separate categories of the Work.
 - 2) Mark new information that is important to Owner, but was not shown on Contract Drawings.
 - 3) Note related Change Order numbers where applicable.
2. As Built Record Drawings:
 - a. Provide two full-size sets of prints and PDF file of As Built Record Drawings to Facilities Management Office, printed from the updated AutoCAD drawing files or updated Revit model files, as specified by Owner, that have been modified to show actual dimensions and location of equipment, material, utility lines, and other work as actually constructed, based upon information provided by Contractor. Architect will submit updated As Built Record Drawings in PDF (ISO32000 format) to Owner. In addition, Architect will submit to Owner updated AutoCAD as built record drawing files with associated plot style tables or the Revit as built record model files, as specified by Owner.

B. Operations And Maintenance Manual:

1. General:
 - a. Include closeout submittal documentation as required by Contract Documentation. Include only closeout submittals as defined in individual specification section.
 - b. Submittal Format: Digital copies unless otherwise noted, required for each individual specification section that include 'Closeout Submittals'.
2. Project Manual:
 - c. Copy of complete Project Manual including Addenda, Modifications as defined in General Conditions, and other interpretations issued during construction:
 - (1) Mark these documents to show variations in actual Work performed in comparison with text of specifications and Modifications.
 - (2) Show substitutions, selection of options, and similar information, particularly on elements that are concealed or cannot otherwise be readily discerned later by direct observation.
3. Maintenance Contracts: (digital format only).
4. Operations and Maintenance Data (digital format only):
 - a. Operations and maintenance submittals including cleaning instructions, maintenance instructions, operations instructions, equipment list, and parts lists.
5. Warranty Documentation: Digital format of final, executed warranties.
6. Record Documentation:
 - a. Documentation includes Certifications, color and pattern selections, Design Date, Geotechnical Evaluation Reports (soils reports), Manufacture Reports, Literature or cut sheets, Shop Drawings, Source Quality Control, Special Procedures, and Testing and Inspection Reports.
7. Software: Audio and Video System software, programming and set-files.
8. Irrigation Plan: Laminated and un-laminated reduced sized hard copies.
9. Landscape Management Plan (LMP):
 - a. Irrigation Section:
 - (1) Documentation required by Sections under 32 8000 Heading: Irrigation.
 - b. Landscaping Section:
 - (1) Documentation required by Sections under 32 8000 Heading: Irrigation.

C. Warranties:

1. When written guarantees beyond one (1) year after substantial completion are required by Contract Documents, secure such guarantees and warranties properly addressed and signed in favor of Owner. Include these documents in Operations & Maintenance Manual(s) specified above.
2. Delivery of guarantees and warranties will not relieve Contractor from obligations assumed under other provisions of Contract Documents.

END OF SECTION

SECTION 01 4546**DUCT TESTING, ADJUSTING, AND BALANCING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Test, balance, and adjust air duct systems as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 01 0000: 'General Requirements':
 - a. Section 01 1200: Multiple contracts.
 - b. Section 01 4000: 'Quality Requirements' for administrative and procedural requirements for quality assurance and quality control.
 - c. Section 01 4301: 'Quality Assurance – Qualifications' establishes minimum qualification levels required.
 - d. Section 01 4523: 'Testing and Inspecting Services' for testing and inspection, and testing laboratory services for materials, products, and construction methods.
 - e. Section 01 7800: 'Closeout Submittals'.
 - 2. Division 23:
 - a. Completing installation and start-up of mechanical systems, and changing sheaves, belts, and dampers as required for correct balance.
 - b. Maintain HVAC system and equipment in full operation each working day of testing, balancing, and adjusting.

1.2 REFERENCES

- A. Definitions (Following are specifically referenced for testing):
 - 1. Approved: To authorize, endorse, validate, confirm, or agree to.
 - 2. Field Quality Assurance: Testing, Inspections, Special Testing and Special Inspections provided for by Owner.
 - 3. Field Quality Control: Testing, Inspections, Special Testing and Special Inspections provided for by Contractor.
 - 4. Inspection/Special Inspection: Inspection of materials, installation, fabrication, erection or placement of components and connections requiring special expertise to ensure compliance with approved construction documents and referenced standards. "Inspection" is not required by code provisions but may be required by Contract Documents. "Special inspection" is required by code provisions and by Contract Documents.
 - a. Inspection-Continuous: Full-time observation of the Work requiring inspection by approved inspector who is present in area where the Work is being performed.
 - b. Inspection-Periodic: Part-time or intermittent observation of the Work requiring inspection by approved inspector who is present in area where the Work has been or is being performed and at completion of the Work.
 - 5. Installer/Applicator/Erector: Contractor or another entity engaged by Contractor as an employee, Subcontractor, or Sub-subcontractor, to perform particular construction operation, including installation, erection, application, and similar operations.
 - 6. Observation: Visual observation of building / site elements or structural system by registered design professional for general conformance to approved construction documents at significant construction stages and at completion. Observation does not include or waive responsibility for performing inspections or special inspections.
 - 7. Owner's Representative: Owner's Designated Representative (Project Manager or Facilities Manager) whom will have express authority to bind Owner with respect to all matters requiring Owner's approval or authorization.
 - 8. Service Provider: Agency or firm qualified to perform required tests and inspections.

9. Testing Agency: Entity engaged to perform specific tests, inspections, or both.
10. Test/Special Test: Field or laboratory tests to determine characteristics and quality of building materials and workmanship. "Test" is not required by code provisions but may be required by Contract Documents. "Special test" is required by code provisions and by Contract Documents.
11. Verification: Act of reviewing, inspecting, testing, etc. to establish and document that product, service, or system meets regulatory, standard, or specification requirements.

B. Reference Standards:

1. ASTM International (Following are specifically referenced for Testing Agencies):
 - a. ASTM E329-09: 'Standard Specification for Agencies Engaged in Construction Inspection and/or Testing.'

1.3 ADMINISTRATIVE REQUIREMENTS

A. Coordination:

1. Assisting Testing Agency in testing and balancing of mechanical system.

B. Scheduling:

1. Schedule this work in cooperation with other Sections involved and to comply with completion date for test, balance, and adjust air duct systems as described in Contract Documents.
2. Contact Testing Agency and coordinate:
 - a. One inspection when 90 percent of equipment and ductwork is installed.
3. Contact Testing Agency and coordinate date(s) for test and balance work when following is completed:
 - a. HVAC and exhaust systems including installation of specialties, devices, and new filters.
 - b. Proper function of control system components including electrical interlocks, damper sequences, air and water reset, and fire and freeze stats has been verified.
 - c. Automatic temperature controls have been calibrated and set for design operating conditions.
 - d. Verification of proper thermostat calibration and setting of control components such as static pressure controllers and other devices that may need set points changed during process of balancing system.
4. If, in opinion of Testing Agency, systems are not ready for test and balance, reschedule as required.

1.4 SUBMITTALS

A. Informational Submittals:

1. Test and Evaluation Reports:
 - a. Preliminary Report:
 - 1) Four copies to be given to Owner's Representative.
 - b. Final Report :
 - 1) Four copies to be given to Owner's Representative.

B. Closeout Submittals:

1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Record Documentation:
 - 1) Testing and Inspection Reports:
 - a) Testing Agency Testing and Evaluation Final Report of testing, balancing, and adjusting air duct systems. Bind approved copy of Testing and Evaluation Report in Operations And Maintenance Manual for Division 23.

1.5 QUALITY ASSURANCE

A. Qualifications:

1. Approved Testing Agency. Section 01 4301 applies, but is not limited to following:

- a. Testing Agency shall specialize in testing and balancing of heating, ventilating, and cooling systems to balance, adjust, and test air moving equipment, air distribution, and exhaust systems.
 - b. Testing Agency shall provide proof of having successfully completed at least five years of specialized experience in air and hydronic system balancing.
 - c. Testing Agency shall provide testing under direct supervision of qualified heating and ventilating engineer.
 - d. Neither Architect's engineering consultant nor anyone performing work on this Project under other Sections of Division 23 shall be permitted to do this work.
2. Testing and Inspection.
 - a. Owner will provide Testing and Inspection for testing, balancing, and adjusting air duct systems:
 - 1) See Section 01 1200: 'Multiple Contract Summary'.

PART 2 - PRODUCTS: Not Used

PART 3 - EXECUTION

3.1 FIELD QUALITY CONTROL

A. Field Tests:

1. Air System Testing, Adjusting, And Balance:
 - a. Inspections and site visits. (For paragraph a thru c, note deficiencies, if any, that needs to be corrected and report this to Owner's Representative, Architect, and Mechanical Engineer):
 - 1) One inspection when equipment installation is 90% complete.
 - 2) Site visit for test and balance. Before commencing test and balance, perform an inspection to verify 100% completion of system. Confirm completion of work, correction of previously noted deficiencies, and look for new deficiencies not noted in previous inspections. If the work is complete, then proceed with test and balance. If the work is not complete and ready for test and balance, inform Contractor and submit an invoice to Owner's Representative for compensation for travel time, expenses, and time on site. Report deficiencies or incomplete work to Owner's Representative, Architect, and Mechanical Engineer.
 - 3) Additional site visits (beyond those set forth above) to complete the work after issues are resolved may be needed and will be paid for separately from compensation for services set forth in this Agreement, pursuant to hourly rates and conditions set forth in Attachment "A".
 - b. Checklist for Inspections and site visits:
 - 1) Pre-Startup Inspection – use for inspections and site visits a thru d in paragraph 1 above. All pertinent items shall be checked, including but not limited to following:
 - a) Removal of shipping blocks and stops.
 - b) Vibration isolators' alignment and adjustment.
 - c) Flexible connections properly installed and aligned.
 - d) Safety controls, safety valves and high or low limits in operation.
 - e) All systems properly filled.
 - f) Filters in place and seal provided around edges.
 - g) Filters and strainers are clean.
 - h) Fire damper installation and operation, and access door installation.
 - i) Installation of all gauges on equipment.
 - j) Control system is operating.
 - k) All dampers, valves, and operators are properly installed and operating.
 - l) All ductwork is installed and sealed.
 - m) Voltage to unit matches nameplate voltage.
 - 2) First Run Inspection – use for inspections and site visits d and e in paragraph 1 above. Recheck items in Pre-Startup list, and check for following items:
 - a) Excessive vibration or noise.

- b) Loose components.
 - c) Initial control settings.
 - d) Motor amperages.
 - e) Heat buildup in motors.
 - f) Control system is calibrated and functioning as required.
- 3) System Operation Inspection – use for inspections and site visits d and e in paragraph 1 above. Observe mechanical systems under operation for sufficient amount of time to ensure proper operation in all running modes. Check following items periodically.
- a) Filters and strainers.
 - b) Filters and strainers.
 - c) Check for system leaks at seals and valves.
- c. Performance Requirements:
- 1) Testing and balancing in complete accordance with Associated Air Balance Council (AABC) Standards for Field Measurement & Instructions, Form P1266, Volume I.
 - 2) Noise level in chapel and / or cultural hall shall not exceed NC 35 with all HVAC equipment operating in full or second stage cooling mode.
- d. Site tests: Air Test and Balancing Procedure:
- 1) Instruments used by Consultant shall be accurately calibrated and maintained in good working order.
 - 2) All supply air and return air fans in all HVAC zone systems, energy recovery ventilators, and exhaust fans in building shall be operating when final setup of all units is performed.
 - 3) Perform tests at high and low speeds of multi-speed systems and single speed systems.
 - 4) Perform following testing and balancing functions in accordance with Associated Air Balance Council National Standards.
 - a) Fan Speeds - Air handling units (with variable pitch pulleys and sheaves): Test and adjust fan RPM to achieve design CFM requirements.
 - b) Fan Speeds - Furnaces (with direct drive motors): Set fan speed to lowest possible setting that will achieve design CFM requirements. Adjust down from Contractor setting, if necessary. Adjust low voltage fan speed jumpers (provided and installed by installing contractor) as necessary to achieve design cooling air flow at lowest possible setting. An exception to this would be when furnace is variable speed blower for dehumidification applications.
 - c) Current And Voltage: Measure and record motor current and voltage.
 - d) Pitot-Tube Traverse Method:
 - (1) Make measurements in duct where velocity is uniform, 7-1/2 duct diameters downstream and 2 duct diameters minimum upstream from any turbulence, i.e., elbow, damper, take-off, etc.
 - (2) Perform pitot-tube traverse of outdoor ventilation air duct serving each piece of air moving equipment.
 - (3) Where single outdoor ventilation air trunk duct serves multiple pieces of equipment, perform pitot-tube traverse of duct branch serving each piece of equipment as well as pitot-tube traverse of total air flow in trunk with all pieces of equipment operating.
 - e) Where pitot-tube traverse is not possible or if pitot-tube traverse is unreliable, flow hood measurement over exterior intake louver or grille is acceptable for measuring outdoor ventilation air.
 - f) Use proportionate method of air balance leaving fan at lowest possible speed and at least one branch balance damper fully open.
 - 5) Static Pressure: Test and record system static pressures, including suction and discharge static pressure of each fan.
 - 6) Air Temperature: Take wet and dry bulb air temperatures on entering and leaving side of each cooling coil. Dry bulb temperatures shall be taken on entering and leaving side of each heating unit.
 - 7) Zone Ducts: Adjust zone ducts to within design CFM requirements. At least one zone balancing damper shall be completely open.
 - 8) Branch Ducts: Adjust branch ducts to within design CFM requirements. Multi-diffuser branch ducts shall have at least one outlet or inlet volume damper completely open.

- 9) Tolerances: Test and balance all fans, zone ducts, registers, diffusers etc. to + or – 5% of design. When multiple registers and/or diffusers serve common space tolerances can be + or – 10% for outlet to outlet balance, but total air flow in space shall be + or – 5% of design requirements.
 - 10) Identification: Identify location and area of each grille, diffuser, register, and terminal box. Record on air outlet data sheets.
 - 11) Description: Record size, type, and manufacturer of each diffuser, grille, and register on air outlet data sheets.
 - 12) Drafts: Adjust diffusers, grilles, and registers to minimize drafts. For high sidewall supply air diffusers install horizontal blade core to direct air flow upward 15° and set adjustable vertical blades to spread air flow horizontally and evenly in fan pattern.
 - 13) Permanently mark all outside air, supply air, and return air damper positions after balancing has been completed.
 - 14) Smoke testing: Smoke testing, or some other approved means, may be required to determine leak locations if air balance report indicates that any system's CFM total is less than 90 percent of design CFM. Prior to test, verify that system's duct joints have been sealed as specified and that air moving device in question is supplying required design system air flow. Mechanical Engineer will approve test method required. If smoke test is selected, use following procedure. Provide necessary precautions to protect those performing or observing test from being exposed to smoke.
 - a) Use zinc chloride smoke candles, titanium tetrachloride ampules or sticks, or other devices acceptable to Mechanical engineer to generate smoke.
 - b) Close openings in duct except for one opening at farthest end of duct run.
 - c) Circulate smoke at pressurized condition of **1/2 inch (13 mm)** minimum water gauge static pressure.
 - d) Report findings to mechanical engineer in writing.
- e. Air System Test and Evaluation Report:
- 1) Record test data on AABC standard forms or facsimile.
 - 2) Preliminary Report: Provide and deliver four copies of complete data for evaluation and approval to Owner.
 - 3) Final report: Provide and deliver complete four copies of final report to Owner prior to project Substantial Completion date.
 - 4) Complete with logs, data, and records as required herein. Print logs, data, and records on white bond paper bound together in report form.
 - 5) Certified accurate and complete by Consultant's certified test and balance engineer.
 - 6) Contain following general data in format selected by Consultant:
 - a) Project Number.
 - b) Project Title.
 - c) Project Location.
 - d) Project Architect and Mechanical Engineer.
 - e) Consultant and Certified Engineer.
 - f) Contractor and mechanical sub-contractor.
 - g) Dates tests were performed.
 - h) Certification Document.
 - i) Report Forms similar to AABC Standard format.
 - 7) Report shall include following:
 - a) Instrumentation List including type, model, manufacturer, serial number, and calibration dates.
 - b) HVAC zone identification to include reduced ductwork floor plan from project documents with outlets and inlets numbered to match written test and balance report. This page may be oversized but it should fold up neatly within standard 8 1/2 x 11 report paper size.
 - c) Record following for each piece of air handling equipment:
 - (1) Manufacturer, model number, and serial number.
 - (2) Design and manufacture rated data.
 - (3) Actual CFM.
 - (4) Suction and discharge static pressure of each fan.
 - (5) Outdoor-ventilation-air and return-air total CFM.
 - (6) Final RPM of each motor or speed tap.
 - (7) Actual operating current, voltage, and brake horsepower of each fan motor.

- (8) Fan and motor sheave manufacturer, model, size, number of grooves and center distance.
- (9) Belt size and quantity.

3.2 PREPARATION

- A. Heating, ventilating, and cooling systems and equipment shall be in full operation and continue in operation during each working day of testing and balancing.

END OF SECTION

DIVISION 02: EXISTING CONDITIONS

02 4000 DEMOLITION AND STRUCTURE MOVING

02 4119 SELECTIVE STRUCTURE DEMOLITION

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 02 4119**SELECTIVE STRUCTURE DEMOLITION****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Demolition and removal of selected portions of building or structure.
 - 2. Salvage of existing items to be reused or recycled.
- B. Related Requirements:
 - 1. Section 26 0501: 'Common Electrical Requirements' for salvage of existing electrical items to be reused or recycled removed by Owner.

1.2 REFERENCES

- A. Reference Standards:
 - 1. National Fire Protection Association / American National Standards Institute:
 - a. NFPA 241, 'Standard for Safeguarding Construction, Alteration, and Demolition Operations', 2013 Edition.
 - 2. American Society of Safety Engineers:
 - a. ASSE A10.6-2006, 'Safety Requirements for Demolition Operations'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Storage or sale of removed items or materials will not be permitted on-site.
- B. Pre-Installation Conference:
 - 1. Before beginning Selective Demolition work, in addition to requirements of Section 01 3100, meet on site to confirm work to be demolished, items to be salvaged or reused, and coordination with Owner.
- C. Scheduling:
 - 1. Indicate detailed sequence of selective demolition and removal work, with starting and ending dates for each activity, on Schedule specified in Section 01 3200.

1.4 SUBMITTALS

- A. Informational Submittals:
 - 1. Special Procedure Submittals:
 - a. Inventory:
 - 1) After selective demolition is complete, submit list of items that have been removed and salvaged.

1.5 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:

1. Comply with governing EPA notification regulations before beginning selective demolition.
2. Comply with hauling and disposal regulations of authorities having jurisdiction.
3. Standards: Comply with ANSI A10.6 and NFPA 241.

1.6 FIELD CONDITIONS

A. Existing Conditions:

1. Conditions existing at time of inspection for bidding purpose will be maintained by Owner as far as practical.

PART 2 - PRODUCTS: Not Used

PART 3 - EXECUTION

3.1 EXAMINATION

A. Verification Of Conditions:

1. Survey existing conditions and correlate with requirements indicated to determine extent of selective demolition required.
 - a. Notify Architect of discrepancies between existing conditions and Drawings before proceeding with selective demolition.

B. Evaluation And Assessment:

1. Hazardous Materials:
 - a. It is not expected that hazardous materials will be encountered in the Work. Identified hazardous materials will be removed by Owner before start of the Work.
 - b. If materials suspected of containing hazardous materials are encountered, do not disturb and immediately notify Architect.
2. Inventory and record condition of items to be removed and reinstalled and items to be removed and salvaged.
3. When unanticipated mechanical, electrical, or structural elements that conflict with intended function or design are encountered, investigate and measure nature and extent of conflict. Promptly submit written report to Architect.
4. Engage a professional engineer to survey condition of building to determine whether removing any element might result in structural deficiency or unplanned collapse of any portion of structure or adjacent structures during selective demolition operations.
5. Perform surveys as the Work progresses to detect hazards resulting from selective demolition activities.

3.2 PREPARATION

A. Temporary Facilities:

1. Provide temporary barricades and other protection required to prevent injury to people and damage to adjacent buildings and facilities to remain.
2. Maintain fire-protection facilities in service during selective demolition operations.

B. Temporary Shoring:

1. Provide and maintain shoring, bracing, and structural supports as required to preserve stability and prevent movement, settlement, or collapse of construction and finishes to remain, and to prevent unexpected or uncontrolled movement or collapse of construction being demolished.
2. Strengthen or add new supports when required during progress of selective demolition.

C. Utility Services:

1. Existing Services/Systems: Maintain services/systems indicated to remain and protect them against damage during selective demolition operations.
2. Service/System Requirements: Locate, identify, disconnect, and seal or cap off indicated utility services and mechanical/electrical systems serving areas to be selectively demolished.
 - a. Arrange to shut off indicated utilities with utility companies.
 - b. If services/systems are required to be removed, relocated, or abandoned, before proceeding with selective demolition, provide temporary services/systems that bypass area of selective demolition and that maintain continuity of services/systems to other parts of building.

3.3 SELECTIVE DEMOLITION

A. General:

1. Conduct selective demolition and debris-removal operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
2. Demolish and remove existing construction only to extent required by new construction and as indicated. Use methods required to complete the Work within limitations of governing regulations and as follows:
 - a. Neatly cut openings and holes plumb, square, and true to dimensions required. Use cutting methods least likely to damage construction to remain or adjoining construction. Use hand tools or small power tools designed for sawing or grinding, not hammering and chopping, to minimize disturbance of adjacent surfaces. Temporarily cover openings to remain.
 - b. Cut or drill from the exposed or finished side into concealed surfaces to avoid marring existing finished surfaces.
 - c. Do not use cutting torches until work area is cleared of flammable materials. At concealed spaces, such as duct and pipe interiors, verify condition and contents of hidden space before starting flame-cutting operations. Maintain fire watch and portable fire-suppression devices during flame-cutting operations.
 - d. Maintain adequate ventilation when using cutting torches.
 - e. Remove decayed, vermin-infested, or otherwise dangerous or unsuitable materials and promptly dispose of off-site.
 - f. Remove structural framing members and lower to ground by method suitable to avoid free fall and to prevent ground impact or dust generation.
 - g. Locate selective demolition equipment and remove debris and materials so as not to impose excessive loads on supporting walls, floors, or framing.
 - h. Dispose of demolished items and materials promptly.

B. Selective Demolition Procedures For Specific Materials:

1. Concrete: Demolish in sections. Cut concrete full depth at junctures with construction to remain and at regular intervals, using power-driven saw, then remove concrete between saw cuts.
2. Masonry: Demolish in small sections. Cut masonry at junctures with construction to remain, using power-driven saw, then remove masonry between saw cuts.
3. Concrete Slabs-on-Grade: Saw-cut perimeter of area to be demolished, then break up and remove.

C. Removed and Salvaged Items:

1. Relics, and similar objects including, but not limited to, cornerstones and their contents, commemorative plaques and tablets, antiques, and other items of interest or value to Owner that may be encountered during selective demolition remain Owner's property. Carefully remove and salvage each item or object in a manner to prevent damage and deliver promptly to Owner.
 - a. Clean salvaged items as directed by Owner.
 - b. Pack or crate items after cleaning. Identify contents of containers.
 - c. Store items in a secure area until delivery to Owner.
 - d. Transport items to Owner's storage area designated by Owner.
 - e. Protect items from damage during transport and storage.

D. Removed and Reinstalled Items:

1. Clean and repair items to functional condition adequate for intended reuse. Paint equipment to match new equipment.
2. Pack or crate items after cleaning and repairing. Identify contents of containers.

3. Protect items from damage during transport and storage.
 4. Reinstall items in locations indicated. Comply with installation requirements for new materials and equipment. Provide connections, supports, and miscellaneous materials necessary to make item functional for use indicated.
- E. Existing Items to Remain:
1. Protect construction indicated to remain against damage and soiling during selective demolition.
 2. When permitted by Architect, items may be removed to a suitable, protected storage location during selective demolition and cleaned and reinstalled in their original locations after selective demolition operations are complete.

3.4 CLEANING

- A. General:
1. Clean adjacent structures and improvements of dust, dirt, and debris caused by selective demolition operations.
 2. Return adjacent areas to condition existing before selective demolition operations began.
- B. Waste Management:
1. Disposal of Demolished Materials:
 - a. Remove demolished materials from Project site and legally dispose of them in an EPA-approved landfill. Do not burn demolished materials.
 - 1) Do not allow demolished materials to accumulate on-site.
 - 2) Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
 - 3) Remove debris from elevated portions of building by chute, hoist, or other device that will convey debris to grade level in a controlled descent.

END OF SECTION

DIVISION 03: CONCRETE

03 1000 CONCRETE FORMING AND ACCESSORIES

03 1113 STRUCTURAL CAST-IN-PLACE CONCRETE FORMING
03 1511 CONCRETE ANCHORS

03 2000 CONCRETE REINFORCING

03 2100 REINFORCEMENT BARS

03 3000 CAST-IN-PLACE CONCRETE

03 3111 CAST-IN-PLACE STRUCTURAL CONCRETE
03 3517 CONCRETE SEALER-FINISHING
03 3923 MEMBRANE CONCRETE CURING

03 6000 GROUTING

03 6213 NON-METALLIC NON-SHRINK GROUT

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 03 1113**STRUCTURAL CAST-IN-PLACE CONCRETE FORMING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Design, construction, and safety of formwork.
 - 2. Furnish and install required formwork ready for placing of concrete.
 - 3. Strip and dispose of formwork.
- B. Related Requirements:
 - 1. Section 03 3111: 'Cast-In-Place Structural Concrete' for:
 - a. Tolerances for placing structural concrete.
 - b. Pre-installation conference held jointly with other concrete related sections.

1.2 REFERENCES

- A. Reference Standards:
 - 1. American Concrete Institute:
 - a. ACI 318-14, 'Building Code Requirements for Structural Concrete and Commentary'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 - 1. Participate in pre-installation conference as specified in Section 03 3111.
 - 2. In addition to agenda items specified in Section 01 3100 and 31 3111, review following:
 - a. Review Section 01 4523 for Testing and Inspection administrative requirements and responsibilities and Field Quality Control tests and inspections required of this section.
 - 1) Review requirements and frequency of testing and inspections.
- B. Scheduling:
 - 1. Notify Testing Agency and Architect as directed in Section 03 3111.

1.4 SUBMITTALS

- A. Informational Submittals:
 - 1. Manufacturer Instructions:
 - a. Printed application instructions for form release agents.

PART 2 - PRODUCTS**2.1 COMPONENTS**

- A. Forms: Wood, metal, or plastic as arranged by Contractor:
 - 1. Forming material shall be compatible with specified form release agents and with finish requirements for concrete to be left exposed or to receive a smooth rubbed finish.

2.2 ACCESSORIES

- A. Form Release Agents:
 - 1. Unexposed Surfaces Only: Contractor's option.
- B. Expansion / Contraction Joints:
 - 1. **1/2 inch (13 mm)** thick.
 - 2. Manufactured commercial fiber type:
 - a. Meet requirements of ASTM D1751.
 - b. Type Two Acceptable Products:
 - 1) Conflex by Knight-Celotex, Northfield, IL www.aknightcompany.com.
 - 2) Sealtight by W R Meadows Inc, Hampshire, IL www.wrmeadows.com.
 - 3) Equal as approved by Architect before installation. See Section 01 6200.
 - 3. Recycled Vinyl:
 - a. Light gray color.
 - b. Type Two Acceptable Products:
 - 1) Proflex by Oscoda Plastics Inc, Oscoda, MI www.oscodaplastics.com.
 - 2) Equal as approved by Architect before Installation. See Section 01 6200.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Forms:
 - 1. Assemble forms so forms are sufficiently tight to prevent leakage.
 - 2. Properly brace and tie forms.
 - 3. Make proper form adjustments before, during, and after concreting.
 - 4. Use new forms, or used forms that have been cleaned of loose concrete and other debris from previous concreting and repaired to proper condition. Use APA Plyform B-B Class I, or APA HDO Plyform B-B Class I, on exposed to view concrete that do not receive a smooth rubbed finish.
- B. Accessories:
 - 1. General:
 - a. Provide for installation of inserts, templates, fastening devices, sleeves, and other accessories to be set in concrete before placing.
 - b. Position anchor bolts for hold-down anchors and columns and securely tie in place before placing concrete.
 - 2. Form Release / Finish Agents:
 - a. Film thickness shall be no thicker than as recommended by Manufacturer.
 - b. Allow no release / finish agent on reinforcing steel or footings.
 - 3. Expansion Joints:
 - a. Install at joints between floor slab and foundation wall where shown on Drawings.

3.2 FIELD QUALITY CONTROL

- A. Field Tests And Inspections:
 - 1. Concrete Formwork:
 - a. Inspections are not required and will be performed at discretion of Architect.

END OF SECTION

SECTION 03 1511**CONCRETE ANCHORS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Cast-in place and post-installed concrete anchors including:
 - a. Adhesive anchors for concrete.
 - b. Expansion anchors for concrete.
 - c. Screw anchors for concrete.
 - d. Concrete anchors and inserts not specified elsewhere.
 - 2. Installer responsible when inspection results of concrete anchors require corrective actions.
- B. Related Requirements:
 - 1. Section 01 1200: 'Multiple Contract Summary' for Owner Furnished Testing and Inspecting Services.
 - 2. Section 01 4523: 'Testing and Inspecting Services' for testing and inspection, and testing laboratory services for materials, products, and construction methods.
 - 3. Section 03 3111: 'Cast-In-Place Structural Concrete' for installation and inspection of cast-in-place anchors.
 - 4. Section 06 1100: 'Wood Framing' for installation of drilled in anchors.

1.2 REFERENCES

- A. Reference Standards:
 - 1. American Concrete Institute:
 - a. ACI 355.4-11, 'Qualification of Post-Installed Adhesive Anchors in Concrete and Commentary'.
 - b. ACI 548.12-12, 'Specification for Bonding Hardened Concrete and Steel to Hardened Concrete with an Epoxy Adhesive'.
 - 2. American National Standards Institute / American Welding Society (Following are specifically referenced for Structural Steel testing):
 - a. ANSI/AWS D1.1/D1.1M:2015, 'Structural Welding Code - Steel'.
 - 3. ASTM International:
 - a. ASTM A307-14, 'Standard Specification for Carbon Steel Bolts and Studs, 60 000 psi Tensile Strength'.
 - b. ASTM A563-15, 'Standard Specification for Carbon and Alloy Steel Nuts'.
 - c. ASTM A706/A706M-16, 'Standard Specification for Low-Alloy Steel Deformed and Plain Bars for Concrete Reinforcement'.
 - d. ASTM F1554-18, 'Standard Specification for Anchor Bolts, Steel, 36, 55, and 105-ksi Yield Strength'.
 - e. ASTM F3125/F3125-15a, 'Standard Specification for High Strength Structural Bolts, Steel and Alloy Steel, Heat Treated, 120 ksi (830 MPa) and 150 ksi (1040 MPa) Minimum Tensile Strength, Inch and Metric Dimensions'.
 - 4. International Code Council (IBC) (2018 or most recent edition adopted by AHJ):
 - a. IBC Chapter 17, 'Structural Tests and Special Inspections'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Scheduling:
 - 1. Inspection shall be performed according IBC requirements.

2. Notify Testing Agency and Architect one week before installing anchors so inspection may be scheduled.

1.4 SUBMITTALS

- A. Action Submittals:
 1. Product Data:
 - a. Manufacturer's product literature for each item.
- B. Informational Submittals:
 1. Certificates:
 - a. Adhesive Anchors:
 - 1) Installer to provide current ACI/CRSI certification to Architect prior to installation of anchors.
 2. Test And Evaluation Reports:
 - a. Provide ESR for products used indicating conformance with current applicable ESR Acceptance Criteria.
 3. Manufacturer's Instructions:
 - a. Manufacturer's published installation recommendations for each item.
 4. Qualification Statements:
 - a. All concrete anchors except Adhesive Anchors:
 - 1) Installer to provide record of installer installation training showing dates and those trained for all installed products when required when by Architect.
- C. Closeout Submittals:
 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Record Documentation:
 - 1) Testing and Inspection Reports:
 - a) Testing Agency inspection reports of all inspected anchors.

1.5 QUALITY ASSURANCE

- A. Qualifications:
 1. Manufacturer:
 - a. Having sufficient capacity to produce and deliver required materials without causing delay in work.
 2. Installer:
 - a. Acceptable to Manufacturer, experienced in performing work of this section and has specialized in installation of work similar to that required for this project.
 - b. Adhesive Anchors:
 - 1) Adhesive Anchors installed in horizontal to vertical overhead orientation to support sustained tension loads shall be installed by Certified Adhesive Anchor Installer (AAI) as certified through ACI/CRSI:
 - a) Refer to most current version of ACI 318 for certification requirements.
 - b) Proof of current certification shall be submitted to the Architect for approval prior to commencement of installation.
 - c. All other Concrete Anchors:
 - 1) Arrange for manufacturer's field representative to provide installation training for all products to be used, prior to commencement of work:
 - a) Provide installation training when required by Architect.
- B. Field Inspection:
 1. Owner is responsible for Quality Assurance. Quality assurance performed by Owner will be used to validate Quality Control performed by Contractor.
 2. Owner will provide Inspection for post-installed concrete anchors:

- a. Owner will employ testing agency to perform inspection for post-installed concrete anchors as specified in Field Quality Control in Part 3 of this specification:
 - 1) Owner's employment of an independent Testing Agency does not relieve Contractor of Contractor's obligation to perform the Work in strict accordance with requirements of Contract Documents and perform contractor testing and inspection.
 - 2) See Section 01 1200: 'Multiple Contract Summary'.

1.6 DELIVERY, STORAGE, AND HANDLING

A. Delivery And Acceptance Requirements:

1. Materials shall be delivered in original, unopened packages with labels intact.

B. Storage And Handling Requirements:

1. Store materials protected from exposure to harmful weather conditions and as directed by Manufacturer.

PART 2 - PRODUCTS

2.1 MATERIALS

A. Concrete Anchors:

1. General:
 - a. Use hot-dipped galvanized or stainless steel with matching nuts and washers in exterior and moist interior applications unless indicated otherwise on Contract Drawings.
 - b. Install hot-dipped or stainless steel anchor bolts to attach wood sill plates to foundation with **1/4 inch (6.4 mm)** by **3 inch (76 mm)** x **3 inch (76 mm)** minimum adjustable plate washers and standard cut washers between wood sill plates and nuts.
 - c. Nut: Conform to requirements of ASTM A563, Grade A, Hex.
 - d. Conform to requirements of ASTM F3125/F3125 for chemical, physical and mechanical requirements for quenched and tempered bolts manufactured from steel and alloy steel.
2. Threaded rod for adhesive anchors and cast-in anchors:
 - a. Conform to requirements of ASTM A307, Grade A or ASTM F1554 Grade 36 unless indicated otherwise on Contract Drawings.
3. Cast-In-Place Anchor Bolts:
 - a. J-Bolts:
 - 1) Non-headed type threaded **2 inches (50 mm)** minimum conforming to requirements of ASTM F1554, Grade A.
 - 2) Anchor hook to project **2 inches (50 mm)** minimum including bolt diameter.
 - b. Headed Bolts:
 - 1) Headed type threaded **2 inches (50 mm)** minimum conforming to requirements of ASTM F1554, Grade A.
4. Reinforcing Bars:
 - a. Composed of deformed carbon steel meeting requirements of ASTM A615/A615M, Grade 60.
5. Adhesive Anchors:
 - a. Products shall have current ESR conforming to current ICC Acceptance Criteria AC308 for concrete.
 - b. Rod diameter and embedment length as indicated on Contract Drawings.
 - c. Type Two Acceptable Products:
 - 1) HIT-RE 500V3 with SafeSet Epoxy Adhesive by Hilti Fastening Systems, Tulsa, OK www.us.hilti.com.
 - 2) Pure 110+ by Powers Fasteners Inc., Brewster NY www.powers.com.
 - 3) SET-XP Epoxy by Simpson Strong-Tie Co., Pleasanton, CA www.simpsonanchors.com.
 - 4) Equal as approved by Architect before installation. See Section 01 6200.

6. Expansion Anchors:
 - a. Products shall have current ESR conforming to current ICC Acceptance Criteria AC193 for concrete.
 - b. Type Two Acceptable Products:
 - 1) KWIK Bolt TZ Expansion Anchor by Hilti Fastening Systems, Tulsa, OK www.us.hilti.com.
 - 2) Power-Stud +SD2 by Powers Fasteners Inc., Brewster NY www.powers.com.
 - 3) Strong-Bolt by Simpson Strong-Tie Co., Pleasanton, CA www.simpsonanchors.com.
 - 4) Equal as approved by Architect before installation. See Section 01 6200.
7. Screw Anchors:
 - a. Provide anchors with length identification markings conforming to ICC Acceptance Criteria AC 193 for concrete.
 - b. Type Two Acceptable Products:
 - 1) KWIK HUS-EZ by Hilti Fastening Systems, Tulsa, OK www.us.hilti.com.
 - 2) Wedge-Bolt+ by Powers Fasteners Inc., Brewster NY www.powers.com.
 - 3) Titen HD by Simpson Strong Tie Co, Pleasanton, CA www.simpsonanchors.com.
 - 4) Equals as approved by Architect through shop drawing submittal before installation. See Section 01 6200.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification Of Conditions:
 1. Embedded Items:
 - a. Identify position of reinforcing steel and other embedded items before drilling holes for anchors:
 - 1) Exercise care in coring or drilling to avoid damaging existing reinforcing or embedded items.
 - 2) Take precautions as necessary to avoid damaging pre-stressing tendons, electrical and telecommunications conduit, and gas lines.
 - b. Notify Engineer if reinforcing steel or other embedded items are encountered during drilling.
 2. Base Material Strength:
 - a. Unless otherwise specified, do not drill holes in concrete until:
 - 1) Concrete has minimum age of 21 days at time of anchor installation.
 - 2) Concrete has achieved full design strength for load achievement.

3.2 PREPARATION

- A. Surface Preparation:
 1. Clean surfaces prior to installation.
 2. Prepare surface in accordance with Manufacturer's written recommendations.

3.3 INSTALLATION

- A. Post-Installed Anchors:
 1. General:
 - a. Drill holes with rotary impact hammer drills using carbide-tipped bits.
 - b. Unless otherwise shown on Drawings, drill holes perpendicular to concrete surface.
 - c. Perform anchor installation in accordance with Manufacturer's published instructions.
 2. Adhesive Anchors:
 - a. Clean holes in accordance with Manufacturer's published instructions before installation of adhesive:

- 1) Follow Manufacturer's recommendations to ensure proper mixing of adhesive components.
- b. Adhesive:
 - 1) Inject adhesive into holes proceeding from bottom of hole and progressing toward surface so as to avoid introduction of air pockets into adhesive.
 - 2) Inject sufficient adhesive into hole to ensure that annular gap is filled to surface.
 - 3) Remove excess adhesive from surface and threads of anchor as necessary.
- c. Shim anchors with suitable device to center anchor in hole. Do not disturb or load anchors before Manufacturer's specified cure time has elapsed.
- d. Temperature:
 - 1) Observe Manufacturer's recommendations with respect to installation temperatures for adhesive anchors.
 - 2) Base material temperatures must be maintained above minimum temperatures allowed by Manufacturer for full required epoxy cure time.
3. Expansion Anchors:
 - a. Protect threads from damage during anchor installation and prior to use.
 - b. Set anchors to Manufacturer's recommended torque, using a torque wrench. Following attainment of ten (10) percent of specified torque, one hundred (100) percent of specified torque shall be reached within 7 or fewer complete turns of nut. If specified torque is not achieved within required number of turns, remove and replace anchor, unless otherwise directed by Architect.
4. Screw Anchors:
 - a. Protect threads from damage during anchor installation and prior to use.
 - b. Set anchor flush, collared.
 - c. Do not exceed Manufacturer's maximum allowed torque when seating anchor.

3.4 FIELD QUALITY CONTROL

- A. Field And Inspections:
1. Civil and structural field inspections are provided by Owner's independent Testing Agency as specified in Section 01 4523 'Testing And Inspection Services':
 - a. Quality Control is sole responsibility of Contractor.
 - 1) Owner's employment of an independent Testing Agency does not relieve Contractor of Contractor's obligation to perform testing and inspection as part of his Quality Control:
 - a) Testing and inspections, if performed by Contractor, will be responsibility of Contractor to be performed by an independent entity.
 2. Expansion Anchors / Adhesive Anchors / Screw Anchors:
 - a. Certified Inspector from Testing Agency shall verify procedures used for installation of all concrete anchors and monitor their installation for compliance with Manufacturer's requirements.
 - b. Inspections:
 - 1) Inspections shall include required verification and inspection of anchors as referenced in IBC Table 1704.4 and in accordance with most current version of ACI 318 or ACI 318M and applicable ASTM material standards that:
 - a) The correct rod/anchor is used; size and type.
 - b) The correct hole size is used and prepared per Manufacturer's instructions.
 - c) That climactic conditions, and concrete temperature, allow for the anchors' installation and use.
 - d) Proper hole cleaning equipment, per Manufacturer's instructions, is used.
 - e) Torque applied to anchors does not exceed Manufacturer's allowable limits.
 - f) Torque applied to anchors is per Manufacturer's instructions.
- B. Non-Conforming Work:
1. Contractor is to immediately notify Architect of incorrectly placed, misplaced or malfunctioning anchors and request instructions for corrective actions.

3.5 CLEANING

A. Waste Management:

1. Disposal of rubbish, debris, and packaging materials.

3.6 PROTECTION

A. General:

1. Protect installed products from damage during construction.

END OF SECTION

SECTION 03 2100**REINFORCEMENT BARS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install concrete reinforcement bars as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 01 1200: 'Multiple Contract Summary' for Owner Furnished Testing and Inspecting Services.
 - 2. Section 03 1113: 'Structural Cast-In-Place Concrete Forming'.
 - 3. Section 03 3111: 'Cast-In-Place Structural Concrete' for:
 - a. Reinforcement installed in concrete.
 - b. Pre-installation conference held jointly with other concrete related sections.

1.2 REFERENCES

- A. Association Publications:
 - 1. American Concrete Institute:
 - a. ACI 'Detailing Manual' (2004 Edition).
 - 2. Concrete Reinforcing Steel Institute (CRSI):
 - a. CRSI, 'Manual of Standard Practice' (2009 28th Edition).
- B. Reference Standards:
 - 1. American Concrete Institute:
 - a. ACI 117-10: 'Specifications for Tolerances for Concrete Construction and Materials and Commentary' (Reapproved 2015).
 - b. ACI 318-14, 'Building Code Requirements for Structural Concrete and Commentary'.
 - 2. ASTM International (Following are specifically referenced for reinforcement bars testing):
 - a. ASTM A615/A615M-18, 'Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 03 3111.
 - 2. In addition to agenda items specified in Section 01 3100, and Section 03 3111, review following:
 - a. Installation scheduling and reinforcing placement.
 - b. Review Section 01 4523 for Testing and Inspection administrative requirements and responsibilities and Field Quality Control tests and inspections required of this section.
 - 1) Review requirements and frequency of testing and inspections.
- B. Scheduling:
 - 1. Notify Testing Agency and Architect as directed in Section 03 3053 and Section 03 3111.

1.4 SUBMITTALS

- A. Action Submittals:
 - 1. Shop Drawings:
 - a. Reinforcing placement drawings.

- B. Informational Submittals:
 - 1. Certificates:
 - a. Mill certificates for mill tests for reinforcing in accordance with ASTM A615/A615M.
- C. Closeout Submittals:
 - 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Record Documentation:
 - 1) Testing and Inspection Reports:
 - a) Testing Agency Inspection Reports of reinforcement bars.

1.5 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Comply with provisions of following codes and standards except where more stringent requirements are shown or specified:
 - a. American Concrete Institute:
 - 1) ACI 318, 'Building Code Requirements for Structural Concrete and Commentary'.
 - b. Concrete Reinforcing Steel Institute:
 - 1) CRSI, 'Manual of Standard Practice'.
- B. Qualifications:
 - 1. Throughout progress of the work of this section, provide at least one (1) person who shall be thoroughly familiar with Construction Documents and other applicable specified requirements, completely trained and experienced in necessary skills, and who shall be present at site and shall direct all work performed under this Section:
 - a. In actual installation of the work of this Section, use adequate numbers of skilled workmen to ensure installation in strict accordance with approved design.
 - b. In acceptance or rejection of work performed under this Section, no allowance will be made for lack of skill on part of workmen.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Deliver bars separated by size and tagged with manufacturer's heat or test identification number.
 - 2. Reinforcement bars shall be free of heavy rust scales and flakes, or other coating at time of delivery and placing.
- B. Storage And Handling Requirements:
 - 1. Properly protect rebar on site after delivery.

PART 2 - PRODUCTS

2.1 MATERIAL

- A. Reinforcement Bars:
 - 1. Bars shall have grade identification marks and conform to ASTM A615/A615M:
 - a. Grade 60 minimum, except dowels that are to be field bent, Grade 40 minimum.
 - 2. Bars shall be deformed type.
 - 3. Bars shall be free of heavy rust scales and flakes, or other bond-reducing coatings.

2.2 ACCESSORIES

- A. Bar Supports:
 - 1. Concrete masonry units or bricks are not acceptable.

2. For exposed-to-view concrete surfaces, where legs of supports are in contact with forms, provide supports with legs which are plastic protected (CRSI, Class 1) or stainless steel protected (CRSI, Class 2).
3. Type Two Acceptable Products:
 - a. Concrete 'dobies' or blocks wired to reinforcing.
 - b. Manufactured chairs with 4 sq inch (25.8 sq cm) bearing surface on sub-grade, or other feature to prevent chair from being pushed into sub-grade or damaging vapor retarder under slabs on grade.
 - c. Equals as approved by Architect before installation. See Section 01 6200.

2.3 FABRICATION

- A. Fabricate reinforcement bars according to the Concrete Reinforcing Steel Institute (CRSI) 'Manual of Standard Practice' and details on Contract Documents.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General:
 1. Avoid cutting or puncturing vapor retarder during reinforcement placement and concrete operations.
 2. Clean reinforcement of loose rust and mill scale, earth, ice, and other materials which reduce or destroy bond with concrete.
 3. Blowtorch shall not be used to facilitate field cutting or bending or any other reinforcing work.
 4. Reinforcement shall not be bent after partially embedded in hardened concrete.
- B. Placing Reinforcement:
 1. Comply with Concrete Reinforcing Steel Institute CRSI 'Manual of Standard Practice' recommended practice for 'Placing Reinforcing Bars' for details and methods of reinforcement placement and supports. and as herein specified.
 2. Accurately position, support, and secure reinforcement against displacement by formwork, construction, or concrete placement operations:
 - a. Locate and support reinforcing by chairs, runners, bolsters, bar supports, spacers, or hangers, as required as recommended by 'ACI Detailing Manual, except slab on grade work.
 - b. Support bars in slabs on grade and footings with specified bar supports around perimeter and at 4-1/2 feet on center each way maximum to maintain specified concrete cover.
 - c. Install bar supports at bar intersections.
 3. Bend bars cold.
 4. Dowel vertical reinforcement for formed concrete columns or walls out of footing or structure below with rebar of same size and spacing required above.
 5. Securely anchor and tie reinforcement bars and dowels before placing concrete. Set wire ties with ends directed into concrete, not toward exposed concrete surfaces.
- C. Splices:
 1. Non-Concrete Structural System:
 - a. Avoid splices of reinforcement bars at points of maximum stress. Lap bars 60 bar diameters minimum unless dimensioned otherwise on Drawings. Run reinforcement bars continuous through cold joints.
 2. Concrete Structural System:
 - a. In slabs, and walls, avoid splices of reinforcement bars at points of maximum stress.
 - b. Lap bars as follows:
 - 1) Compression Splices: 45 bar diameters minimum.
 - 2) Tension Splices: In accordance with ACI 318 Class B requirements.
 - 3) No splice shall be less than 20 inches (508 mm).
 - 4) For epoxy coated rebar, increase lap-splice lengths by 1.5 times those listed above.

- c. In columns, splices in vertical bars are permitted only at floor levels or points of lateral support and shall consist of 45 bar diameter laps.
 - d. Run reinforcement bars continuous through cold joints.
- D. Tolerances:
- 1. Provide following minimum concrete cover for reinforcement as per ACI 318 or ACI 318M. Arrange, space and securely tie bars and bar supports to hold reinforcement in position during concrete placement operations:
 - a. Concrete cast against and permanently exposed to earth:
 - 1) Interior Slabs on Grade: **1 inches (25 mm)**. clear from top of slab at **4 inches (100 mm)** slabs, **2 inches (50 mm)** clear at **6 inches (150 mm)** slabs.
 - 2) Sections other than Slabs: **3 inches (75 mm)**.
 - b. Concrete Exposed to Earth or Weather:
 - 1) No. 6 and Larger Bars: **2 inches (50 mm)**.
 - 2) No. 5 and Smaller Bars, W31 and D31 Wire: **1-1/2 inches (38 mm)**.

3.2 FIELD QUALITY CONTROL

- A. Field Tests And Inspections:
- 1. Civil and structural field tests, laboratory testing, and inspections are provided by Owner's independent Testing Agency as specified in Section 01 4523 'Testing And Inspection Services':
 - a. Quality Control is sole responsibility of Contractor.
 - 1) Owner's employment of an independent Testing Agency does not relieve Contractor of Contractor's obligation to perform testing and inspection as part of his Quality Control:
 - a) Testing and inspections, if performed by Contractor, will be responsibility of Contractor to be performed by an independent entity.
 - 2. Reinforcement Bars:
 - a. Testing Agency shall provide inspection for Reinforcement Bars. See Section 03 3111 for Testing and Inspection requirements.

END OF SECTION

SECTION 03 3111**CAST-IN-PLACE STRUCTURAL CONCRETE****PART 1 - GENERAL****1.1 SUMMARY****A. Includes But Not Limited To:**

1. Furnish and install concrete work as described in Contract Documents including:
 - a. Quality of concrete used on Project but furnished under other Sections.
 - b. Concrete mix information and use of admixtures.
 - c. Field Quality Control Testing and Inspection requirements for concrete.
 - d. Pre-installation conference held jointly with other concrete related sections.
 - e. Sealants and curing compounds used with concrete.
 - f. Compact aggregate base for miscellaneous cast-in-place concrete.
 - g. Miscellaneous cast-in-place concrete and equipment pads.

B. Products Installed But Not Furnished Under This Section:

1. Concrete accessories.
2. Inserts, bolts, boxes, templates, and fastening devices for other work, including those for bases only for Mechanical and Electrical.
3. Membrane Concrete Curing.

C. Related Requirements:

1. Section 01 1200: 'Multiple Contract Summary' for Owner Furnished Testing and Inspecting Services.
2. Section 01 4523: 'Testing and Inspecting Services' for testing and inspection, and testing laboratory services for materials, products, and construction methods.
3. Section 03 1113: 'Structural Cast-In-Place Concrete Forming'.
4. Section 03 1511: 'Concrete Anchors and Inserts'.
5. Section 03 2100: 'Reinforcement Bars'.
6. Section 03 3517: 'Concrete Sealer Finishing' for application of concrete sealers.
7. Section 03 3923: 'Membrane Concrete Curing' for quality of curing materials used.
8. Section 07 9213: 'Elastomeric Joint Sealant' for quality of sealants.
9. Section 31 0501: 'Common Earthwork Requirements' for:
 - a. General procedures and requirements for earthwork.
 - b. Pre-installation conference held jointly with other common earthwork related sections.
10. Section 31 1123: 'Aggregate Base' for aggregate base under miscellaneous cast-in-place concrete and exterior slabs, under interior slabs-on-grade concrete, and asphalt paving.
11. Section 31 2213: 'Rough Grading' for rough grading and preparation of natural soil subgrades below fill and aggregate base materials.
12. Section 31 2216: 'Fine Grading' for grading of subgrade below aggregate base and topsoil.
13. Section 31 2323: 'Fill' for compaction procedures and tolerances.
14. Section 32 8423: 'Underground Sprinklers' for sleeves for underground irrigation system.
15. Section 32 9121: 'Topsoil Grading' for grading of subgrade below topsoil.
16. Divisions 22, 23, And 26: Mechanical and electrical devices including boxes, conduits, pipes, hangers, inserts, and other work to be embedded in concrete work before placing.
17. Furnishing of items to be embedded in concrete specified in Section involved.
18. Owner will provide concrete leveling compounds and patching compounds required for carpet installation.

1.2 REFERENCES**A. Association Publications:**

1. American Concrete Institute, Farmington Hills, MI www.concrete.org. Abstracts of ACI Periodicals and Publications.
 - a. ACI 117.1R-14: 'Guide for Tolerance Compatibility in Concrete Construction'.
 - b. Certifications:
 - 1) ACI CP-1(16), '*Technical Workbook for ACI Certification of Concrete Field Testing Technician-Grade 1*'.
 - 2) ACI CP-10(10), '*Craftsman Workbook for ACI Certification of Concrete Flatwork Technician/Finisher*'.
 - 3) ACI CP-19(16), '*Technical Workbook for ACI Certification of Concrete Strength Testing Technician*'.
- B. Definitions:
 1. Cold Weather, as referred to in this Section, is four (4) hours with ambient temperature below **40 deg F (4.4 deg C)** in twenty-four (24) hour period.
 2. Floor Flatness (F_F): Rate of change in elevation of floor over **12 inches (305 mm)** section.
 3. Floor Levelness (F_L): Measures difference in elevation between two points which are **10 feet (3.05 m)** apart.
 4. Hot Weather, as referred to in this Section, is ambient air temperature above **100 deg F (38 deg C)** or ambient air temperature above **90 deg F (32 deg C)** with wind velocity **8 mph (12.9 kph)** or greater.
- C. Reference Standards:
 1. American Association of State and Highway Transportation Officials:
 - a. AASHTO M 153-06 (2016), 'Standard Specification for Preformed Sponge Rubber and Cork Expansion Joint Fillers for Concrete Paving and Structural Construction'.
 2. American Concrete Institute
 - a. ACI 117-10 (R2015): 'Specifications for Tolerances for Concrete Construction and Materials and Commentary'.
 - b. ACI 305.1-14, 'Specification for Hot Weather Concreting'.
 - c. ACI 306.1-90 (R2002), 'Standard Specification for Cold Weather Concreting'.
 - d. ACI 318-14, 'Building Code Requirements for Structural Concrete' (ACI 318) and 'Commentary on Building Code Requirements for Structural Concrete' (ACI 318R).
 3. ASTM International:
 - a. ASTM C31/C31M-19, 'Standard Practice for Making and Curing Concrete Test Specimens in the Field'.
 - b. ASTM C33/C33M-18, 'Standard Specification for Concrete Aggregates'.
 - c. ASTM C39/C39M-18, 'Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens'.
 - d. ASTM C94/C94M-17a, 'Standard Specification for Ready-Mixed Concrete'.
 - e. ASTM C140/C140M-18a, 'Standard Test Methods for Sampling and Testing Concrete Masonry Units and Related Units'.
 - f. ASTM C143/C143M-15a, 'Standard Test Method for Slump of Hydraulic-Cement Concrete'.
 - g. ASTM C150/C150M-18, 'Standard Specification for Portland Cement'.
 - h. ASTM C172/C172M-17, 'Standard Practice for Sampling Freshly Mixed Concrete'.
 - i. ASTM C173/C173M-16, 'Standard Test Method for Air Content of Freshly Mixed Concrete by the Volumetric Method'.
 - j. ASTM C192/C192M-18, 'Standard Practice for Making and Curing Concrete Test Specimens in the Laboratory'.
 - k. ASTM C231/C231M-17a, 'Standard Test Method for Air Content of Freshly Mixed Concrete by the Pressure Method'.
 - l. ASTM C260/C260M-10a(2016), 'Standard Specification for Air-Entraining Admixtures for Concrete'.
 - m. ASTM C330/C330M-17a, 'Standard Specification for Lightweight Aggregates for Structural Concrete'.
 - n. ASTM C494/C494M-17, 'Standard Specification for Chemical Admixtures for Concrete'.
 - o. ASTM C496/C496M-17, 'Standard Test Method for Splitting Tensile Strength of Cylindrical Concrete Specimens'.
 - p. ASTM C567/C567M-14, 'Standard Test Method for Determining Density of Structural Lightweight Concrete'.
 - q. ASTM C595/C595M-18, 'Standard Specification for Blended Hydraulic Cements'.

- r. ASTM C618-19, 'Standard Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete'.
 - s. ASTM C1077-17, 'Standard Practice for Agencies Testing Concrete and Concrete Aggregates for Use in Construction and Criteria for Testing Agency Evaluation'.
 - t. ASTM C1157/C1157M-17, 'Standard Performance Specification for Hydraulic Cement'.
 - u. ASTM D1751-18, 'Standard Specification for Preformed Expansion Joint Filler for Concrete Paving and Structural Construction (Non-extruding and Resilient Bituminous Types)'.
 - v. ASTM E329-18: 'Standard Specification for Agencies Engaged in Construction Inspection and/or Testing'.
 - w. ASTM E1155-14, 'Standard Test Method for Determining F_F Floor Flatness and F_L Floor Levelness Numbers'.
4. International Code Council (IBC) (2018 or latest approved edition):
- a. IBC Chapter 17, 'Special Inspections And Tests'.
 - 1) Section 1704, 'Special Inspections And Tests, Contractor Responsibility And Structural Observations'.
 - 2) Section 1705, 'Required Special Inspection And Tests'.
 - a) Section 1705.2, 'Steel Construction'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
- 1. Participate in MANDATORY pre-installation conference as specified in Section 01 3100 and held jointly with following sections:
 - a. Section 03 1113: 'Structural Cast-In-Place Concrete Forming'.
 - b. Section 03 2100: 'Reinforcement Bars'.
 - 2. Schedule pre-installation conference prior to placing of footings, installation of foundation forms and reinforcing steel, and installation of anchors, dowels, inserts, and block outs in foundation walls and slabs.
 - 3. In addition to agenda items specified in Section 01 3100, review following:
 - a. Set up concrete placement pour card system and verify that all relevant trades have signed off prior to concrete placement.
 - b. Obtaining trade sign-offs on each pour card will be responsibility of General Contactor's foreman or whoever is in charge of ordering concrete.
 - c. Pour cards will be turned in to Quality Assurance representative after the work has been completed so that they can be reviewed and filed.
 - d. Review installation scheduling, coordination, placement of building concrete, and placement of items installed in and under concrete.
 - e. Review installation scheduling, coordination and placement of site concrete and of items installed in concrete.
 - f. Review 'Verification of Conditions' requirements.
 - g. Review requirements for preparation of subgrade and aggregate base requirements.
 - h. Review formwork requirements.
 - i. Review approved mix design requirements, mix designs and use of admixtures.
 - j. Review reinforcing bar submittals.
 - k. Review installation schedule and placement of reinforcing bars.
 - l. Review placement, finishing, and curing of concrete, including cold and hot weather requirements.
 - m. Review joint layout plan for control and expansion joints, fillers for sidewalks, curbs, and gutters:
 - 1) Review jointing requirements.
 - n. Review smooth rubbed concrete finish procedures and requirements (applied immediately after removing concrete formwork while concrete is 'green').
 - o. Review concrete slab tolerances and corrective measures if tolerances not met.
 - p. Review safety issues.

1.4 SUBMITTALS

- A. Informational Submittals:

1. Certificates:
 - a. Installers:
 - 1) Certification for National Ready Mixed Concrete Association (NRMCA).
 - 2) Certification for ACI-certified Flatwork Finishers and Technicians.
2. Design Data:
 - a. Mix Design:
 - 1) Furnish proposed mix design to Architect for review prior to commencement of Work.
 - a) Include density (unit weight) and void content determined per ASTM C1688/C1688M for fresh mixed properties and per ASTM C140/C140M for hardened concrete properties.
 - b) Mix design shall show proposed admixture, amount, usage instructions, and justification for proposed use.
 - b. Ready-Mix Supplier:
 - 1) Require mix plant to furnish delivery ticket for each batch of concrete. Keep delivery tickets at job-site for use of Owner or his representatives. Tickets shall show following:
 - a) Name of ready-mix batch plant.
 - b) Serial number of ticket.
 - c) Date and truck number.
 - d) Name of Contractor.
 - e) Name and location of Project.
 - f) Specific class or designation of concrete conforming to that used in Contract Documents.
 - g) Amount of concrete.
 - h) Amount and type of cement.
 - i) Total water content allowed by mix design.
 - j) Amount of water added at plant.
 - k) Sizes and weights of sand and aggregate.
 - l) Time loaded.
 - m) Type, name, manufacturer, and amount of admixtures used.
 - n) Design Data.
 - 2) Provide certificates with supporting testing reports verifying compliance with Contract Document requirements and that materials provided are from single source for following:
 - a) Cement.
 - b) Aggregate.
 - c) Fly Ash.
3. Source Quality Control Submittals:
 - a. Concrete mix design: Submit mix designs to meet following requirements:
 - 1) Mix Type B:
 - a) Unexposed interior concrete slabs on grade.
 - b) 3500 psi (24.13 MPa) minimum at twenty-eight (28) days.
 - c) Water / Cementitious Material: 0.45 maximum by weight.
 - 2) Mix Type E:
 - a) Exterior concrete exposed to freeze/thaw cycles and deicing salts or where soils are 'corrosive'.
 - b) 4500 psi (31.03 MPa) minimum at twenty-eight (28) days.
 - c) Water / Cementitious Material: 0.40 maximum by weight.
 - d) Use twenty-five (25) percent Class F fly ash as part of cementitious material.
 - e) Mix Type F should be used for all exterior concrete exposed to freeze/thaw cycles and deicing salts, unless dictated otherwise by site conditions.
 - f) For concrete paving, use mix design based upon use of 1-1/2 inches (38 mm) coarse aggregate (about 15 percent).
 - 3) Air Entrainment: Six (6) percent, plus or minus 1-1/2 percent for exterior concrete and foundation walls exposed to freeze/thaw cycles.
 - 4) Do not add water any time during mixing cycle above amount required to meet specified water / cement ratio. No reduction in amount of cementitious material is allowed.
 - b. Slump:
 - 1) 4 inch (100 mm) slump maximum before addition of high range water reducer.
 - 2) 8 inch (200 mm) slump maximum with use of high range water reducer.
 - 3) Slump not required for Mix Type G.

- c. Admixtures:
 - 1) Mix design shall show proposed admixture, amount, usage instructions, and justification for proposed use. Do not use any admixture without Architect's written approval.
 - 2) Fly ash: Amount of specified Class F (or Class C where Class F is not available) fly ash not to exceed twenty-five (25) percent of weight of cementations materials may used.
 - 3) Chemical:
 - a) Specified accelerator or retarder may be used if necessary to meet environmental conditions.
 - b) Special additives to promote rapid drying concrete, or moisture vapor reduction (MVRA), may be used in interior concrete slabs on grade and elevated concrete decks that will receive flooring if necessary to meet construction schedules.

1.5 QUALITY ASSURANCE

- A. Qualifications: Requirements of Section 01 4301 applies, but is not limited to following:
 1. Installers and Installation Supervisor:
 - a. ACI-certified Flatwork Technician and Finisher and a supervisor who is an ACI-certified Concrete Flatwork Technician.
 2. Ready-Mix Supplier:
 - a. Comply with ASTM C94/C94M requirements and be certified according to NRMCA's 'Certification of Ready Mixed Concrete Production Facilities'.
- B. Delivery And Acceptance Requirements:
 1. Expansion Joint Filler Material:
 - a. Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- C. Storage And Handling Requirements:
 1. Expansion Joint Filler Material:
 - a. Store materials in a clean, dry area in accordance with manufacturer's instructions.
 - b. Protect materials during handling and application to prevent damage.

PART 2 - PRODUCTS

2.1 SYSTEM

- A. Manufacturers:
 1. Manufacturer Contact List:
 - a. Aridus Admixture by US Concrete, Euless, TX www.us-concrete.com/aridus/.
 - b. BASF (Construction Chemicals Division), Cleveland, OH www.master-builders-solutions.basf.us/en-us.
 - c. Bonsal American, Charlotte, NC www.bonsal.com.
 - d. Concure Systems Admixture by Concure Systems, Phoenix, AZ www.ConcureSystems.com.
 - e. Dayton Superior Specialty Chemicals, Kansas City, KS www.daytonsuperiorchemical.com.
 - f. Euclid Chemical Company, Cleveland, OH www.euclidchemical.com.
 - g. Fritz-Pak Concrete Admixtures, Dallas, TX www.fritzpak.com.
 - h. GCP Applied Technologies, Cambridge, MA www.gcpat.com/construction/en-us.
 - i. ISE Logik Industries, Gulfport, MS www.iselogik.com.
 - j. Kryton International Inc., Vancouver, British Columbia, Canada www.kryton.com.
 - k. L & M Construction Chemicals, Omaha, NE www.lmcc.com.
 - l. Larsen Weldcrete by Larsen Products Corp, Rockville, MD www.larsenproducts.com.
 - m. Sika Corporation, Lyndhurst, NJ www.sikaconstruction.com and Sika Canada, Pointe Claire, QC www.sika.ca.
 - n. Unitex, Kansas City, MO www.unitex-chemicals.com.
 - o. U S Mix Products Co, Denver, CO www.usspec.com.

- p. W R Meadows, Hampshire, IL www.wrmeadows.com.
- B. Performance:
1. Design Criteria: Conform to requirements of ASTM C94/C94M unless specified otherwise:
 2. Capacities:
 - a. For testing purposes, following concrete strengths are required:
 - 1) At 7 days: 70 percent minimum of 28 day strengths.
 - 2) At 28 days: 100 percent minimum of 28 day strengths.
- C. Materials:
1. Hydraulic Cement: Meet requirements of ASTM C150/C150M, Type I or IA.
 2. Aggregates:
 - a. General:
 - 1) Submit a letter on quarry's letterhead that certifies all aggregate for concrete complies with the requirements of this section. Material certificates which are submitted shall be signed by both the materials producer and the contractor, certifying that materials comply with or exceed requirements specified herein to the Architect, Civil and Structural Engineering Consultant and the Independent Testing Laboratory for review and approval.
 - 2) Aggregates for all concrete shall come from a quarry that is DOT approved and meets or exceeds durability Class I aggregate. The quarry shall submit a letter to Engineer that certifies that all aggregate complies with DOT requirements for durability. Aggregate not meeting DOT durability requirements shall not be used.
 - b. Coarse:
 - 1) Meet requirements of ASTM C33/C33M or nonconforming aggregate that by test or actual service produces concrete of required strength and conforms to local governing codes.
 - 2) Aggregate shall be uniformly graded by weight.
 - c. Fine:
 - 1) Meet requirements of ASTM C33/C33M.
 - 2) Aggregate shall be uniformly graded by weight.
 3. Water: Clear, apparently clean, and potable.
 4. Admixtures And Miscellaneous:
 - a. Fly Ash:
 - 1) Meet requirements of ASTM C618, Class F (or Class C where Class F is not available) and with loss on ignition (LOI) of three (3) percent maximum.
 - b. Chemical:
 - 1) No admixture shall contain calcium chloride nor shall calcium chloride be used as an admixture. All chemical admixtures used shall be from same manufacturer and compatible with each other.
 - 2) Air Entraining Admixture:
 - a) Meet requirements of ASTM C260/C260M.
 - b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
 - 3) Water Reducing Admixture:
 - a) Meet requirements of ASTM C494/C494M, Type A and containing not more than 0.05 percent chloride ions.
 - b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
 - 4) Water Reducing, Retarding Admixture:
 - a) Meet requirements of ASTM C494/C494M, Type D and contain not more than 0.05 percent chloride ions.
 - b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
 - 5) High Range Water Reducing Admixture (Superplasticizer):
 - a) Meet requirements of ASTM C494/C494M, Type F or G and containing not more than 0.05 percent chloride ions.
 - b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
 - 6) Non-Chloride, Non-Corrosive Accelerating Admixture:

- a) Meet requirements of ASTM C494/C494M, Type C or E and containing not more than 0.05 percent chloride ions.
- b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
- 7) Corrosion Inhibiting Admixture:
 - a) Liquid admixture to inhibit corrosion of steel reinforcement in concrete by introducing proper amount of anodic inhibitor. Admixture shall contain thirty (30) percent calcium nitrite solution and shall be used where called for in specifications or on drawings.
 - b) Type Two Acceptable Products:
 - (1) Eucon CIA by Euclid.
 - (2) DCI or DCI-S by GCP Applied Technologies.
 - (3) Equal as approved by Architect before use. See Section 01 6200.
- 8) Alkali-Silica Reactivity Inhibiting Admixture:
 - a) Specially formulated lithium nitrate admixture for prevention of alkali-silica reactivity (ASR) in concrete. Admixture must have test data indicating conformance to ASTM C1293.
 - b) Type Two Acceptable Products:
 - (1) Eucon Integral ARC by Euclid.
 - (2) RASIR by W R Grace.
 - (3) Equal as approved by Architect before use. See Section 01 6200.
- 9) Viscosity Modifying Admixture (VMA):
 - a) Liquid admixture used to optimize viscosity of Self-Consolidating Concrete (SCC). Subject to compliance with requirements, provide following at dosage rates per manufacturer's recommendation.
 - b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
- 10) Shrinkage Reducing Admixture (SRA):
 - a) Liquid admixture specifically designed to reduce drying shrinkage and potential for cracking.
 - b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
- 11) Rapid Drying Admixture in Interior Concrete Slabs on Grade:
 - a) Admixture specifically designed to promote rapid drying of concrete.
 - b) Type Two Acceptable Products:
 - (1) Equal as approved by Architect before use. See Section 01 6200.
- 12) Moisture Vapor Reduction Admixture (MVRA):
 - a) Liquid, inorganic, ASTM C494/C494M Type S Admixture free of volatile organic compounds (VOCs); specifically formulated to close capillary systems formed during concrete placement and to reduce moisture vapor emission and transmission with no adverse effect on concrete properties or finish flooring.
 - b) Type Two Acceptable Products:
 - (1) MVRA 900 by ISE Logik Industries: www.iselogik.com.
 - (2) Concure Systems Admixture by Concure Systems, Phoenix, AZ www.ConcureSystems.com.
 - (3) Equal as approved by Architect before use. See Section 01 6200.
- 13) Waterproofing Admixture: Admixture formulated to reduce permeability to liquid water, with no adverse effect on concrete properties:
 - a) Functioning by growth of crystals in capillary pores.
 - b) Permeability of Cured Concrete: No measurable leakage when tested in accordance with COE CRD-C 48 at 200 feet of head; provide test reports.
 - c) Type Two Acceptable Products:
 - (1) CWPA 800 by ISE Logik Industries: www.iselogik.com.
 - (2) Krystol Internal Membrane (KIM) by Kryton: www.kryton.com.
 - (3) Equal as approved by Architect before use. See Section 01 6200.

2.2 ACCESSORIES

A. Formwork:

1. Meet requirements specified in Section 03 1113:
- B. Bonding Agents:
1. Type Two Acceptable Products:
 - a. Acrylic Additive by Bonsal American.
 - b. Day Chem Ad Bond (J-40) by Dayton Superior.
 - c. Flex-Con by Euclid Chemical Co.
 - d. Larsen Weldcrete by Larsen Products Corp.
 - e. Everbond by L & M Construction Chemicals.
 - f. MasterEmaco A 660 (formally Acryl 60) by BASF.
 - g. U S Spec Multicoat by U S Mix Products.
 - h. Intralok by W R Meadows.
 - i. Equal as approved by Architect before use. See Section 01 6200.
- C. Expansion Joint Filler:
1. Expansion Joint Filler Material:
 - a. Design Criteria:
 - 1) Resilient, flexible, non-extruding, expansion-contraction joint filler meeting requirements of ASTM D1751.
 - 2) **1/2 inch (12.7 mm)** thick.
 - 3) Resilience:
 - a) When compressed to half of original thickness, recover to minimum of seventy (70) percent of original thickness.
 - b. Type Two Acceptable Products:
 - 1) Fiber Expansion Joint by W R Meadows, Hampshire, IL www.wrmeadows.com.
 - 2) Equal as approved by Architect before installation. See Section 01 6200.
- D. Finishing Material (Exposed Vertical Faces of Foundation and Retaining Walls):
1. Finishing Material available in multiple concrete shades to closely match concrete surface.
 2. Type Two Acceptable Products:
 - a. Mixture of 1 part cement (using same cement as used in concrete foundations), 1 part sand with 95 percent passing #50 sieve.
 - b. RapidSet WunderFixx by CTS Cement Manufacturing Corporation, Cypress, CA www.rapidset.com.
 - c. Equal as approved by Architect before installation. See Section 01 6200.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification Of Conditions:
1. Concrete Forms:
 - a. Verify dimensions and spot elevations for locations of forms for concrete footings, stem walls, building slabs, curbs, gutters, walkways, and drainage systems are correct before concrete is placed.
 - 1) Notify Architect of incorrect dimensions or spot elevations in writing.
 - 2) Do not place concrete until corrections are made and verified.

3.2 PREPARATION

- A. Concrete Mixing:
1. General:
 - a. All concrete shall be machine mixed.
 - b. Water gauge shall be provided to deliver exact predetermined amount of water for each batch.

- c. Reliable system must be employed to insure that no less than predetermined amount of cement goes into each batch.
 - d. Re-tempering partly set concrete will not be permitted.
 2. Transit Mix:
 - a. Transit mix concrete may be used provided it conforms to Specifications and tests herein described and ASTM C94/C94M.
 - b. Central plant producing concrete and equipment transporting it are suitable for production and transportation of controlled concrete and plant is currently approved by local state DOT.
 - c. Maximum elapsed time between time of introduction of water and placing shall be one (1) hour.
 - d. Minimum time of mixing shall be one (1) minute per cubic yard after all material, including water, has been placed in drum, and drum shall be reversed for an additional two (2) minutes.
 - e. Mixing water shall be added only in presence of Inspecting Engineer or inspector employed by Testing Agency.
 - f. Trucks shall not be overloaded in excess of rated capacity as recommended by manufacturer.
 3. Cold Weather Concreting Procedures:
 - a. General Requirements:
 - 1) Materials and equipment required for heating and protection of concrete shall be approved and available at Project site before beginning cold weather concreting.
 - 2) Forms, reinforcement, metallic embedments, and fillers shall be free from snow, ice, and frost. Surfaces that will be in contact with newly placed concrete, including sub-grade materials, shall be **35 deg F (2 deg C)** minimum at time of concrete placement.
 - 3) Thaw sub-grade **6 inches (150 mm)** deep minimum before beginning concrete placement. If necessary, re-compact thawed material.
 - 4) Use no frozen materials or materials containing ice.
 - 5) See ACI 306.1 'Standard Specification for Cold Weather Concreting' for additional requirements.
 4. Hot Weather Concreting Procedures:
 - a. General:
 - 1) Maximum concrete temperature allowed is **90 deg F (32 deg C)** in hot weather.
 - 2) Cool aggregate and subgrades by sprinkling.
 - 3) Avoid cement over **140 deg F (60 deg C)**.
 - 4) Use cold mixing water or ice.
 - 5) Use fog spray or evaporation retardant to lessen rapid evaporation from concrete surface.
 - 6) See ACI 305.1 'Specification for Hot Weather Concreting' for additional requirements.
- B. Surface Preparation:
 1. Earthwork Preparation:
 - a. Aggregate base and subgrade:
 - 1) Prepare aggregate base as specified in Section 31 1123.
 - 2) Prepare natural soil subgrade as specified in Section 31 2213.
 - 3) Prepare fill subgrade as specified in Section 31 2323.
 2. Inserts, bolts, boxes, templates, pipes, conduits, and other accessories required by Divisions 22, 23, and 26 shall be installed and inspected before placing concrete.
 3. Install inserts, bolts, boxes, templates, pipes, conduits, and other accessories furnished under other Sections to be installed as part of work of this Section:
 - a. Tie anchor bolts for hold-down anchors and columns securely to reinforcing steel.
- C. Removal:
 1. Remove water and debris from space to be placed:

3.3 INSTALLATION

- A. Placing Concrete:
 1. General:
 - a. Place as soon after mixing as possible.

- b. Deposit as nearly as possible in final position.
- c. No concrete shall be deposited in water.
- d. Placing of concrete shall be continuous until panel or section is complete.
- e. Compact concrete in forms by vibrating and other means where required.
 - 1) Thoroughly consolidate concrete around reinforcing bars (Consolidation not required in concrete around reinforcing bars with Mix Type G).
 - 2) Use and type of vibrators shall conform to ACI 309.
- f. Form vertical surfaces full depth. Do not allow concrete to flow out from under forms in any degree into landscaped areas.
- g. Consolidate concrete thoroughly.
- h. Do not embed aluminum in concrete.
- i. Do not use contaminated, deteriorated, or re-tempered concrete.
- j. Avoid accumulation of hardened concrete.
- k. Dusting with cement not permitted.
- 2. Footings:
 - a. Bear **12 inches (300 mm)** minimum into undisturbed earth or on mechanically compacted engineered fill. Step footings at ratio of 1-1/2 horizontal to One vertical unless detailed otherwise.
 - b. Level top of finish footing and leave rough.
 - c. Where joints are required, bulkhead, key horizontally, and dowel with two No. 5 reinforcing bars, **48 inches (1 200 mm)** long.
- 3. Exterior Slabs:
 - a. For continuous placing and where shown on Drawings, saw cut **one inch (25 mm)** deep control joints before shrinkage occurs (**2 inches at 6 inch slabs**) (**50 mm at 150 mm slabs**).
- 4. Miscellaneous Concrete Elements:
 - a. Equipment Bases: Coordinate with appropriate Sections for locations and dimensions.
 - b. Mow Strips, and Aprons:
 - 1) Install bond breaker consisting of three (3) layers of **30 lb (13.6 kg)** roofing felt between pole base and adjoining sidewalk, mow strip and building foundations, and aprons and building foundations.
 - c. Mow Strips and Aprons:
 - 1) Aggregate base not necessary under mow strips and aprons.
 - 2) Form and cast mow strips in place.
 - 3) Set top of mow strip above finish grade as follows:
 - a) Sodded Areas: **2 inches (50 mm)** below.
 - b) Seeded Areas: **One inch (25 mm)** below.
 - c) Ground Cover Areas: **2 inches (50 mm)** below.
 - d) Trees and Shrub Areas (not individual trees): **4 inches (100 mm)** below.
 - 4) Compact topsoil underneath mow strips and aprons to density of undisturbed earth.
 - d. Sidewalks:
 - 1) Slope with cross slope of **1/8 to 1/4 inch per ft (3 to 6 mm per 300 mm)** (one to two percent) in direction of intended drainage.
 - 2) Slope away from building **1/8 to 1/4 inch per ft (3 to 6 mm per 300 mm)** (one to two percent) minimum.
 - 3) Concrete walks shall be screeded to bring surface to grades and lines as indicated. Surface shall be floated with wood float with no coarse aggregate showing and then given broom finish before concrete sets.
- 5. Joints:
 - a. Control Joints (Contraction Joints):
 - 1) Form control joints with early-entry, dry-cut saws as soon as final trowel operations are complete, and joints can be cut without raveling.
 - 2) Depth of control joints shall be approximately one quarter of concrete slab thickness, but not less than **one inch (25 mm)**.
 - 3) Control joints to be hand tooled in sidewalks, curbs and gutters, mow strips, and aprons.
 - 4) Table One:

Concrete Control Joint On-Center Spacing (+/-)		
Sidewalks	4 feet to 6 feet	1.2 meters to 1.8 meters

Mow Strips	3 feet to 5 feet	0.90 meters to 1.50 meters
Flat Drainage Structures	10 feet	3 meters

b. Expansion Joints:

- 1) Expansion joints in Concrete Paving are specified in Section 32 1313.
- 2) Install so top of expansion joint material is 1/4 inch (6 mm) below finished surface of concrete.
- 3) No expansion joint required between curbs and sidewalks parallel to curb.
- 4) Provide expansion joints at ends of exterior site concrete elements that are perpendicular to and terminate at curbs, building foundations or other concrete elements (i.e. sidewalks, mow strips, aprons).
- 5) Provide expansion joints between sidewalks that are parallel, and adjacent, to storage building or main building.
- 6) Provide expansion joints around perimeter of concrete slab on grade at mechanical enclosure, around perimeter of slab on grade at dumpster enclosure and at top and bottom of exterior stairs.
- 7) Table Two:

Concrete Expansion Joint (Isolation) On-Center Spacing (+/-)		
Sidewalks, Curbs and Gutters	40 feet to 100 feet	12 meters to 30 meters
Mow Strips and Aprons	20 feet to 40 feet	6 meters to 12 meters

- 8) Seal expansion joints as specified in Section 07 9213 for following areas:
 - a) Between entryway slabs and building foundations.
 - b) Between sidewalks and building foundations.
 - c) Within flat drainage structures and at joints between flat drainage structures and other concrete elements.
 - 9) Expansion joints are not required to be sealed for following areas:
 - a) Within aprons and where apron abuts sidewalks.
 - b) Within mow strips and where mow strip abuts building foundation and sidewalks.
 - c) Within sidewalks.
6. Anchor Bolts:
- a. Place anchor bolts not tied to reinforcing steel immediately following leveling of concrete. Reconsolidate concrete around bolt immediately after placing bolt.
 - b. Do not disturb bolts during finishing process.

B. Finishing:

1. Interior Concrete Flatwork:
 - a. Screed Concrete.
 - b. Float Finish:
 - 1) Float as soon after screeding as possible.
 - 2) Consolidate surface with power-driven floats with exception of areas inaccessible to power-driven floats, which may be hand-floated.
 - 3) Re-straighten, cutting down high spots and filling low spots.
 - 4) Repeat float passes and re-straightening until surface has uniform, smooth, granular texture.
 - c. Trowel Finish:
 - 1) Steel trowel slab after concrete has set enough to avoid bringing water and fines to surface.
 - 2) Perform troweling with power-driven trowels with exception of areas inaccessible to power-driven trowels, which may be hand-troweled.
 - 3) Continue troweling passes and re-straightening with 10 foot (3 meter) highway straightedge until surface is free of trowel marks and uniform in texture and appearance.
 - 4) Apply burnished, burned-out trowel finish.
2. Exterior Concrete Flatwork:
 - a. Curb, Gutter, Sidewalks, Mow Strips, Flat Drainage Structures, And Miscellaneous:

- 1) After completion of final floating, performed immediately after screeding and when excess moisture or surface sheen has disappeared, complete surface finishing, as follows:
 - a) Provide fine hair finish where grades are less than 6 percent **1-1/4 inch (32 mm)**.
 - b) Provide rough hair finish where grades exceed 6 percent **1-1/4 inch (32 mm)**.
 - c) Broom finish, by drawing broom across concrete surface, perpendicular to line of traffic. Repeat operation if required to provide fine line texture acceptable to Architect. At curb and gutter, apply broom finish longitudinal to curb and gutter flowline.
 - d) On inclined slab surfaces, provide coarse, non-slip finish by scoring surface with stiff-bristled broom, perpendicular to line of traffic. At curb and gutter, apply broom finish longitudinal to curb and gutter flowline.
 - e) Do not remove forms for twenty-four (24) hours after concrete has been placed. After form removal, clean ends of joints and point-up any minor honeycombed areas. Remove and replace areas or sections with major defects, as directed by Architect.
 - f) Round edges exposed to public view to **1/2 inch (13 mm)** radius, including edges formed by expansion joints.
 - g) Remove edger marks.

C. Curing:

1. Membrane Concrete Curing:

- a. As specified in Section 09 3923 'Membrane Concrete Curing'.
- b. Follow Manufacturer's written instructions for preparation, application rates, placement, and cleanup:
 - 1) Apply product in areas where Water Concrete Curing is NOT used.
 - 2) Apply as soon as troweling on interior concrete is complete.
 - 3) Apply as soon as brooming or finishing of exterior concrete is complete.
 - 4) Spraying application is required.
 - 5) Do not dilute or thin product.
 - 6) Do not apply when temperature of concrete is less than **40 deg F (4.4 deg C)**.
 - 7) Apply uniformly without puddles or ponding.
 - 8) Do not apply before bleed water has dissipated.
 - 9) Do not apply over standing water.

D. Exterior Concrete Sealer:

1. Exterior Concrete Sealer:

- a. Exterior concrete placed after about September 1 and located in areas of freeze/thaw cycles and deicing salts are to be sealed per Section 03 3517 'Exterior Concrete Sealer'.
- b. Apply product as specified in Section 03 3517.

E. Tolerances:

1. General:

- a. Tolerances shall conform to requirements of ACI 117 or CSA A23.1/A23.2, except where specified differently:
 - 1) Floor test surfaces shall be measured and reported within seventy two (72) hours after completion of slab concrete finishing operations and before removal of any supporting shores to eliminate any curling effect F-numbers.
- b. Maximum Variation Tolerances:
 - 1) Table Three:

Maximum Variation Tolerances		
Thickness, standard	plus 3/8 inch, minus 1/4 inch	plus 9.5 mm, minus 3 mm
Thickness, footings	minus 0 inch	minus 0 mm
Plan, 0 - 20 feet	1/2 inch	12.7 mm
Plan, 40 feet or greater	3/4 inch	19 mm
Plan, footings	plus 1/2 inch	plus 12.7 mm
Eccentricity, footings	2 inch maximum standard,	50 mm maximum standard,

	1/2 inch at masonry	12.7 mm at masonry
Openings, size	minus 1/4 inch, plus one inch	minus 6 mm, plus 25.4 mm
Openings, location	plus / minus 1/2 inch at center	plus / minus 12.7 mm at center
Plumb	1/2 inch maximum	12.7 mm maximum
Consecutive Steps, treads	1/4 inch	6 mm
Consecutive Steps, risers	1/8 inch	3 mm
Flight of Stairs, treads	1/4 inch in total run	6 mm in total run
Flight of Stairs, risers	1/8 inch in total height	3 mm in total height

- 2. Local Flatness / Levelness of Interior Slabs:
 - a. Carpet and Tile Areas:
 - 1) Specified Overall Value of F_F25 / F_L20 and Minimum Local Value of F_F15 / F_L13 when tested in accordance with ASTM E1155.
 - 2) Specified Overall Value of F_F30 / F_L20 and Minimum Local Value of F_F18 / F_L13 when tested in accordance with ASTM E1155 in ceramic, resilient or vinyl tiled areas.
 - 3) Used on building slabs to be covered by carpet and tile as shown on Contract Drawings. Verify and coordinate with Finish Schedule.
 - 4) Remedy For Out-of-Tolerance Building Slabs:
 - a) Sections of building slabs which do not meet specified tolerances but are within ten (10) percent of specified tolerances, may be corrected by grinding or filling, at Owner's option.
 - b) Remove and replace sections of slabs measuring outside specified correctable tolerances.
 - c) Carpet areas: If floor leveling compounds or concrete patching compounds are required to bring floor into specified tolerances, they will be provided by Owner in conjunction with carpet installation and back-charged to Contractor.

- F. Non-Conforming Work: Non-conforming work as covered in the General Conditions applies, but is not limited to the following:
 - 1. Correct any work found defective or not complying with contract document requirements at no additional cost to the Owner.

3.4 CLEANING

- A. General:
 - 1. Curing:
 - a. Clean tools, equipment as directed by Manufacturer's instructions.

3.5 PROTECTION

- A. Concrete:
 - 1. Protect concrete that has not received its initial set from precipitation to avoid excess water in mix and unsatisfactory surface finish.
 - 2. Do not allow materials resulting from construction activities, which will affect concrete or application of finish floor systems adversely, to come in contact with interior concrete slabs.
 - 3. Protect interior concrete floors from stains, paint, mortar and other construction activities.

- B. Curing:
 - 1. Restrict foot or vehicle traffic as curing membrane dries as recommended by Manufacturer.

END OF SECTION

BLANK PAGE

SECTION 03 3517**CONCRETE SEALER FINISHING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Furnish and install Concrete Sealer on concrete surfaces as described in Contract Documents including:
 - a. Concrete sealers are used on existing or new exterior concrete surfaces exposed to freeze/thaw cycles and deicing salts or where exterior concrete is placed after about September 1st or as otherwise desired by Project Manager or Facilities Manager.
 - 1) Concrete sealer on exterior concrete is not needed or used in areas not exposed to freeze/thaw cycles and deicing salts.
- B. Related Requirements:
1. Section 03 3111: 'Cast-In-Place Structural Concrete' for concrete mix information and use admixtures.
 2. Section 07 9213: 'Elastomeric Joint Sealant' for quality of sealants'.

1.2 REFERENCES

- A. Definitions:
1. Concrete Sealers: As used in this specification, are sealers applied to concrete surfaces to protect from surface damage, corrosion, and staining. Sealers either block pores in concrete to reduce absorption of water and salts or form impermeable layer which prevents such materials from passing. Concrete sealer, when selected and applied properly, will prevent intrusion of water and deicers, minimizing freeze/thaw damage.
- B. Reference Standards:
1. American Association of State and Highway Transportation Officials:
 - a. AASHTO T 259-02(2012), 'Standard Method of Test for Resistance of Concrete to Chloride Ion'.
 - b. AASHTO T 260-97(2011), 'Standard Method of Test for Sampling and Testing for Chloride Ion in Concrete and Concrete Raw Materials'.
 2. ASTM International:
 - a. ASTM C672/C672M-12 'Standard Test Method for Scaling Resistance of Concrete Surfaces Exposed to Deicing Chemicals'.
 3. German Institute for Standardization (DIN Standards):
 - a. DIN EN 1504-2, 'Products and systems for the protection and repair of concrete structures - Definitions, requirements, quality control and evaluation of conformity - Part 2: Surface protection systems for concrete (2005).

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference: Schedule pre-installation conference for same time as application of mockup application.
- B. Sequencing:
1. Concrete Pavement:
 - a. Install Concrete Sealer before paint stripes are placed on concrete pavement.
 - b. Apply to prepared surfaces no sooner than about thirty (30) days after concrete placement.
 - c. Do not use concrete sealers to replace Membrane Concrete Curing.

1.4 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Concrete Sealer:
 - 1) Manufacturer's product literature or cut-sheets for specified products.
 - 2) Manufacturer's LEED product literature for specified products.
- B. Informational Submittals:
 - 1. Manufacturer Instructions:
 - a. Concrete Sealer: Written preparation and application instructions.
 - 2. Source Quality Control Submittals:
 - a. Provide protection plan of surrounding areas and non-work surfaces if requested by Architect/Owner's Representative.
 - 3. Qualification Statements:
 - a. Applicator: Provide qualification documentation.

1.5 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Comply with applicable VOC standards and other local requirements.
- B. Qualifications:
 - 1. Applicator:
 - a. Applicator shall be acceptable to Manufacturer as applicator of its product.
 - b. Minimum five (5) satisfactorily completed installations of comparable quality, scope, similar size, and complexity in past two (2) years before bidding. Include contact information of person with oversight of each project.
 - c. Provide qualification documentation.
- C. Mockup:
 - 1. Required for all projects. Scheduled as per pre-installation conference.
 - 2. Mockup shall be representative of work to be expected.
 - 3. Mockup will be used to judge workmanship, concrete substrate preparation, operation of equipment, material application.
 - 4. Square footage or size of mock up is between Architect/Owner's Representative and Concrete Sealer Applicator. Consider between **10 sq ft to 20 sq ft (0.93 to 1.86 sq m)** for small projects and **100 sq ft to 200 sq ft (9.3 to 18.6 sq m)** for larger areas.
 - 5. Provide as many field mockups required to verify selections made under submittals and to demonstrate effects of concrete sealer. Approval does not constitute approval of deviations from Contract Documents, unless such deviations are specifically approved by Architect/Owner's Representative in writing.
 - 6. Install mockup in accordance with specification using same materials, staff and equipment.
 - 7. Use same personnel that will be doing project, including Supervisor.
 - 8. Approvals should be based on:
 - a. Compliance with approved submittals.
 - 9. Approval from Architect/Owner's Representative is required BEFORE starting work on Project.
 - 10. Allow twenty four (24) hours for inspection of mockup before proceeding with work.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Materials shall be delivered in original, unopened packages with labels intact.
- B. Storage And Handling Requirements:
 - 1. Follow Manufacturer's written instructions for handling and storage of product.

- a. Store in unopened containers in clean, dry area between 35 deg F (2 deg C) and 110 deg F (43 deg C) or as directed by Manufacturer's instruction.

1.7 FIELD CONDITIONS

A. Ambient Conditions:

1. Concrete Sealer:
 - a. Follow printed Manufacturer's instruction for environmental hazards:
 - b. Follow printed Manufacturer's instruction for ambient conditions for application of product including:
 - 1) Minimum and maximum application temperatures.
 - 2) Application precautions when rain is expected.

PART 2 - PRODUCTS

2.1 PRODUCTS

A. Exterior Concrete Sealer:

1. Description:
 - a. Concrete sealer that protects new and existing exterior concrete from freeze/thaw cycles and deicing salts.
2. Design Criteria:
 - a. General:
 - 1) Penetrating water repellent silane or linseed oil/mineral spirit concrete sealers are to be used.
 - 2) Siloxanes are not to be used to replace silane or linseed oil/mineral spirits sealers.
 - b. Linseed Oil/Mineral Spirits Sealers:
 - 1) Protects concrete from freeze/thaw cycles and deicing salts.
 - 2) Resists penetration of water and deicing salts.
 - c. Silane Based Sealers:
 - 1) Protects concrete from freeze/thaw cycles and deicing salts.
 - 2) Resists penetration of water and deicing salts.
 - 3) 100 percent silane active ingredient content.
 - 4) Penetrating sealer.
 - 5) Water repellent.
 - 6) Clear (colorless, non-yellowing). Surface appearance after application: unchanged.
3. Limitations:
 - a. VOC:
 - 1) If Low VOC product are required or desired, use only those products listed as 'Low VOC' in acceptable products below.
4. Type One Acceptable Products. See Section 01 6200 for definition of Categories. Applicator Option:
 - a. Linseed Oil/Mineral Spirits Sealers:
 - 1) Anti Spall J33 Concrete Sealer by Dayton Superior Corporation, Miamisburg, OH www.daytonsuperior.com.
 - a) Low VOC.
 - 2) Equal product meeting design criteria requirements as approved by Architect/Owner's Representative before BID. See Section 01 6200.
 - b. Silane Based Sealers:
 - 1) MasterProtect H 1000 by BASF, Cleveland, OH www.master-builders-solutions.basf.us.
 - a) Low VOC.
 - 2) Weather Worker J29A by Dayton Superior Corporation, Miamisburg, OH www.daytonsuperior.com.
 - 3) Barcade Silane 100 by Euclid, Cleveland, OH www.euclidchemical.com.
 - a) Low VOC.
 - 4) Sikagard 705L by Sika Corporation, Lyndhurst, NJ www.usa.sika.com.

- a) Low VOC.
- 5) TK-590-100 by TK Products, Minnetonka, MN www.tkproducts.com.
- 6) Equal product meeting design criteria requirements as approved by Architect/Owner's Representative before BID. See Section 01 6200.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification Of Conditions:
 - 1. Verify concrete has properly cured.

3.2 PREPARATION

- A. Surface Preparation:
 - 1. Concrete Sealer:
 - a. Take necessary precautions to protect adjoining property.
 - b. Do not contaminate any body of water by direct application, cleaning of equipment or disposal of wastes.
 - 2. Cleaning:
 - a. Clean concrete surface of membrane curing and all dirt, mud spots, silt spots, loose material, vegetation, oil spots, and other objectionable and foreign material.
 - b. Remove debris, sand, dirt, and dust from concrete surface.
 - c. Power brooms, power blowers, air compressors, water flushing equipment, and blowers are acceptable equipment for cleaning concrete surface.

3.3 PREPARATION

- A. Protection Of In-Place Conditions:
 - 1. Sterilant/Concrete Sealer:
 - a. Take necessary precautions to protect adjoining property and areas designated for planting on building site. Use drop cloths or masking as required.
 - b. Do not contaminate any body of water by direct application, cleaning of equipment or disposal of wastes.
- B. Surface Preparation:
 - 1. Paint Stripes:
 - a. Do not remove paint strips and markings if they do not interfere with performance of Concrete Sealer.
 - b. Remove existing paint stripes and markings that interfere with performance of Concrete Sealer.
 - 2. Grease or Oil Patches:
 - a. Remove grease or oil patches, and spillage of any material that has adhered to concrete surface.
 - 3. Cracks, Control Joints and Expansion Joints:
 - a. Remove weed and other live vegetation matter from concrete cracks (if any) and joints:
 - 1) Remove with wire wheel on crack cleaner/edger.
 - b. Repair concrete cracks and joints if required using sealant as specified in Section 07 9213.
 - 4. Cleaning:
 - a. Clean concrete surface of all dirt, mud spots, silt spots, loose material, vegetation, oil spots, and other objectionable and foreign material.
 - b. Remove debris, sand, dirt, and dust from concrete surface.
 - c. Power brooms, power blowers, air compressors, water flushing equipment, and blowers are acceptable equipment for cleaning concrete surface.
 - d. Concrete surface is to be dry, clean and sound.

5. Inspect concrete surface. Repeat any steps if necessary.

3.4 APPLICATION

A. Concrete Sealer:

1. General:
 - a. Apply concrete sealer after surface preparation has been completed as per Manufacturer's recommendations.
 - b. Follow Manufacturer's ambient conditions for minimum and maximum application temperatures and application precautions when rain is expected.
 - c. Stir material thoroughly before and during application if required by Manufacturer.
 - d. Do not apply sealer if standing water is visible on concrete surface to be treated.
 - e. Apply even distribution of sealer.
 - f. Do NOT over apply. All product should penetrate substrate with no surface build-up. Any excess or puddles of material must be removed.
2. Apply Concrete Sealer:
 - a. Linseed Oil/Mineral Spirits Sealers:
 - 1) For maximum protection, apply onto concrete surface before it is exposed to deicing salts.
 - 2) Do not apply in temperatures below 40 deg F (4.4 deg C).
 - 3) Apply first coat at 1 gallon (3.785 liters) per 350 sq ft (32.5 sq m).
 - 4) When first coat is dry to touch, apply second coat at 1 gallon (3.785 liters) per 600 sq ft (55.7 sq m).
 - 5) When second coat is totally dry, surface is ready for traffic.
 - 6) Texture and absorption of surface will influence final coverage rates.
 - 7) This application will turn concrete to dark amber color.
 - b. Silane Based Sealers:
 - 1) Apply at rate of about 1 gallon (3.785 liters) per 300 sq ft (27.8 sq meters) or as per Manufacturer's recommendations depending upon absorbency of concrete surface.
3. Allow Concrete Sealer to dry as per Manufacturer's recommendations.

3.5 CLEANING

A. General:

1. Upon completion of crack seal operations, clean up and remove debris.
2. Clean tools, equipment and spills as directed by Manufacturer's instructions.
3. Clean drips and over spray while still wet.

B. Waste Management:

1. Sterilant/Concrete Sealers:
 - a. Follow Manufacturer's recommendations for approved disposal of product and containers.
 - 1) Do not reuse empty containers.

END OF SECTION

BLANK PAGE

SECTION 03 3923**MEMBRANE CONCRETE CURING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Quality of membrane concrete curing as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 03 3111: 'Cast-In-Place Structural Concrete' for application of membrane concrete curing.
 - 2. Section 03 3517: 'Concrete Sealer-Finishing' for application of concrete sealer.

1.2 REFERENCES

- A. Definitions:
 - 1. Curing: Process by which hydraulic-cement concrete matures and develops hardened properties, over time, as result of continued hydration of cement in presence of sufficient water and heat. Also used to describe action taken to maintain moisture and temperature conditions in freshly placed concrete.
- B. Reference Standards:
 - 1. American Association of State and Highway Transportation Officials:
 - a. AASHTO M 148-05, 'Standard Specification for Liquid Membrane-Forming Compounds for Curing'.
 - 2. ASTM International:
 - a. ASTM C309-11, 'Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete'.

1.3 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Manufacturer's product data.
 - b. Material Safety Data Sheets (MSDS).
- B. Informational Submittals:
 - 1. Manufacturer Instructions:
 - a. Printed installation instructions.

1.4 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Comply with applicable VOC standards and other local requirements.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Materials shall be delivered in original, unopened packages with labels intact.

B. Storage And Handling Requirements:

1. Follow Manufacturer's written instructions for handling and storage of product:
 - a. Store in unopened containers in clean, dry area between **35 deg F (2 deg C)** and **110 deg F (43 deg C)** (Keep from freezing) or as directed by Manufacturer's instruction.
2. Shelf Life: Do not use curing compound that is over one (1) year from manufacturer date.

1.6 FIELD CONDITIONS**A. Ambient Conditions:**

1. Do not apply curing compound when temperature of concrete is less than **40 deg F (4.4 deg C)**.

PART 2 - PRODUCTS**2.1 MATERIALS****A. Membrane Concrete Curing:**

1. Description:
 - a. Clear water-based, ready-to use membrane curing agent that cures freshly placed concrete, forming effective barrier against moisture loss from concrete surface.
2. Design Criteria:
 - a. Exterior Concrete:
 - 1) Dissipating or non-dissipating membrane curing agent.
 - b. Interior Concrete:
 - 1) Dissipating membrane curing agent only.
 - c. VOC-compliant compound.
 - d. Meet requirements of ASTM C309 and AASHTO M 148, Type 1 or 1-D, Class B.
 - e. Interior concrete: containing no mineral spirits, naphtha, or other components detrimental to finish flooring installation.
 - f. Maintain ninety-five (95) percent of mix water present in concrete mass after application.
 - g. Gradually dissipate after twenty-eight (28) days without leaving stain or discoloring concrete surface.
3. Horizontal and Vertical Cast-In-Place Structural Concrete:
 - a. Type One Acceptable Products.
 - 1) Exterior Concrete:
 - a) Clear Cure J7WB by Dayton Superior Corporation, Miamisburg. OH www.daytonsuperior.com.
 - b) Clear Water Resin by Right Point, Dekalb, IL www.rightpointe.com.
 - c) L&M Cure R by L&M Construction Chemicals, Inc. Omaha, NE www.lmcc.com.
 - d) VOCOMP 20 (do not use when concrete sealer will be applied in areas of freeze/thaw and deicer salts) by W.R. Meadows, Inc. Hampshire, IL www.wrmeadows.com.
 - e) 1100-Clear by W. R. Meadows, Inc. Hampshire, IL www.wrmeadows.com.
 - 2) Interior Concrete:
 - a) Clear Cure J7WB by Dayton Superior Corporation, Miamisburg. OH www.daytonsuperior.com.
 - b) Clear Water Resin by Right Point, Dekalb, IL www.rightpointe.com.
 - c) L&M Cure R by L&M Construction Chemicals, Inc. Omaha, NE www.lmcc.com.
 - d) 1100-Clear by W. R. Meadows, Inc. Hampshire, IL www.wrmeadows.com.
 - b. Equal product meeting design criteria requirements as approved by Architect/Owner's Representative before BID. See Section 01 6200.

PART 3 - EXECUTION: Not Used**END OF SECTION**

SECTION 03 6213**NON-METALLIC NON-SHRINK GROUTING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install structural grout as described in Contract Documents.
 - a. For securing rebar, anchor bolts and hardware in concrete.

1.2 REFERENCES

- A. Association Publications:
 - 1. American Concrete Institute:
 - a. ACI 305R-10, 'Guide to Hot Weather Concreting'.
 - b. ACI 306R-10, 'Guide to Cold Weather Concreting'.
 - c. ACI 351.1R-12, 'Grouting Between Foundations and Bases for Support of Equipment and Machinery'.
- B. Reference Standards:
 - 1. ASTM International:
 - a. ASTM C1107/C1107M-17, 'Standard Specification for Packaged Dry, Hydraulic-Cement Grout (Non-shrink).'
 - 2. United States Army Corps of Engineers (USACE):
 - a. CRD C-621-93, 'Handbook for Concrete and Cement Standard Specification for Packaged, Dry, Hydraulic-Cement Grout (Nonshrink'.

1.3 SUBMITTALS

- A. Action Submittals
 - 1. Product Data:
 - a. Manufacturer's data sheets on each product to be used, including:
 - 1) Preparation instructions and recommendations.
 - 2) Storage and handling requirements and recommendations.
 - 3) Manufacturer's printed installation instructions for each product.

1.4 DELIVERY, STORAGE AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Materials shall be delivered in original, unopened packages with labels intact clearly identifying product name and manufacturer until time of use.
- B. Storage And Handling Requirements:
 - 1. Follow Manufacturer's recommendations including but not limited to following:
 - a. Store in clean, dry location.
 - b. Keep containers sealed until ready for use.
 - c. Store materials at room temperature before use.
 - 2. Protect materials during handling and placement to prevent damage or contamination.
 - a. Protect materials from freezing or overheating.
 - 3. Shelf Life: One (1) year minimum in original, unopened containers.

1.5 FIELD CONDITIONS

- A. Ambient Conditions:
 - 1. General:
 - a. Do not place grout over frozen concrete.
 - 2. Maintain environmental conditions and protect Work during and after installation to comply with referenced standards and Manufacturer's printed recommendations:
 - a. Do not install products under environmental conditions outside Manufacturer's recommendations.
 - 3. Follow ACI requirements for cold and hot weather concreting or Manufacturer's written instructions, whichever is more stringent:
 - a. Cold Weather Limitations:
 - 1) Follow requirements of ACI 306R for cold weather concreting.
 - b. Hot Weather Limitations:
 - 1) Follow requirements of ACI 305R for hot weather concreting.
 - c. ACI 305R-10, 'Guide to Hot Weather Concreting'.
 - d. ACI 306R-10, 'Guide to Cold Weather Concreting'.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Design Criteria:
 - 1. Description:
 - a. Commercial non-shrink, non-metallic grout.
 - 2. Meet following requirements:
 - a. ASTM C1107/C1107M, Type B or Type C.
 - b. Corps and Engineers CRD C-621.
 - c. Compressive strength of **6000 psi (41 MPa)** minimum.
- B. Type Two Acceptable Products:
 - 1. Masterflow 928 by BASF Systems, Shakopee, MN or BASF Canada, Mississauga, ON www.buildingsystems.basf.com
 - 2. ProSpec F77 by Bonsal American, Inc., Charlotte, NC www.bonsal.com.
 - 3. Advantage 1107 Grout by Dayton Superior Corporation, Oregon, IL www.daytonsuperiorchemical.com.
 - 4. NS Grout by Euclid Chemical Company, Cleveland, OH www.euclidchemical.com.
 - 5. Five Star Grout by Five Star Products Inc, Fairfield, CT www.fivestarproducts.com.
 - 6. Duragrout by L&M Construction Chemicals Inc., Omaha, NE www.lmcc.com.
 - 7. Planigrout 712 by MAPEI Corporation, Deerfield Beach, FL www.mapei.US or Mapei Inc., Laval, QC www.mapei.com/CA.
 - 8. SikaGrout 212 by Sika Corporation, Lyndhurst, NJ www.usa.sika.com or Sika Canada, Inc. Pointe-Claire, QC www.can.sika.com.
 - 9. MP Grout by US Mix Products Company, Denver, CO www.usspec.com.
 - 10. Sealtight CG-86 Grout by W R Meadows, Hampshire, IL www.meadows.com.
 - 11. Equal as approved by Architect before installation. See Section 01 6200.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification Of Conditions:
 - 1. Examine substrate and verify substrate is suitable for installation.
 - 2. Notify Architect of unsuitable conditions in writing.
 - a. Do not install board over unsuitable conditions.

- b. Commencement of Work by installer is considered acceptance of substrate.

3.2 PREPARATION

- A. Surface Preparation:
 1. Prepare concrete surfaces in accordance with Manufacturer's written instructions:
 2. Remove all loose materials.
 3. Clean surface of any substance that could interfere with bond on material including dirt, paint, tar, asphalt, wax, oil, grease, latex compounds, form release agents, laitance, loose toppings, foreign substances and any other residues.
 4. Saturate area to be grouted with water in accordance with Manufacturer's written instructions.

3.3 APPLICATION

- A. General:
 1. Follow Manufacturer's recommended thickness.
- B. Mixing:
 1. Mix grout in accordance with Manufacturer's written instructions.
 2. Add mix water in amount in accordance with Manufacturer's written instructions to provide required placing consistency.
 3. Do not add water in amount that will cause bleeding or segregation of mixed grout.
 4. Do not add any sand, cement, admixtures, or fluidifiers to grout.
- C. Placement:
 1. Place grout in accordance with Manufacturer's written instruction including but not limited to the following:
 - a. Proper curing is required.
 - b. Use cold weather or hot weather grouting procedures in accordance with Manufacturer's written instructions, as temperature dictates:
 - 1) Do not use at temperatures that may cause premature freezing.
 - 2) Do not allow to freeze until 4000 psi (27.6 MPa) is attained.
 - c. Employ cold weather or hot weather grouting practices as temperatures dictates.
 2. Completely eliminate air pockets and provide full contact between grout and item being grouted. Do not exceed Manufacturer's recommended thickness.
- D. Curing:
 1. Cure grout in accordance with Manufacturer's written instructions or ACI curing practices.
 2. Wet cure grout until forms are removed.
 3. Seal grout surfaces after forms are removed as recommended by Manufacturer.
- E. Keep grout surfaces wet after curing compound has dried for as long as recommended by Manufacture.

3.4 FIELD QUALITY CONTROL

- A. Field Inspections:
 1. Verify product has been installed as per Contract Documents and Manufacturer's written instructions.
- B. Non-Conforming Work: Non-conforming work as covered in the General Conditions applies, but is not limited to the following:
 1. Correct any work found defective or not complying with Contract Document requirements at no additional cost to the Owner.

3.5 CLEANING

- A. Use clean water.
- B. Clean tools and equipment with water before material hardens.

3.6 PROTECTION

- A. Follow Manufacturer's recommendation for protection when applying material.
- B. Protect placed grout from freezing until minimum strength of 4000 psi (27.58 MPa) is reached.
- C. Protect placed grout from damage during construction.

END OF SECTION

DIVISION 05: METALS

05 0500 COMMON WORK RESULTS OF METALS

05 0503 SHOP-APPLIED METAL COATINGS
05 0523 METAL FASTENINGS

05 5000 METAL FABRICATIONS

05 5214 GALVANIZED STEEL PIPE AND TUBE RAILINGS

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 05 0503**SHOP-APPLIED METAL COATINGS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Quality of factory or shop-applied priming applied to steel supplied to Project without finish coat.
 - 2. Quality of and procedures for field touch-up and repair of factory-applied priming and galvanizing.
- B. Related Requirements:
 - 1. Section 05 4010: 'Cold-Formed Load-Bearing Metal Framing' for repair to galvanized coatings.
 - 2. Sections under 09 9000 heading: Finish painting.

1.2 REFERENCES

- A. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A780/A780M-09(2015), 'Standard Practice for Repair of Damaged and Uncoated Areas of Hot-Dip Galvanized Coatings'.
 - b. ASTM B695-04(2016), 'Standard Specification for Coatings of Zinc Mechanically Deposited on Iron and Steel'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 - 1. Participate in pre-installation conference.
 - 2. In addition to requirements of Section 01 3100, review following:
 - a. Meet with Architect before commencing repair of galvanized surfaces to establish extent of repairs required and, if applicable, choice of methods to be used.

1.4 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Product data and samples, if requested by Architect.

PART 2 - PRODUCTS**2.1 FINISHES**

- A. Factory And Shop-Applied Primer:
 - 1. Compatible with and of equal or better quality than finish paint system to be applied by Sections under 09 9000 heading.
 - 2. Primer on unexposed, unfinished surfaces may be fabricator's standard shop coat.
- B. Repairs To Primed Surface:

- C. Unless otherwise specified, use primer which matches characteristics of original primer and is compatible with and of equal or better quality than finish paint system to be applied by Sections under 09 9000 heading.
- D. Material For Repairs Of Galvanized Surfaces:
1. Non-Structural, Non-Load-Bearing Items Not Exposed To Weather:
 - a. Zinc-Rich Paints:
 - 1) Zinc-Dust Content: Dried film shall contain 94 percent minimum of zinc-dust by weight.
 - 2) Type One Acceptable Manufacturers:
 - a) Galvax by Alvin Products Inc, Everett, MA www.alvinproducts.com.
 - b) ZRC Galvilite by ZRC Worldwide, Marshfield, MA www.zrcworldwide.com.
 - c) Equal as approved by Architect before bidding. See Section 01 6200.
 2. Structural, Load-Bearing Items And Items Exposed To Weather:
 - a. Zinc-Based Solders, Powder, Or Rod:
 - 1) Zinc-Cadmium solder with liquidus temperature range from 518 to 527 deg F (270 to 275 deg C), or
 - 2) Zinc-Tin-Lead alloy with liquidus temperature range from 446 to 500 deg F (230 to 260 deg C).
 - b. Sprayed Zinc: Wire, ribbon, or powdered zinc suitable for process.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Surface Preparation:
1. General:
 - a. Clean, grind, or otherwise prepare welds in steel that is to be coated within limits acceptable to welder responsible for structural integrity.
 - b. Surfaces to be coated shall be clean, dry and free of oil, grease, and corrosion products.
 2. Preparation Of Primed, Ungalvanized Surfaces:
 - a. Clean welds and grind serious abrasions.
 3. Preparation Of Galvanized Surfaces:
 - a. Follow requirements of ASTM A780/A780M and following:
 - b. For Repair Using Zinc-Rich Paints:
 - 1) Blast clean surfaces to near-white metal, in accordance with SSPC-SP10 (1 to 2 mil anchor pattern), as minimum.
 - 2) Where circumstances do not allow blast cleaning, power disk sand to bright metal finish.
 - 3) Extend surface preparation into undamaged galvanized area.
 - 4) Remove flux residue and weld spatter from welded areas.
 - c. For Repair Using Zinc-Based Alloys:
 - 1) Clean surface to be reconditioned using wire brush, light grinding action, or mild blasting.
 - 2) Extend surface preparation into surrounding, undamaged galvanized areas.
 - 3) Remove flux residue and weld spatter from welded areas.
 - 4) Preheat cleaned area to at least 600 deg F (316 deg C).
 - a) Do not overheat surface beyond 750 deg F (400 deg C) or allow surrounding galvanized coatings to be burned.
 - b) Wire brush surface during preheating.
 - d. For Repair Using Sprayed Zinc (Metallizing):
 - 1) Blast clean surfaces to near-white metal, in accordance with SSPC-SP5 as minimum.
 - 2) Extend surface preparation into undamaged galvanized area.
 - 3) Remove flux residue and weld spatter from welded areas.

3.2 REPAIR / RESTORATION

- A. Repairs To Primed, Ungalvanized Surfaces:
 - 1. Thoroughly clean metal and give one (1) prime coat of specified material, well-worked into metal joints and open spaces. Match existing primed finish as required.
 - a. Do not apply primer at temperatures below 45 deg F (7 deg C).
 - b. Protect un-primed machine-finished surfaces against corrosion by priming.

- B. Repairs To Galvanized Surfaces:
 - 1. Non-Structural, Non-Load-Bearing Items Not Exposed To Weather:
 - a. Repair Using Zinc-Rich Paints: Spray- or brush-apply zinc-rich paint to prepared area. Apply paint in single application employing multiple spray passes to achieve dry film thickness of 2 mils.
 - 2. Structural, Load-Bearing Items And Items Exposed To Weather:
 - a. Repair Using Zinc-Based Alloys:
 - 1) Rub cleaned, pre-heated areas with repair stick to deposit evenly distributed layer of zinc alloy. If powdered zinc alloys are used, sprinkle powder on surface and spread out with spatula or similar tool.
 - 2) Remove flux residue by rinsing with water or wiping with damp cloth.
 - b. Repair Using Sprayed Zinc (Metallizing): Apply 2 mil minimum coating by means of metal-spraying pistols fed with either zinc wire or zinc powder in accordance with requirements of ASTM B695, Type I.
 - 3. All Items:
 - a. Apply repair materials immediately after surface preparation is complete.
 - b. Take thickness measurements, with either magnetic or electromagnetic gauge, to ensure applied coating is as specified or agreed to.

END OF SECTION

BLANK PAGE

SECTION 05 0523**METAL FASTENING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Quality of structural metal-to-metal, wood-to-metal, and wood-to-wood bolts used on Project.
 - 2. Requirements and standards for site welded metal-to-metal connections.
- B. Related Requirements:
 - 1. Section 03 1511: 'Concrete Anchors And Inserts' for cast-in-place and drilled-in anchor bolts.
 - 2. Furnishing and installing of structural bolts specified under Section concerned.
 - 3. Performance of welding specified under Section concerned.

1.2 REFERENCES

- A. Reference Standards:
 - 1. American National Standards Institute / American Welding Society:
 - a. ANSI/AWS D1.1/D1.1M:2015, 'Structural Welding Code - Steel'.
 - b. ANSI/AWS D1.3/D1.3M:2018, 'Structural Welding Code - Sheet Steel'.
 - 2. ASTM International:
 - a. ASTM A307-14, 'Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi Tensile Strength'.

1.3 QUALITY ASSURANCE

- A. Qualifications: Requirements of Section 01 4301 applies, but not limited to the following:
 - 1. Welders shall be certified 30 days minimum before beginning work on Project. If there is doubt as to proficiency of welder, Architect may require welder to take another test, at no expense to Owner. Certification shall be by Pittsburgh Laboratories or other authority approved by Architect.
- B. Certifications:
 - 1. Maintain welder's certifications on job-site.

PART 2 - PRODUCTS**2.1 MANUFACTURED UNITS**

- A. Materials:
 - 1. Bolts And Threaded Fasteners:
 - a. Bolts: Conform to requirements of ASTM A307, Grade A.

2.2 ACCESSORIES

- A. Arc-Welding Electrodes: Type E70XX AWS Iron and Steel Arc-welding electrodes and meeting current AISC Specifications.

PART 3 - EXECUTION

3.1 PERFORMANCE

- A. Welding shall meet requirements of ANSI / AWS D1.1 and D1.3.

END OF SECTION

SECTION 05 5214**GALVANIZED STEEL PIPE AND TUBE RAILINGS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install galvanized steel pipe handrails as described in Contract Documents.
- B. Products Furnished But Not Installed Under This Section:
 - 1. Anchoring sleeves in concrete (if used).
- C. Related Requirements:
 - 1. Section 03 3111: 'Normal-Weight Structural Concrete' for installation of anchoring sleeves.
 - 2. Section 05 0503: 'Shop-Applied Metal Coatings' for quality of priming and repair of galvanizing.
 - 3. Section 05 0523: 'Metal Fastening' for quality of welding.
 - 4. Section 06 1100: 'Wood Framing' for blocking for handrail brackets installed on wood-framed walls.
 - 5. Section 09 2216: 'Non-Structural Metal Framing' for blocking for handrail brackets installed on metal-framed walls.
 - 6. Finish painting:
 - a. Section 09 9113: 'Exterior Painted Galvanized Metal'.
 - b. Section 09 9124: 'Interior Painted Metal'.
 - 7. Section 10 2813: 'Commercial Toilet Accessories' for grab bars in Rest Rooms.

1.2 REFERENCES

- A. Definitions:
 - 1. Galvanized: To coat iron or steel with zinc for protection from rust and corrosion.
 - 2. Non-shrink Grout: Structural grout used for filling voids between elements that is formulated with cement, fine aggregates and admixtures. Admixtures are used to provide expansive properties of the material during curing. This expansion counteracts the natural tendency of cement grouts to shrink during curing.
- B. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A53/A53M-18, 'Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless'.
 - b. ASTM A501/A501M-14, 'Standard Specification for Hot-Formed Welded and Seamless Carbon Steel Structural Tubing'.
 - c. ASTM C1107/C1107M-17, 'Standard Specification for Packaged Dry, Hydraulic-Cement Grout (Nonshrink)'.

1.3 SUBMITTALS

- A. Action Submittals:
 - 1. Shop Drawings: Show fabrication and installation of handrails and railings including floor plans, elevations, sections, details of components, and attachments to other elements of The Work.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Storage And Handling Requirements:

1. Store handrails and railing systems in clean, dry location, away from uncured concrete and masonry, and protected against damage.
2. Cover with waterproof paper, tarpaulin, or polyethylene sheeting. Allow for air circulation inside covering.

PART 2 - PRODUCTS

2.1 ASSEMBLIES

A. Materials:

1. Handrails, Railings, And Balusters:
 - a. Galvanized steel pipe meeting requirements of ASTM A53/A53M or galvanized steel tubing meeting requirements of ASTM A501/A501M.
 - b. **1-1/2 inch (38 mm)** outside diameter.
2. Sleeves:
 - a. **6 to 9 inches (150 to 225 mm)** long with cross-section shape and dimension to allow **1/2 inch (12.7 mm)** minimum of grout around perimeter of pipe or tube.
 - b. Provide with fully welded steel plate forming bottom closure.
3. Brackets, Flanges, Fittings, And Anchors:
 - a. Provide standard wall brackets, flanges, miscellaneous fittings, and anchors for connection of handrails and railings to other construction.
 - b. Provide inserts and other anchorage devices for connecting handrails and railing systems to concrete or masonry work.

B. Fabrication:

1. Preassemble railing systems in shop to greatest extent possible to minimize field splicing and assembly.
2. Disassemble units only as necessary for shipping and handling limitations. Clearly mark units for reassembly and coordinated installation. Use connections that maintain structural value of joined pieces.
3. Grind smooth welded joints and buff welds to same appearance as remainder of railing. Repair galvanizing and cut pipe ends as specified in Section 05 0503.
4. Form curves by bending pipe in jigs to produce uniform curvature for each configuration required. Maintain cylindrical cross-section of pipe throughout entire bend without buckling, twisting, cracking, or otherwise deforming exposed surfaces of pipe.
5. Welded Connections:
 - a. Fabricate railing system and handrail connections by welding.
 - b. Weld corners and seams continuously to comply with following:
 - 1) Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
 - 2) At tee and cross intersections, notch ends of intersecting members to fit contour of pipe to which end is joined and weld all around.
 - 3) At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and so contours of welded surfaces match adjacent surfaces.
6. Return pipe ends of wall mounted handrails into wall.
7. Cap pipe ends of floor / ground mounted handrails and exterior handrails.
8. After fabrication, shop prime metal to be painted.

2.2 ACCESSORIES

A. Rail Setting Grout:

1. Commercial nonshrink grout conforming to requirements of ASTM C1107/C1107M, Type B or Type C.
2. Type Two Approved Manufacturers:
 - a. Normal Construction Grout A by Bonsal American, Charlotte, NC www.bonsal.com.

- b. Advantage 1107 Grout by Dayton Superior Specialty Chemicals, Kansas City, KS www.daytonsuperiorchemical.com.
- c. NS Grout by Euclid Chemical Co, Cleveland, OH www.euclidchemical.com
- d. 5 Star Special Grout 110 by Five Star Products Inc, Fairfield, CT www.fivestarproducts.com.
- e. Duragrout by L&M Construction Chemicals Inc, Omaha, NE www.lmcc.com
- f. Sonneborn / BASF Building Systems, Shakopee, MN www.chemrex.com.
- g. Tamms Grout 621 by TAMMS Industries, Mentor, OH www.tamms.com.
- h. U S Spec MP Grout by U S Mix Products Co www.usspec.com.
- i. CG-86 Grout by W R Meadows, Hampshire, IL www.wrmeadows.com.
- j. Equal as approved by Architect before use. See Section 01 6200.

PART 3 - EXECUTION

END OF SECTION

BLANK PAGE

DIVISION 06: WOOD, PLASTICS, AND COMPOSITES

06 0500 COMMON WORK RESULTS OF WOOD, PLASTICS, AND COMPOSITES

06 0573 PRESERVATIVE WOOD TREATMENT

06 1000 ROUGH CARPENTRY

06 1011 WOOD FASTENINGS

06 1100 WOOD FRAMING

06 2000 FINISH CARPENTRY

06 2001 COMMON FINISH CARPENTRY REQUIREMENTS

06 2024 DOOR, FRAME, AND FINISH HARDWARE INSTALLATION

06 2210 MISCELLANEOUS WOOD TRIM

06 4000 ARCHITECTURAL WOODWORK

06 4001 COMMON ARCHITECTURAL WOODWORK REQUIREMENTS

06 4512 ARCHITECTURAL WOODWORK WOOD TRIM

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 06 0573**PRESERVATIVE WOOD TREATMENT****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Quality of wood preservative treatment where specified.
- B. Related Requirements:
 - 1. Section 06 1100:
 - a. Characteristics of wood to be pressure-treated.
 - b. Furnishing and installing of pressure-treated wood.

1.2 REFERENCES

- A. Definitions:
 - 1. Preservative-Treated Wood: Wood exposed to high levels of moisture or heat susceptible to decay by fungus and other organisms, and to insect attack. The damage caused by decay or insects can jeopardize the performance of the wood members so as to reduce the performance below that required. Preservative treatment requires pressure-treatment process to achieve depth of penetration of preservative into wood to verify that the wood will be resistant to decay and insects over time.
 - 2. Treated Wood: Wood impregnated under pressure with compounds that reduce its susceptibility to flame spread or to deterioration caused by fungi, insects, or marine bores.
- B. Reference Standards:
 - 1. American Wood Protection Association:

1.3 SUBMITTALS

- A. Informational Submittals:
 - 1. Certificate: Certificate of pressure treatment showing compliance with specification requirements and including information required under IBC Section 2303.1.8.1, 'Identification'.

PART 2 - PRODUCTS**2.1 SYSTEMS**

- A. Manufacturers:
 - 1. Type One Acceptable Manufacturers:
 - a. Arch Wood Protection Inc, Atlanta, GA www.wolmanizedwood.com.
 - b. Hoover Treated Wood Products, Thomson, GA www.frtw.com.
 - c. Osmose Inc, Griffin, GA www.osmose.com.
 - d. U S Borax Inc, Valencia, CA www.borax.com/wood.
 - e. Viance LLC, Charlotte, NC www.treatedwood.com.
 - f. Equal as approved by Architect before bidding. See Section 01 6200.
- B. Performance:
 - 1. Framing lumber grade and species shall be as specified in Section 06 1100 for particular use.
 - 2. Interior Wood In Contact With Concrete or Masonry:

- a. Preservatives:
 - 1) Disodium octoborate tetrahydrate (DOT / SBX) meeting requirements of AWPA U1 and with retention of **0.25 lbs per cu ft (4 kg per cu meter)**.
 - 2) Zinc borate meeting requirements of AWPA U1 and with retention of **0.17 lbs per cu ft (2.7 kg per cu meter)**.
 - 3) CCA-C (47.5 percent chromium trioxide, 18.5 percent copper oxide and 34 percent arsenic pentoxide) by Koppers Performance Chemicals, Griffin, Georgia, <http://www.koppersperformancechemicals.com/> (0.25 lb/cu ft minimum retention).
 - 4) DURA-GUARD by Hoover Treated Wood Products, Thomson, GA www.frtw.com (.40 lb/cu ft minimum retention).
- b. Lumber: Treat in accordance with AWPA U1.

PART 3 - EXECUTION: Not Used**END OF SECTION**

SECTION 06 1011

WOOD FASTENINGS

PART 1 - GENERAL

1.1 SUMMARY

- A. Includes But Not Limited To:
 - 1. Quality of wood fastening methods and materials used for Rough Carpentry unless specified otherwise.
- B. Related Requirements:
 - 1. Section 05 0523: 'Metal Fastenings' for Quality of bolts used for Rough Carpentry.
 - 2. Furnishing and installing of other fasteners are specified in individual Sections where installed.

1.2 REFERENCES

- A. Reference Standards;
 - 1. ASTM International:
 - a. ASTM A153/A153M-16a, 'Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware'.
 - b. ASTM D3498-03(2011), 'Standard Specification for Adhesives for Field-Gluing Plywood to Lumber Framing for Floor Systems'.
 - c. ASTM F1667-17, 'Standard Specification for Driven Fasteners: Nails, Spikes, and Staples'.

PART 2 - PRODUCTS

2.1 MANUFACTURED UNITS

- A. Description:
 - 1. Nail Terminology:
 - a. When following nail terms are used in relation to this Project, following lengths and diameters will be understood. Refer to nails of other dimensions by actual length and diameter, not by one of listed terms:

Nail Term	Length	Diameter	Length	Diameter
8d Box	2-1/2 inches	0.113 inch	63.5 mm	2.827 mm
8d Common	2-1/2 inches	0.131 inch	63.5 mm	3.389 mm
10d Box	3 inches	0.128 inch	76.2 mm	3.251 mm
10d Common	3 inches	0.148 inch	76.2 mm	3.759 mm
16d Box	3-1/2 inches	0.135 inch	88.9 mm	3.411 mm
16d Sinker	3-1/4 inches	0.148 inch	82.6 mm	3.759 mm
16d Common	3-1/2 inches	0.162 inch	88.9 mm	4.115 mm

- B. Materials:
 - 1. Wood fastener list:
 - a. Provide VMR Suppliers with wood fastener list.
 - 2. Fasteners:
 - a. General:
 - 1) Fasteners for preservative treated and fire-retardant-treated wood shall be of hot dipped zinc-coated galvanized steel, stainless steel, silicon bronzed, or copper. Coating weights for zinc-coated fasteners shall be in accordance with ASTM A153/A153M.
 - b. Nails:

- 1) Meet requirements of ASTM F1667.
- 2) Unless noted otherwise, nails listed on Drawings or in Specifications shall be common nail diameter, except 16d nails, which shall be box diameter.
- c. Wood Screws:
 - 1) SDS Screws:
 - a) Category Four Approved Products. See Section 01 6200 for definitions of categories.
 - (1) SDS Screws by Simpson Strong Tie Co, Dublin, CA www.strongtie.com.
 - 2) All Other: Standard type and make for job requirements.
 - 2) Powder-Actuated Fasteners:
 - 1) Type One Quality Standard: Hilti X-DNI 62P8.
 - 2) Manufacturers:
 - a) Hilti, Tulsa, OK www.us.hilti.com.
 - b) Redhead Division of ITW, Wood Dale, IL www.itw-redhead.com and Markham, ON www.itwconstruction.ca.
 - c) Equals as approved by Architect through shop drawing submittal before installation. See Section 01 6200.
3. Adhesives:
 - a. Construction Mastics:
 - 1) Meet requirements of 'APA-The Engineered Wood Association' Specification AFG-01 or ASTM D3498.
 - 2) Use phenol-resorcinol type for use on pressure treated wood products.
4. Framing Anchors:
 - a. Framing anchors and associated fasteners in contact with preservative hot dipped zinc-coated galvanized steel or stainless steel. Do not use stainless steel items with galvanized items.
 - b. Type Two Acceptable Products:
 - 1) KC Metals Inc, San Jose, CA www.kcmetals.com.
 - 2) Simpson Strong Tie Co, Dublin, CA www.strongtie.com.
 - 3) United Steel Products Co Inc (USP), Montgomery, MN www.uspconnectors.com.
 - 4) Equals as approved by Architect through shop drawing submittal before installation. See Section 01 6200.

PART 3 - EXECUTION

3.1 ERECTION

- A. Secure one Manufacturer approved fastener in each hole of framing anchor that bears on framing member unless approved otherwise in writing by Architect.
- B. Provide washers with bolt heads and with nuts bearing on wood.

END OF SECTION

SECTION 06 1100**WOOD FRAMING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install wood framing and blocking as described in Contract Documents.
- B. Products Installed But Not Furnished Under This Section:
 - 1. Miscellaneous structural steel elements.
 - 2. Roof Flue Holes.
- C. Related Requirements:
 - 1. Section 06 0573: 'Preservative Wood Treatment' for quality of preservative wood treatment.
 - 2. Sections under 06 4000 Heading: 'Architectural Woodwork' for wall blocking requirements.

1.2 REFERENCES

- A. Association Publications:
 - 1. American Lumber Standard Committee (ALSC) (Maintains NIST standard):
 - a. Voluntary Product Standard:
 - 1) PS 20-15, 'American Softwood Lumber Standard'.
 - 2. National Institute of Standards and Technology (NIST), U. S. Department of Commerce:
 - a. Voluntary Product Standard DOC PS 20-15, 'American Softwood Lumber Standard'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 - 1. Participate in MANDATORY pre-installation conference held jointly with Section 06 1636.
 - a. Schedule pre-installation conference immediately before beginning framing work.
 - b. In addition to agenda items specified in Section 01 3100, review following:
 - 1) Equipment and gypsum board blocking in wood framed walls.
 - 2) Rough opening.
 - 3) Nails and nailing requirements.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Protect lumber and sheathing and keep under cover in transit and at job site.
 - 2. Do not deliver material unduly long before it is required.
- B. Storage And Handling Requirements:
 - 1. Store lumber and sheathing on level racks and keep free of ground to avoid warping.
 - 2. Stack to insure proper ventilation and drainage.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Dimension Lumber:
 - 1. Design Criteria:
 - a. Meet requirements of PS 20 and National Grading Rules for softwood dimension lumber.
 - b. Bear grade stamp of WWPA, SPIB, or other association recognized by American Lumber Standards Committee identifying species of lumber by grade mark or by Certificate of Inspection.
 - c. Lumber **2 inches (50 mm)** or less in nominal thickness shall not exceed 19 percent in moisture content at time of fabrication and installation and be stamped 'S-DRY', 'K-D', or 'MC15'.
 - d. Preservative Treated Plates / Sills:
 - 1) **2x4 (38 mm by 64 mm)**: Standard and better Douglas Fir, Southern Pine, or HemFir, or StrandGuard by iLevel by Weyerhaeuser Boise, ID www.ilevel.com. (LSL 1.3 E)
 - 2) **2x6 (38 mm by 140 mm)** And Wider: No. 2 or or MSR 1650f - 1.5e Douglas Fir, Southern Pine, HemFir, or StrandGuard by iLevel by Weyerhaeuser, Boise, ID www.ilevel.com. (LSL 1.3 E).
- B. Posts, Beams, And Timbers **5 Inches by 5 Inches (125 mm by 125 mm)** And Larger:
 - 1. Design Criteria:
 - a. No. 1 or better Douglas Fir or Southern Pine.
- C. Lumber Ledgers:
 - 1. Design Criteria:
 - a. No. 2 Douglas Fir-Larch, or Southern Pine.
- D. See Contract Drawings for additional requirements.

2.2 ACCESSORIES

- A. Blocking:
 - 1. Sound lumber without splits, warps, wane, loose knots, or knots larger than **1/2 inch (13 mm)**.
- B. Furring Strips:
 - 1. Utility or better.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General:
 - 1. Use preservative treated wood for wood members in contact with concrete or masonry, including wall, sill, and ledger plates, door and window subframes and bucks, etc.
- B. Interface With Other Work:
 - 1. Coordinate with other Sections for location of blocking required for installation of equipment and building specialties. Do not allow installation of gypsum board until required blocking is in place.
 - 2. Where manufactured items are to be installed in framing, provide rough openings of dimensions within tolerances required by manufacturers of such items. Confirm dimensions where not shown on Contract Drawings.
- C. Tolerances:
 - 1. Walls:

- a. 1/4 inch (6 mm) in 20 feet (6 meters), non-cumulative in length of wall.
- b. 1/8 inch (3 mm) in 10 feet (3 meters) with 1/4 inch (6 mm) maximum in height of wall.
- c. Distances between parallel walls shall be 1/4 inch (6 mm) maximum along length and height of wall.

D. Floors:

- 1. Place with crown side up.
- 2. Provide accurately fitted header and trimmer joists of same size as regular joists around floor openings, unless detailed otherwise, and support by steel joist hangers.
- 3. Double joists under partitions that parallel run of joists.

E. Walls:

- 1. Openings: Single, bearing stud supporting header and one adjacent (king) stud continuous between top and bottom plates, unless shown otherwise.
- 2. Corners And Partition Intersections: Triple studs.
- 3. Top Plates In Bearing Partitions: Doubled or tripled and lapped. Stagger joints at least 48 inches (1 200 mm).
- 4. Stud Walls To Masonry. Use one of the following methods:
 - a. Connect with 1/2 inch (13 mm) machine bolts 6 inches (150 mm) from top, 6 inches (150 mm) from bottom, and 48 inches (1 200 mm) maximum on center. Use three bolts minimum in height of 6 foot (1 800 mm) or higher wall.
 - b. Secure wood to masonry using continuous 1/4 inch (6 mm) minimum bead of construction adhesive and powder actuated fasteners installed at 32 inches (800 mm) on center minimum.
- 5. Firestops:
 - a. Horizontal or vertical concealed spaces in walls, light coves, soffits, drop ceilings, and other features over 10 feet (3 000 mm) in length or height, and at stairs, ceiling levels, floor levels, and other junctures of horizontal to vertical concealed spaces.
 - b. Within concealed spaces of exterior wall finishes and exterior architectural elements, such as trims, cornices or projections, at maximum intervals of 20 feet (6 000 mm), length or height.
- 6. Sill Plates:
 - a. Shear Walls And Bearing Walls:
 - 1) Provide specified anchor 12 inches (300 mm) maximum and 4 inches (100 mm) minimum from each end of each plate.
 - 2) Shear Walls: Fasten with anchor bolts embedded in concrete or with screw anchors.
 - 3) Bearing Walls: Fasten with anchor bolts embedded in concrete, or with screw anchors or expansion bolts in drilled holes.
 - b. Non-Structural Walls: Fasten with powder actuated fasteners.
 - c. In addition to requirements of paragraphs 'a' and 'b' above, set sill plates of interior walls measuring less than 36 inches (900 mm) in length in solid bed of specified construction adhesive, except where sill sealer is used.
 - d. Install specified seal sealer under sill plates of exterior walls of main building and of acoustically insulated interior walls.
- 7. Posts And Columns:
 - a. Unless shown otherwise, nail members of multiple member columns together with 16d at 6 inches (150 mm) on center from each side.
 - b. Wood shims are not acceptable under ends.
 - c. Do not notch framing members unless specifically shown in Drawing detail.
- 8. Nailing:
 - a. Stud to plate (coordinate with Contract Drawings):

2 by 4 inch nominal	38 by 89 mm	End nail, two 16d OR toe nail, four 8d
2 by 6 inch nominal	38 by 140 mm	End nail, three 16d OR toe nail, four 8d
2 by 8 inch nominal	38 by 184 mm	End nail, four 16d OR toe nail, six 8d
2 by 10 inch nominal	38 by 235 mm	End nail, five 16d OR toe nail, six 8d
1-3/4 by 5-1/2 inch LVL	44 by 140 mm LVL	End nail, three 16d OR toe nail, four 8d
1-3/4 by 7-1/4 inch LVL	44 by 184 mm LVL	End nail, four 16d OR toe nail, six 8d
1-3/4 by 9-1/4 inch LVL	44 by 235 mm LVL	End nail, five 16d OR toe nail, six 8d

1-3/4 by 11-1/4 inch LVL	44 by 286 mm LVL	End nail, six 16d OR toe nail eight 8d
--------------------------	------------------	--

- b. Top plates: Spiked together, 16d, 16 inches (400 mm) on center.
 - c. Top plates: Laps, lap members 48 inches (1200 mm) minimum and nail with 16d nails 4 inches (100 mm) on center
 - d. Top plates: Intersections, three 16d.
 - e. Backing And Blocking: Three 8d, each end.
 - f. Corner studs and angles: 16d, 16 inches (400 mm) on center.
- F. Roof And Ceiling Framing:
- 1. Place with crown side up at 16 inches (400 mm) on center unless noted otherwise.
 - 2. Install structural blocking and bridging as necessary and as described in Contract Documents.
 - 3. Special Requirements:
 - a. Roof And Ceiling Joists: Lap joists 4 inches (100 mm) minimum and secure with code approved framing anchors.
 - 4. Secure headers and header backing to structure as described in Contract Documents.
- G. Accessory / Equipment Mounting And Gypsum Board Back Blocking (nailers) for Wood Framing):
- 1. Furnish and install blocking in wood framing required for hardware, specialties, equipment, accessories, and mechanical and electrical items, etc.
 - 2. Furnish and install back blocking in wood framing required for joints in gypsum wallboard.
 - a. Install back blocking between I-joist framing members with equivalent of Simpson Z2 clips attached with four 10d x 1-1/2 inches (38 mm) nails at each end, two into 'I' joist and two into blocking.
 - b. Attach back blocking at trusses, stick framing, or walls with two 10d nails in each end of each piece of blocking.
- H. Accessory / Equipment Mounting And Standing & Running Trim Blocking (nailers) for Metal Framing:
- 1. Furnish and install blocking in wood framing required for hardware, specialties, equipment, accessories, and mechanical and electrical items, etc.
 - 2. Attach blocking not installed with clips with two fasteners in each end of each piece of blocking.
- I. Furring Strips:
- 1. On Wood or Steel: Nail or screw as required to secure firmly.
 - a. Ceiling:
 - 1) Attach furring strips to the underside of structural elements with #8 wood screws, of length to penetrate wood framing 1 inch (25 mm) minimum.
 - 2. On Concrete or Masonry:
 - a. Back up furring strips on exterior walls or walls in contact with earth with 15 lb (6.8 kg) felt strip.
 - b. Nail at 12 inches (300 mm) on center maximum.

END OF SECTION

SECTION 06 2001**COMMON FINISH CARPENTRY REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install sealants required for items installed under this Section, as described in Contract Documents.

- B. Products Installed But Not Furnished Under This Section:
 - 1. Architectural Woodwork.
 - 2. Casings, stops, handrails, and jambs.
 - 3. Miscellaneous Wood Trim.
 - 4. Selected Building Specialties.
 - 5. Selected Equipment.
 - 6. Wood Trim at ceilings.
 - 7. Miscellaneous as specified elsewhere.

- C. Related Requirements:
 - 1. Section 06 1100: 'Wood Framing' for furring and blocking.
 - 2. Section 06 2210: 'Miscellaneous Wood Trim'.
 - a. Wood Trim.
 - b. Section 06 4512: 'Architectural Woodwork Wood Trim'.
 - 3. Section 07 9213: 'Elastomeric Joint Sealants' for quality of sealants, submittal and installation requirements.
 - 4. Section 08 3110: 'Access Doors And Panels' for furnishing of Factory Manufactured Access Doors.
 - 5. Sections under 09 9000 heading: Back priming of work to be installed against concrete or masonry or subjected to moisture, and finishing of finish carpentry and architectural woodwork.
 - 6. Sections in Division 10: Furnishing of Specialties.

1.2 REFERENCES

- A. Association Publications:
 - 1. Architectural Woodwork Institute / Architectural Woodwork Manufacturers Association of Canada / Woodwork Institute, 46179 Westlake Drive, Suite 120, Potomac Falls, VA www.awinet.org.
 - a. Architectural Woodwork Standards (AWS), 2nd Edition, 2014.

- B. Definitions:
 - 1. Grade: Unless otherwise noted, this term means Grade rules for Economy, Custom, and/or Premium Grade:
 - a. Economy Grade: The lowest acceptable grade in both material and workmanship requirements, and is for work where price outweighs quality considerations.
 - b. Custom Grade: Typically specified for and adequately covers most high-quality architectural woodwork, providing a well-defined degree of control over a project's quality of materials, workmanship, or installation.
 - c. Premium Grade: The highest Grade available in both material and workmanship where the highest level of quality, materials, workmanship, and installation is required.

- C. Reference Standards:

PART 2 - PRODUCTS

2.1 MATERIALS

A. Manufacturers:

1. Manufacturer Contact List:
 - a. Blum Inc, Stanley, NC www.blum.com.
 - b. Bommer Industries, Landrum, SC www.bommer.com.
 - c. CompX National, Mauldin, SC www.nclnet.com.
 - d. Dow Chemical, Midland, MI www.dow.com.
 - e. Flynn & Enslow, San Francisco, CA www.flynnenslow.com.
 - f. Grass America Inc, Kernersville, NC www.grassusa.com.
 - g. Hafele America Co., Archdale, NC hafele.com.
 - h. Hillside Wire Cloth Co., Inc., Bloomfield, NJ www.hillsidewirecloth.com.
 - i. Ives, Indianapolis, IN www.iveshardware.com.
 - j. Knappe & Vogt, Grand Rapids, MI www.knappeandvogt.com or Knappe & Vogt Canada, Mississauga, ON (905) 676-8972.
 - k. Olympus Lock Co, Seattle, WA www.olympus-lock.com.
 - l. Owens Corning, Toledo, OH www.owens-corning.com.
 - m. Salice America Inc, Charlotte, NC www.saliceamerica.com.
 - n. SOSS Door Hardware (Division of Universal Industrial Products Company) Pioneer OH www.soss.com.
 - o. Stanley, New Britain, CT www.stanleyhardware.com or Oakville, ON (800) 441-1759.
 - p. TWP Inc., Berkley, CA www.twpinc.com.
 - q. Wire Cloth Manufacturers Inc., Mine Hill, NJ www.wireclothman.com.

B. Glue: Waterproof and of best quality.

PART 3 - EXECUTION

3.1 EXAMINATION

A. Verification Of Conditions:

1. Verify walls, ceilings, floors, and openings are plumb, straight, in-line, and square before installing Architectural Woodwork.
2. Report conditions that are not in compliance to Architect before starting installation.

3.2 PREPARATION

A. Surface Preparation:

1. Install Architectural Woodwork after wall and ceiling painting is completed in areas where Architectural Woodwork is to be installed.

B. Items Installed But Not Furnished Under This Section: Install in accordance with requirements specified in Section furnishing item.

3.3 INSTALLATION

A. Special Techniques:

1. AWS Custom Grade is minimum acceptable standard, except where explicitly specified otherwise, for installation of architectural woodwork.

B. General Architectural Woodwork Installation:

1. Fabricate work in accordance with measurements taken on Project site.

2. Scribe, miter, and join accurately and neatly to conform to details.
 3. Exposed surfaces shall be machine sanded, ready for finishing.
 4. Allow for free movement of panels.
 5. Countersink nails. Countersink screws and plug those exposed to view.
 6. Attach custom casework as specified in Sections under 06 4000 Heading: 'Furnishing of Architectural Woodwork' to wall blocking with #10 x 3 inch (76 mm) minimum Cabinet Screws. Attach wall cabinets with screws equally spaced horizontally not to exceed 12 inches (305 mm) O.C. with 3 inch (76 mm) maximum spacing at cabinet edges.
- C. Items Installed But Not Furnished Under This Section: Install in accordance with requirements specified in Section furnishing item.

END OF SECTION

BLANK PAGE

SECTION 06 2024**DOOR, FRAME, AND FINISH HARDWARE INSTALLATION****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install sealants for caulking door frames as described in Contract Documents.
 - 2. Furnish and install insulation in doorframes as described in Contract Documents.

- B. Products Installed But Not Furnished Under This Section:
 - 1. Flush wood doors.
 - 2. Hollow metal door frames.
 - 3. Finish hardware.

- C. Related Requirements:
 - 1. Divisions under 04 0000 heading: Grouting of frames installed in masonry walls.
 - 2. Section 08 1416: 'Flush Wood Doors'.
 - 3. Section 07 9213: 'Elastomeric Joint Sealants' for quality of sealants.
 - 4. Sections under 08 1000 heading: Furnishing of doors and metal frames.
 - 5. Sections under 08 7000 heading: Furnishing of finish hardware.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference.
 - 1. Participate in pre-installation conference.
 - 2. In addition to agenda items specified in Section 01 3100, review following:
 - a. Schedule conference after hardware has been delivered to site and organized into hardware groups by door, but before installation of hardware.
 - b. Check for appropriate blocking and for correct hardware models and fasteners for substrates.
 - c. Review submittals and set of Manufacturer's installation, adjustment, and maintenance instructions submitted under Section 08 7101.
 - d. Review use of crowbar or other prying devices are not permitted to be used to set door frame into wall opening.

1.3 SUBMITTALS

- A. Informational Submittals:
 - 1. Installer Report:
 - a. Report verifying correct operation and adjustment of installed hardware.
 - 2. Special Procedure Submittals:
 - a. Copy of 'Installation Guide for Doors & Hardware' by Door & Hardware Institute. Guide may be obtained from Door and Hardware Institute (DHI).

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Wood Doors:
 - a. Do not have doors delivered to building site until after plaster, cement, and taping compound are dry.

- b. If doors are to be stored at job-site for more than one week, seal top and bottom edges if not factory sealed.
 2. Metal Frames:
 - a. Examine door frames and note damage upon acceptance.
- B. Storage And Handling Requirements:
1. Wood Doors:
 - a. Store flat on a level surface in a dry, well ventilated building.
 - 1) Cover to keep clean but allow air circulation
 - b. Handle with clean gloves and do not drag doors across one another or across other surfaces.
 - c. Do not subject doors to abnormal heat, dryness, or humidity or sudden changes therein
 - 1) Condition doors to average prevailing humidity of locality before hanging.
 2. Metal Frames:
 - a. Protect metal frames from damage before and during installation.

PART 2 - PRODUCTS: Not Used

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Hollow Metal Frames:
1. Site Tolerances:
 - a. Squareness: **1/16 inch (1.6 mm)** from top edge to opposite top edge.
 - b. Plumbness: **1/16 inch (1.6 mm)** from top of jamb to bottom of jamb.
 - c. Alignment: **1/16 inch (1.6 mm)** from plane of left side face of jamb to right side face of jamb.
 - d. Twist: **1/16 inch (1.6 mm)** across throat of jamb plane measured across each face to plane of opposite jamb throat.
 - e. Finished Clearance Between Door And Frame:
 - 1) **1/16 inch (1.6 mm)** at head and hinge jamb plus **1/16 inch (1.6 mm)** maximum
 - 2) **1/8 inch (3 mm)** at strike jamb plus or minus **1/16 inch (1.6 mm)** maximum.
 - 3) **1/2 inch (12.7 mm)** to top of finished floor surface or **1/4 inch (6 mm)** to top of threshold, plus or minus **1/16 inch (1.6 mm)** maximum.
 2. Set frame in location and level head.
 - a. Use of crowbar or other prying device to set door frame into wall opening will damage door frames and are not permitted to be used.
 3. Equalize with adjustable floor anchor.
 4. Set spreaders and fasten jambs to floor and wall.
 - a. Wood spreaders shall be square, fabricated from lumber one inch minimum thick, be same length as door opening at header, and same depth as frame.
 - b. Cut notches for frame stops.
 - c. Do not remove spreaders until frames are permanently anchored in wall.
 - d. Use one spreader at base of frame and another at strike level.
 - e. Do not use temporary spreaders welded to base of jambs during installation of frame.
 5. Fill gap between frame and framing with urethane foam or tightly-packed fiberglass insulation. If urethane foam is used, foam interior of frames before installing frame. Trim excess before installation of frame.
 6. Caulking:
 - a. Caulk around both sides of frames of doors receiving acoustical seals with specified sealant.
 - b. Caulk around both sides of frames installed in exposed masonry walls with specified sealant.
- B. Doors:
1. When Project is completed, doors shall not bind, stick, or be mounted so as to cause future hardware difficulties.

2. Do not impair utility or structural strength of door in fitting of door, applying hardware, or cutting and altering door louvers, panels, or other special details.
- C. Hardware:
1. General:
 - a. Install using set of Manufacturer's installation, adjustment, and maintenance instructions submitted with hardware under Section 08 7101. Follow as closely as possible.
 - b. Mount closers on jamb stop side of door in parallel arm configuration where it is physically possible to do so and not damage or hinder operation of door or closer.
 2. Hardware for Wood Doors:
 - a. If doors are not factory-machined, use hardware templates furnished by Hardware Manufacturer when mounting hardware.
 - b. Set hinges flush with edge surface. Be sure that hinges are set in a straight line to prevent distortion.
 - c. Mount door latches high in strike plate opening so when door later settles, latch will not bind.

3.2 FIELD QUALITY CONTROL

- A. Field Tests:
1. Arrange to have keys brought to Project site and, in meeting attended by local representatives and Architect, test every new key and locking mechanism.
- B. Non-Conforming Work: Non-conforming work as covered in the General Conditions applies, but is not limited to the following:
1. Correct any work found defective or not complying with contract document requirements at no additional cost to the Owner.
 2. Door frames:
 - a. Door frames damaged by use of crowbar or other prying devices to set door frames shall be repaired or replaced at no additional cost to Owner.

3.3 CLOSEOUT ACTIVITIES

- A. Instruction of Owner:
1. Using Owner's Operations And Maintenance Manual, explain keying systems at same time keys and locking mechanisms are tested.
- B. Key Delivery:
1. Immediately before Final Acceptance Meeting, turn change keys over to Owner properly organized, tagged, and placed in existing key cabinet.

END OF SECTION

BLANK PAGE

SECTION 06 2210**MISCELLANEOUS WOOD TRIM****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Furnish and install wood trim not specified elsewhere as described in Contract Documents.
 2. Section 06 4512: 'Architectural Woodwork Wood Trim'.

1.2 REFERENCES

- A. Association Publications:
1. Architectural Woodwork Institute / Architectural Woodwork Manufacturers Association of Canada / Woodwork Institute, 46179 Westlake Drive, Suite 120, Potomac Falls, VA www.awinet.org.
 - a. Architectural Woodwork Standards (AWS), 2nd Edition, 2014.
- B. Definitions:
1. Grade: Unless otherwise noted, this term means Grade rules for Economy, Custom, and/or Premium Grade:
 - a. Custom Grade: Typically specified for and adequately covers most high-quality architectural woodwork, providing a well-defined degree of control over a project's quality of materials, workmanship, or installation.
 2. Plain-Sawn: A hardwood figure developed by sawing a log lengthwise at a tangent to the annual growth rings. It appears as U-shaped or straight markings in the board's face.

1.3 SUBMITTALS

- A. Action Submittals:
1. Samples:
 - a. Interior Hardwood for Transparent Finish:
 - 1) Before performing work of this Section, prepare Control Sample, to match sample available from Owner, to be used as finishing standard for interior clear finished hardwood as specified in Section 09 9324.
 - 2) Design Criteria:
 - a) Provide **8 inch by 10 inch (200 mm by 255 mm)** sample of Red Oak to match Owner provided stain color selected for Project.
 - b) Control Sample will be used as performance standard for evaluating finish provided.
- B. Informational Submittals:
1. Source Quality Control Submittals:
 - a. Samples:
 - 1) Interior Hardwood for Transparent Finish:
 - a) Owner will provide Control Sample for finish.

1.4 WARRANTY

- A. Manufacturer Extended Warranty:
1. Approved Fabricator's written guarantee that all Goods and Services will be free from defects in materials and workmanship for a period of five (5) years from date of substantial completion.

PART 2 - PRODUCTS**2.1 MATERIALS**

- A. Design Criteria:
 - 1. General:
 - a. Meet requirements of Section 06 4001 for general standards for materials and fabrication of Architectural Woodwork.
 - 2. Clear Finished Hardwood:
 - a. Match materials specified in Section 06 4512.
 - b. Match finish specified in Section 06 4512 and match Owner selected sample as specified in Section 09 9324.
 - 3. Clear Finished Paneling: Match materials specified in Sections 06 4216.
 - 4. Opaque Finished Hardwood: Hardwood allowed by AWS Custom Grade.
 - 5. Opaque Finished Softwood: Solid stock Pine, C or better, S4S.

2.2 SOURCE QUALITY CONTROL

- A. Inspections:
 - 1. Clear Finished Hardwood:
 - a. Color matches Owner provided sample specified in Section 09 9324.

PART 3 - EXECUTION: Not Used**END OF SECTION**

SECTION 06 4001**COMMON ARCHITECTURAL WOODWORK REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. General standards for materials and fabrication of Architectural Woodwork and for hardware associated with Architectural Woodwork.
- B. Related Requirements:
 - 1. Section 06 1100: 'Wood Framing' for furring and blocking.
 - 2. Section 06 2001: 'Common Finish Carpentry Requirements' for Installation.
 - 3. Section 06 2210: 'Miscellaneous Wood Trim'.
 - 4. Section 06 4512: 'Architectural Woodwork Wood Trim'.
 - 5. Section 09 9324: 'Interior Clear-Finished Hardwood' for filling of nail holes and finishing.

1.2 REFERENCES

- A. Association Publications:
 - 1. Architectural Woodwork Institute / Architectural Woodwork Manufacturers Association of Canada / Woodwork Institute, 46179 Westlake Drive, Suite 120, Potomac Falls, VA www.awinet.org.
 - a. Architectural Woodwork Standards (AWS), 2nd Edition, 2014.
- B. Definitions:
 - 1. Grade: Unless otherwise noted, this term means Grade rules for Economy, Custom, and/or Premium Grade:
 - a. Custom Grade: Typically specified for and adequately covers most high-quality architectural woodwork, providing a well-defined degree of control over a project's quality of materials, workmanship, or installation.

1.3 QUALITY ASSURANCE

- A. Qualifications: Requirements of Section 01 4301 applies, but not limited to following:
 - 1. Fabricator:
 - a. Fabricator Firm specializing in performing work of this section.
 - 1) Firm experience in supplying products indicated for this Project.
 - 2) Firm with sufficient production capacity to produce required units.
 - 3) Firm will comply with specifications and Contract Documents for this Project.
 - 4) Minimum five (5) years experience in Woodwork installations.
 - 5) Minimum five (5) satisfactorily completed installations in past three (3) years of projects similar in size, scope, and installation procedures required for this project before bidding.
 - b. Upon request by Architect or Owner, submit documentation.

1.4 DELIVERY, HANDLING, AND STORAGE

- A. Delivery And Acceptance Requirements:
 - 1. Assemble architectural woodwork at Architectural Woodwork Fabricator's plant and deliver ready for erection insofar as possible.
 - 2. Protect architectural woodwork from moisture and damage while in transit to job site.
 - 3. Report damaged materials received within two (2) days from delivery at project site.

B. Storage And Handling Requirements:

1. Unload and store in place where it will be protected from moisture and damage and convenient to use.

PART 2 - PRODUCTS**2.1 FABRICATORS**

A. Approved Fabricators. See Section 01 4301:

1. Meet Quality Assurance Fabricator Qualifications as specified in Part 1 of this specification.

2.2 ASSEMBLIES

A. Design Criteria:

1. General:
 - a. AWS Custom Grade is minimum acceptable standard, except where explicitly specified otherwise, for materials, construction, and installation of architectural woodwork.
2. Materials:
 - a. Lumber:
 - 1) Grade:
 - a) No defects in boards smaller than 600 sq in (3 871 sq cm).
 - b) One defect per additional 150 sq inches (968 sq cm) in larger boards.
 - c) Select pieces for uniformity of grain and color on exposed faces and edges.
 - d) No mineral grains accepted.
 - 2) Allowable Defects:
 - a) Tight knots not exceeding 1/8 inch (3 mm) in diameter. No loose knots permitted.
 - b) Patches (dutchmen) not apparent after finishing when viewed beyond 18 inches (450 mm).
 - c) Checks or splits not exceeding 1/32 inch by 3 inches (1 mm by 75 mm) and not visible after finishing when viewed beyond 18 inches (450 mm).
 - d) Stains, pitch pockets, streaks, worm holes, and other defects not mentioned are not permitted.
 - e) Normal grain variations, such as cats eye, bird's eye, burl, curl, and cross grain are not considered defects.
 - 3) Use maximum lengths possible, but not required to exceed 10 feet (3 meters) without joints. No joints shall occur closer than 72 inches (1 800 mm) in straight runs exceeding 18 feet (3 600 mm). Runs between 18 feet (3 600 mm) and 10 feet (3 meters) may have no more than one joint. No joints shall occur within 72 inches (1 800 mm) of outside corners nor within 18 inches (450 mm) of inside corners.
 - 4) Moisture content shall be six (6) percent maximum at fabrication. No opening of joints due to shrinkage is acceptable.

B. Fabrication:

1. Follow Architectural Woodwork Standards (AWS) for fabrication of Architectural Woodwork.
2. Tolerances:
 - a. No planer marks (KCPI) allowed. Sand wood members and surfaces with 100 grit or finer.
 - b. Maximum Gap: None allowed.
 - c. Flushness Variation: 0.015 inch (0.4 mm) maximum.
 - d. Sanding Cross Scratches: 1/4 inch (6 mm) maximum.
 - e. Plug screw holes. Screw locations not to be visible beyond 18 inches (450 mm).
3. Fabricate work in accordance with measurements taken on job site.
4. 'Ease' sharp corners and edges of exposed members to promote finishing and protect users from splinters. Radius of 'easing' shall be uniform throughout Project and between 1/32 and 1/16 of an inch (0.8 and 1.6 of a millimeter).
5. Fabricate so veneer grain is vertical.
6. Joints:

- a. Use lumber pieces with similar grain pattern when joining end to end.
- b. Compatibility of grain and color from lumber to panel products is required.
7. Install hardware in accordance with Manufacturer's directions. Leave operating hardware operating smoothly and quietly.
8. Remove or repair damaged surface of or defects in exposed finished surfaces of architectural woodwork to match adjacent similar undamaged surface.

PART 3 - EXECUTION: Not Used

END OF SECTION

BLANK PAGE

SECTION 06 4512**ARCHITECTURAL WOODWORK WOOD TRIM****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Wood trim at walls and ceiling.
 - 2. Chair rails.

- B. Related Requirements:
 - 1. Section 06 1100: 'Wood Framing' for wall blocking required for Wood Trim.
 - 2. Section 06 2001: 'Common Finish Carpentry Requirements':
 - a. Installation of Wood Trim.
 - 3. Section 06 2210: Remaining Wood Trim.
 - 4. Section 06 4001: 'Common Architectural Woodwork Requirements':
 - a. Approved Fabricators.
 - b. General standards for materials and fabrication of Architectural Woodwork.
 - 5. Section 08 1429: Interior Flush Wood Doors.

1.2 REFERENCES

- A. Association Publications:
 - 1. Architectural Woodwork Institute / Architectural Woodwork Manufacturers Association of Canada / Woodwork Institute, 46179 Westlake Drive, Suite 120, Potomac Falls, VA www.awinet.org.
 - a. Architectural Woodwork Standards (AWS), 2nd Edition, 2014.

- B. Definitions:
 - 1. Grade: Unless otherwise noted, this term means Grade rules for Economy, Custom, and/or Premium Grade.
 - a. Custom Grade: Typically specified for and adequately covers most high-quality architectural woodwork, providing a well-defined degree of control over a project's quality of materials, workmanship, or installation.
 - 2. Plain-Sawn: A hardwood figure developed by sawing a log lengthwise at a tangent to the annual growth rings. It appears as U-shaped or straight markings in the board's face.
 - 3. Running Trim: Generally combined in the term "standing and running trim" and refers to random, longer length trims delivered to the jobsite (e.g., baseboard, chair rail, crown molding).

1.3 SUBMITTALS

- A. Action Submittals:
 - 1. Shop Drawings:
 - a. Include materials used, standing and running trim profiles, joint details, and hardware.
 - 2. Samples:
 - a. Interior Hardwood for Transparent Finish:
 - 1) Before performing work of this Section, prepare Control Sample, to match sample available from Owner, to be used as finishing standard for interior clear finished hardwood as specified in Section 09 9324.
 - 2) Design Criteria:
 - a) Provide **8 inch by 10 inch (200 mm by 255 mm)** sample of Red Oak to match Owner provided stain color selected for Project.
 - b) Control Sample will be used as performance standard for evaluating finish provided.

- B. Informational Submittals:
 - 1. Source Quality Control Submittals:
 - a. Samples:
 - 1) Interior Hardwood for Transparent Finish:
 - a) Owner will provide Control Sample for finish.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Manufacturers:
 - 1. Approved Fabricators. See Section 06 4001 for Approved Fabricators.
- B. Performance / Design Criteria: Conform to requirements of Section 06 4001 'Common Architectural Woodwork Requirements'.
 - 1. Glue: Waterproof and of best quality.
 - 2. Factory-finish to match Owner selected sample as specified in Section 09 9324.
- C. Architectural Woodwork Wood Trim:
 - 1. Interior Hardwood For Transparent Finish:
 - a. Design Criteria:
 - 1) Solid wood shall be plain sawn Red Oak.
 - 2) Paneling shall be panel product with plain sliced Red Oak veneer.
 - 3) Finish to match Owner selected sample as specified in Section 09 9324.
 - b. Match existing Project Color Scheme:
 - 1) Control Sample provided by Owner:
 - a) Control Sample will be existing wood item from Project.

2.2 SOURCE QUALITY CONTROL

- A. Inspections:
 - 1. Clear Finished Hardwood:
 - a. Color matches Owner provided sample specified in Section 09 9324.

PART 3 - EXECUTION Not Used

END OF SECTION

DIVISION 07: THERMAL AND MOISTURE PROTECTION

07 2000 THERMAL PROTECTION

07 2116 BLANKET INSULATION

07 6000 FLASHING AND SHEET METAL

07 6310 STEEP SLOPE ROOF FLASHING: Asphalt Shingles

07 9000 JOINT PROTECTION

07 9213 ELASTOMERIC JOINT SEALANTS

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 07 2116**BLANKET INSULATION****PART 1 - GENERAL****1.1 SUMMARY**

A. Includes But Not Limited To:

1. Furnish and install faced thermal and acoustic batt insulation as described in Contract Documents.

B. Related Requirements:

1. Section 06 2024: 'Door, Frame, And Finish Hardware Installation' for furnishing and installing of insulation in hollow metal door frames.

1.2 REFERENCES

A. Reference Standards:

1. ASTM International:
 - a. ASTM C665-17, 'Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing'.

1.3 QUALITY ASSURANCE

A. Regulatory Agency Sustainability Approvals:

1. Insulation shall be manufactured and installed in compliance with International Building Code (IBC) or other applicable building codes.

PART 2 - PRODUCTS**2.1 SYSTEMS**

A. Manufacturers:

1. Insulation:

a. Type One Acceptable Manufacturers:

- 1) Certaineed Corp, Valley Forge, PA www.certainteed.com.
- 2) FiberTEK, Salt Lake City, UT www.fibertekinsulation.com.
- 3) Guardian Fiberglass, Greer, SC www.guardianbp.com.
- 4) Johns Manville, Denver, CO www.jm.com.
- 5) Knauf Fiber Glass, Shelbyville, IN www.knaufusa.com.
- 6) Owens-Corning Fiberglass Corporation, Toledo, OH www.owens-corning.com.
- 7) Thermafiber, Wabash, IL www.thermafiber.com.

b. Equal as approved by Architect before bidding. See Section 01 6200.

B. Materials:

1. Thermal And Acoustic Insulation:

- a. Order insulation by 'R' value rather than 'U' value, rating, or thickness, either 16 or 24 inches (400 or 600 mm) wide according to framing spacing.
- b. Faced Insulation:
 - 1) Kraft faced meeting requirements of ASTM C665, Type II, Class C.
 - 2) Foil faced meeting requirements of ASTM C665, Type III.
 - a) Class A: Exposed insulation.

- b) Class B: Enclosed insulation.
- c. Unfaced Insulation: Meet requirements of ASTM C665, Type I.
 - 1) Support at trussed rafters:
 - a) Provide support at trussed rafters where insulation is not enclosed by structure or drywall.
 - b) Provide stings/wires which run perpendicular to framing and attach at each trussed rafter and to framing at **32 inches (800 mm)** O.C. minimum and where batt ends adjoin each other.
 - or
 - c) Class Two Quality Standard: Simpson Strong Tie IS Insulation Supports with **14 gauge (1.89 mm)** carbon steel, spring wire and mitered tips for **16 inch (400 mm)** O.C. and **24 inch (610 mm)** O.C. spacing.
- d. 'R' Value Required:
 - 1) Acoustically Insulated Ceilings:
 - a) Enclosed Spaces: Fill framed cavity with batt of appropriate thickness.
 - b) Unenclosed Spaces: R-19.
 - c) Unenclosed Spaces above Offices and Restrooms: R-38.
 - 2) Thermally Insulated Ceilings / Roof:
 - a) R-38 Standard.
 - 3) Wood Wall Stud Framing:

R-11	3-1/2 inches deep	89 mm deep
------	--------------------------	-------------------

2.2 ACCESSORIES SYSTEMS

- A. Attic Baffles:
 - 1. Design Criteria:
 - a. Baffle can be used with spray foam, loose-fill, fiberglass, or other insulation materials.
 - 2. Type One Acceptable Manufacturers:
 - a. SB24 SmartBaffle by DCI Products, Inc., Clifton Heights, PA www.dciproducts.com.
 - b. Equal as approved by Architect before bidding. See Section 01 6200.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General:
 - 1. Leave no gaps in insulation envelope.
 - 2. If two layers of insulation are used to attain required 'R' value, only layer towards interior of building shall have facing.
 - 3. Provide minimum clearance around recessed lighting fixtures as approved by local code.
- B. In Framing:
 - 1. Install insulation behind plumbing and wiring, around duct and vent line penetrations, and in similar places.
 - 2. Fit ends of batts snug against top and bottom plates.
 - 3. Fit batts snug against stud framing at each side.
 - 4. Where insulation is not enclosed by structure or drywall, support in place with wire or other suitable material as approved by Architect before bid.
 - 5. Used face insulation at ceilings and staple installation tabs to bottom chord of existing trusses.

END OF SECTION

SECTION 07 6310**STEEP SLOPE ROOF FLASHING: Asphalt Shingles****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Roof flashing including:
 - a. Pipe flashing for vent piping.
- B. Related Requirements:
 - 1. Section 07 9213: 'Elastomeric Joint Sealants' for quality of sealants.
 - 2. Division 22: Plumbing vent piping.

1.2 REFERENCES

- A. Definitions:
 - 1. Base Flashing: That portion of flashing attached to or resting on roof deck to direct flow of water onto the roof covering.
 - 2. Cap Flashing: Material used to cover top edge of base flashings or other flashings to prevent water seepage behind base flashing. Cap flashing overlaps base flashing.
 - 3. Collar: Pre-formed flange placed over vent pipe to seal roof around vent pipe opening. Also called vent sleeve.
 - 4. Drip Edge: Non-corrosive, non-staining material used along eaves and rakes to allow water run-off to drip clear of underlying building.
 - 5. Flange: Metal pan extending up and down roof slope around flashing pieces. Usually at plumbing vents.
 - 6. Flashing: Components used to prevent seepage of water into a building around any intersection or projection in a roof such as vent pipes, adjoining walls, and valleys.
 - 7. Metal Flashing: Roof components made from sheet metal that are used to terminate roofing membrane or other material alongside roof perimeters as well as at roof penetrations.
 - 8. Penetration: Any object that pierces surface of roof.
 - 9. Pipe Boot: Prefabricated flashing piece used to flash around circular pipe penetrations. Also known as a Roof Jack.
 - 10. Roof Jack: Term used to describe a Pipe Boot or Flashing Collar.
 - 11. Valley: Internal angle formed by intersection of two sloping roof planes to provide water runoff.
 - 12. Vent: Any outlet for air that protrudes through roof deck such as pipe or stack. Any device installed on roof, gable or soffit for purpose of ventilating underside of roof deck.
 - 13. Vent Sleeve: See collar.
- B. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A653/A653M-18, 'Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process'.
 - b. ASTM A792/A792M-10(2015), 'Standard Specification for Steel Sheet, 55 % Aluminum-Zinc Alloy-Coated by the Hot-Dip Process'.
 - 2. ASTM International: (specifically referenced for pipe flashing only):
 - a. ASTM B117-18, 'Standard Practice for Operating Salt Spray (Fog) Apparatus'.
 - b. ASTM E283-04(2012), 'Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen'.
 - c. ASTM E330/E330M-14, 'Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference'.

- d. ASTM E331-00(2016), 'Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference'.
- e. ASTM E2140-01(2017), 'Standard Practice for Water Penetration of Metal Roof Panel Systems by Static Water Pressure Head'.

1.3 WARRANTY

- A. Pipe Flashing:
 1. Manufacturer's warranty against defects in materials and workmanship when correctly installed in appropriate application for life of original roofing material from installation or replacement or fifty (50) years whichever is greater.

PART 2 - PRODUCTS

2.1 MATERIALS

2.2 ACCESSORIES

- A. Pipe Flashing For Plumbing Vent Lines metal flues, and HVAC Air Piping:
 1. Description:
 - a. Ultra-pure high consistency molded one hundred (100) percent silicone rubber pipe boot that prevents cracking and splitting for life of roof.
 2. Design Criteria:
 - a. Meet following Tests:
 - 1) ASTM B117 (Salt Spray Test).
 - 2) ASTM E283 (Air Leakage).
 - 3) ASTM E 330 (Uniform Structural Load).
 - 4) ASTM E331 (Water Penetration).
 - 5) ASTM E2140 (Water).
 - b. Material warranty of product for life of roof.
 3. 24 ga (0.635 mm) coated galvanized steel plate.
 4. Minimum 4 inch (100 mm) flashing on each side, 6 inch (150 mm) flashing at top, 3 inch (76 mm) flashing at bottom with nailing slots.
 5. UV stable solid molded PVC compression collar.
 6. Use Ultimate Pipe Flashing for PVC, ABS and IP.
 7. Sizes: 1-1/4 inch (32 mm), 1-1/2 inch (38 mm), 2 inch (50 mm), 3 inch (76 mm), and 4 inch (100 mm).
 8. Slope: Flat to 18/12 pitch.
 9. Flashing Finish: Face coating polyvinylidene Fluoride (PVF₂) Resin-base finish (Kynar 500) for coil coating components containing seventy (70) percent minimum PVF₂ in resin portion of formula. Thermo-cured two coat system consisting of corrosion inhibiting epoxy primer and top coat factory applied over properly pre-treated metal.
 10. Color: Brown (no other color available).
 11. Category Four Approved System Manufacturers. See Section 01 6200 for definitions of Categories:
 - a. Ultimate Pipe Flashing by Lifetime Tool & Building Products LLC, Winchester, VA www.lifetimetool.com (877) 904-1002.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Interface With Other Work:

1. Coordinate with pipe installers for proper size of roof jacks and pipe flashing.
- B. Pipe Flashing:
1. Follow Manufacturer's installation instructions.

END OF SECTION

BLANK PAGE

SECTION 07 9213**ELASTOMERIC JOINT SEALANTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install sealants not specified to be furnished and installed under other Sections.
 - 2. Quality of sealants to be used on Project not specified elsewhere, including submittal, material, and installation requirements.
- B. Related Requirements:
 - 1. Removing existing sealants specified in Sections where work required.
 - 2. Furnishing and installing of sealants is specified in Sections specifying work to receive new sealants.

1.2 REFERENCES

- A. Definitions:
 - 1. Sealant Types and Classifications:
 - a. ASTM Specifications:
 - 1) Type:
 - a) Type S: Single-component sealant.
 - b) Type M: Multi-component sealant.
 - 2) Grade:
 - a) Grade P: Pourable or self-leveling sealant used for horizontal traffic joints.
 - b) Grade NS: Non-sag or gunnable sealant used for vertical and non-traffic joints.
 - 3) Classes: Represent movement capability in percent of joint width.
 - a) Class 100/50: Sealant that, when tested for adhesion or cohesion under cyclic movement shall withstand of at least 100 percent increase and decrease of at least 50 percent of joint width as measured at time of application.
 - b) Class 50: Sealant that, when tested for adhesion or cohesion under cyclic movement shall withstand increase and decrease of at least 50 percent of joint width as measured at time of application.
 - c) Class 25: Sealant that, when tested for adhesion or cohesion under cyclic movement shall withstand increase and decrease of at least 25 percent of joint width as measured at time of application.
 - d) Class 12: Sealant that, when tested for adhesion and cohesion under cyclic movement shall withstand increase and decrease of at least 12 percent of joint width as measured at time of application.
 - 4) Use:
 - a) T (Traffic): Sealant designed for use in joints in pedestrian and vehicular traffic areas such as walkways, plazas, decks and parking garages.
 - b) NT (Non-Traffic): Sealant designed for use in joints in non-traffic areas.
 - c) I (Immersion): Sealant that meets bond requirements when tested by immersion (Immersion rated sealant applications require primer).
 - d) M (Mortar): Sealant that meets bond requirements when tested on mortar specimens.
 - e) G (Glass): Sealant that meets bond requirements when tested on glass specimens.
 - f) A (Aluminum): Sealant that meets bond requirements when tested on aluminum specimens.
 - g) O (Other): Sealant that meets bond requirements when tested on substrates other than standard substrates, being glass, aluminum, mortar.

2. Silicone: Any member of family of polymeric products whose molecular backbone is made up of alternating silicon and oxygen atoms and which has pendant hydrocarbon groups attached to silicon atoms. Used primarily as a sealant. Offers excellent resistance to water and large variations in temperature (minus 100 deg F to + 600 deg F) (minus 73.3 deg C to + 316 deg C).

B. Reference Standards:

1. ASTM International:
 - a. ASTM C920-14a, 'Standard Specification for Elastomeric Joint Sealants'.
 - b. ASTM C1193-16, 'Standard Guide for Use of Joint Sealants'.
 - c. ASTM C1330-18, 'Standard Specification for Cylindrical Sealant Backing for Use with Cold Liquid Applied Sealants'.
 - d. ASTM C1481-12(2017) 'Standard Guide for Use of Joint Sealants with Exterior Insulation & Finish Systems (EIFS)'.
 - e. ASTM D5893/D5893M-16, 'Standard Specification for Cold Applied, Single Component, Chemically Curing Silicone Joint Sealant for Portland Cement Concrete Pavements'.

1.3 ADMINISTRATIVE REQUIREMENTS

A. Scheduling:

1. Schedule work so waterproofing, water repellents and preservative finishes are installed after sealants, unless sealant manufacturer approves otherwise in writing.
2. Ensure sealants are cured before covering with other materials.

1.4 SUBMITTALS

A. Action Submittals:

1. Product Data:
 - a. Manufacturer's specifications and other data needed to prove compliance with the specified requirements.
 - b. Manufacturer's literature for each Product.
 - c. Schedule showing joints requiring sealants. Show also backing and primer to be used.

B. Informational Submittals:

1. Certificates:
 - a. Manufacturer's Certificate:
 - 1) Certify products are suitable for intended use and products meet or exceed specified requirements.
 - 2) Certificate from Manufacturer indicating date of manufacture.
2. Manufacturers' Instructions:
 - a. Manufacturer's installation recommendations for each Product.
 - b. Manufacturer's installation for completing sealant intersections when different materials are joined.
 - c. Manufacturer's installation for removing existing sealants and preparing joints for new sealant.

1.5 QUALITY ASSURANCE

A. Qualifications:

1. Manufacturer: Company specializing in manufacturing products specified in this section with minimum ten (10) years documented experience.
2. Applicator Qualifications:
 - a. Company specializing in performing work of this section.
 - b. Provide if requested, reference of projects with minimum three (3) years documented experience, minimum three (3) successfully completed projects of similar scope and complexity, and approved by manufacturer.

- c. Designate one (1) individual as project foreman who shall be on site at all times during installation.
- B. Preconstruction Testing:
1. Pre-construction testing is not required when sealant manufacturer can furnish data acceptable to Architect based on previous testing for materials matching those of the Work.
- C. Mockups:
1. Provide mockups including sealant and joint accessories to illustrate installation quality and color if requested by Architect or Project Manager.
 - a. Incorporate accepted mockup as part of Work.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery and Acceptance Requirements:
1. Deliver and keep in original containers until ready for use.
 2. Inspect for damage or deteriorated materials.
- B. Storage and Handling Requirements:
1. Handle, store, and apply materials in compliance with applicable regulations and material safety data sheets (MSDS).
 2. Handle to prevent inclusion of foreign matter, damage by water, or breakage.
 3. Store in a cool dry location, but never under 40 deg F (4 deg C) or subjected to sustained temperatures exceeding 90 deg F (32 deg C) or as per Manufacturer's written recommendations.
 4. Do not use sealants that have exceeded shelf life of product.

1.7 FIELD CONDITIONS

- A. Ambient Conditions:
1. Do not install sealant during inclement weather or when such conditions are expected. Allow wet surfaces to dry.
 2. Follow Manufacturer's temperature recommendations for installing sealants.

1.8 WARRANTY

- A. Manufacturer Warranty:
1. Signed warranties against adhesive and cohesive failure of sealant and against infiltration of water and air through sealed joint for period of three (3) years from date of Substantial Completion.
 - a. Manufacturer's standard warranty covering sealant materials.
 - b. Applicator's standard warranty covering workmanship.

PART 2 - PRODUCTS

2.1 SYSTEMS

- A. Manufacturers:
1. Manufacturer Contact List:
 - a. Dow Corning Corp., Midland, MI www.dowcorning.com.
 - b. Franklin International, Inc. Columbus, OH www.titebond.com.
 - c. GE Sealants & Adhesives (see Momentive Performance Materials Inc.).
 - d. Laticrete International Inc., Bethany, CT www.laticrete.com.
 - e. Momentive Performance Materials Inc. (formally GE Sealants & Adhesives), Huntersville, NC www.ge.com/silicones.

- f. Sherwin-Williams, Cleveland, OH www.sherwin-williams.com.
 - g. Sika Corporation, Lyndhurst, NJ www.sikaconstruction.com or Sika Canada Inc, Pointe Claire, QC www.sika.ca.
 - h. Tremco, Beachwood, OH www.tremcosealants.com or Tremco Ltd, Toronto, ON (800) 363-3213.
- B. Materials:
1. Design Criteria:
 - a. Compliance: Meet or exceed requirements of these standards:
 - 1) ASTM C920: Elastomeric joint sealant performance standard.
 - 2) ASTM D5893/D5893M: Silicone Joint Sealant for Concrete Pavements.
 - b. Comply with Manufacturer's ambient condition requirements.
 - c. Sealants must meet Manufacturer's shelf-life requirements.
 - d. Sealants must adhere to and be compatible with specified substrates.
 - e. Sealants shall be stable when exposed to UV, joint movements, and environment prevailing at project location.
 - f. Primers (Concrete, stone, masonry, and other nonporous surfaces typically do not require a primer. Aluminum and other nonporous surfaces except glass require use of a primer. Installer Option to use Adhesion Test to determine if primer is required or use primer called out in related sections):
 - 1) Adhesion Test:
 - a) Apply silicone sealant to small area and perform adhesion test to determine if primer is required to achieve adequate adhesion. If necessary, apply primer at rate and in accordance with Manufacturer's instructions. See 'Field Quality Control' in Part 3 of this specification for Adhesive Test.
 - 2) If Primer required, shall not stain and shall be compatible with substrates.
 - 3) Allow primer to dry before applying sealant.
 2. Sealants At Exterior Building Elements:
 - a. Description:
 - 1) Weathersealing expansion, contraction, perimeter, and other movement joints which may include all or part of the following for project:
 - a) Other joints necessary to seal off building from outside air and moisture.
 - b. Design Criteria:
 - 1) Meet following standards for Sealant:
 - a) ASTM C920: Type S, Grade NS, Class 50 Use NT, M, G, A.
 - 2) Limitations:
 - a) Do not use below-grade applications.
 - b) Do not use on surfaces that are continuously immersed or in contact with water.
 - c) Do not use on wet, damp, frozen or contaminated surfaces.
 - d) Do not use on building materials that bleed oils, plasticizers or solvents, green or partially vulcanized rubber gaskets or tapes.
 - 3) Color:
 - a) Architect to select from Manufacturer's standard colors.
 - b) Match building elements instead of window (do not use white that shows dirt easily).
 - c. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Dow Corning:
 - a) Primer: 1200 Prime Coat.
 - b) Sealant: 791 Silicone Weatherproofing Sealant.
 - 2) Momentive Performance Materials (formerly, GE Sealants & Adhesives):
 - a) Primer: SS4044 Primer.
 - b) Sealant: GE SCS2000 SilPruf Silicone Sealant & Adhesive.
 - 3) Tremco:
 - a) Primer:
 - (1) Metal surface: No. 20 primer.
 - (2) Porous surfaces: No. 23 primer.
 - b) Sealant: Spectrum 1 Silicone Sealant.
 3. Sealants At Exterior Sheet Metal And Miscellaneous:
 - a. Description:

- 1) Weathersealing expansion, contraction, perimeter, and other movement joints which may include all or part of the following for project:
 - a) Flashings.
 - b) Roof vents and flues.
- b. Design Criteria:
 - 1) Meet following standards for Sealant:
 - a) ASTM C920: Type S Grade NS, Class 25 (min) Use NT, M, G, A and O.
 - 2) Limitations:
 - a) Do not use below-grade applications.
 - b) Do not use on surfaces that are continuously immersed or in contact with water.
 - c) Do not use on wet, damp, frozen or contaminated surfaces.
 - d) Do not use on building materials that bleed oils, plasticizers or solvents, green or partially vulcanized rubber gaskets or tapes.
- c. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Dow Corning: 790 Silicone Building Sealant.
 - 2) Momentive Performance Materials (formerly, GE Sealants & Adhesives): GE SCS2350 Silicone Elastomeric Sealant.
 - 3) Tremco: Tremsil 600 Silicone Sealant.
4. General Interior Sealants:
 - a. General:
 - 1) Inside jambs and heads of exterior door frames.
 - 2) Both sides of interior door frames.
 - 3) Miscellaneous gaps between substrates.
 - b. Design Criteria:
 - 1) Meet ASTM C920, Type S, Grade NS, NT, and Class 25 test requirements.
 - 2) 100 percent silicone sealant.
 - c. Non-Paintable Sealant (Installer Option A):
 - 1) Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - a) Dow Corning: Tub, Tile, And Ceramic Silicone Sealant.
 - b) Laticrete: Latasil Silicone Sealant.
 - c) Momentive Performance Materials (formerly, GE Sealants & Adhesives): GE SCS2800 SilGlaze II Silicone Sealant.
 - d) Sherwin Williams: White Lightning Silicone Ultra Low Odor Window and Door Sealant.
 - e) Tremco: Tremsil 200 Silicone Sealant.
 - f) Franklin International: Titebond 2601 (White) 2611 (Clear) 100% Silicone Sealant.
 - d. Paintable Sealant (Installer Option B):
 - 1) Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - a) Momentive Performance Materials (formerly, GE Sealants & Adhesives): GE SCS7000 Paintable Silicone Sealant.

2.2 ACCESSORIES

- A. Bond Breaker Tape:
 1. Pressure sensitive tape as by Sealant Manufacturer to suit application.
 2. Provide tape to prevent adhesion to joint fillers or joint surfaces at back of joint and allow sealant movement.
- B. Joint Backing:
 1. Comply with ASTM C1330.
 2. Flexible closed cell, non-gassing polyurethane or polyolefin rod or bond breaker tape as recommended by Sealant Manufacturer for joints being sealed.
 3. Oversized 25 to 50 percent larger than joint width.
- C. Joint Cleaner:
 1. Non-corrosive and non-staining type as recommended by Sealant Manufacturer, compatible with joint forming materials.
- D. Masking Tape:

1. Non-staining, non-absorbent tape product compatible with joint sealants and adjacent joint surfaces.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification Of Conditions:
1. Examine substrate surfaces and joint openings are ready to receive Work.
 - a. Verify each sealant is compatible for use with joint substrates.
 - b. Verify joint surfaces are clean and dry.
 - c. Ensure concrete surfaces are fully cured.
 2. Sealants provided shall meet Manufacturer's shelf-life requirements.
 3. Notify Architect of unsuitable conditions in writing.
 - a. Do not proceed until unsatisfactory conditions are corrected.
 4. Commencement of Work by installer is considered acceptance of substrate.

3.2 PREPARATION

- A. Surface Preparation:
1. Remove existing joint sealant materials where specified.
 - a. Clean joint surfaces of residual sealant and other contaminates capable of affecting sealant bond to joint surface using manufacturer's recommended joint preparation methods.
 - b. Repair deteriorated or damaged substrates as recommended by Sealant Manufacturer to provide suitable substrate. Allow patching materials to cure.
 2. Surfaces shall be clean, dry, free of dust, oil, grease, dew, frost or incompatible sealers, paints or coatings that may interfere with adhesion. Prepare substrates in accordance with Manufacturer's instructions:
 - a. Porous surfaces: Clean by mechanical methods to expose sound surface free of contamination and laitance followed by blasting with oil-free compressed air.
 - b. Nonporous surfaces: Use two-cloth solvent wipe in accordance with ASTM C1193. Allow solvent to evaporate prior to sealant application.
 - c. High-pressure water cleaning: Exercise care that water does not enter through failed joints.
 - d. Primers:
 - 1) Primers enhance adhesion ability.
 - 2) Use of primers is not a substitution for poor joint preparation.
 - 3) Primers should be used always in horizontal application where there is ponding water.
 3. Field test joints in inconspicuous location.
 - a. Verify joint preparation and primer required to obtain optimum adhesion of sealants to joint substrate.
 - b. When test indicates sealant adhesion failure, modify joint preparation primer, or both and retest until joint passes sealant adhesion test.
 4. Masking: Apply masking tape as required to protect adjacent surfaces and to ensure straight bead line and facilitate cleaning.
- B. Joints:
1. Prepare joints in accordance with ASTM C1193.
 - a. Clean joint surfaces of contaminates capable of affecting sealant bond to joint surface using Manufacturer's recommended instructions for joint preparation methods.
 - b. Remove dirt, dust, oils, wax, paints, and contamination capable of affecting primer and sealant bond.
 - c. Clean concrete joint surfaces to remove curing agents and form release agents.
- C. Protection:
1. Protect elements surrounding the Work of this section from damage or disfiguration.

3.3 APPLICATION

- A. General:
1. Apply silicone sealant in accordance with Manufacturer's instructions.
 2. Do not use damaged or deteriorated materials.
 3. Install primer and sealants in accordance with ASTM C1193 and Manufacturer's instructions.
 4. Apply primer where required for sealant adhesion.
 5. Install sealants immediately after joint preparation.
 6. Do not use silicone sealant as per the following:
 - a. Apply caulking/sealant at temperatures below 40 deg F (4 deg C).
 - b. Below-grade applications.
 - c. Brass and copper surfaces.
 - d. Materials bleeding oils, plasticizers, and solvents.
 - e. Structural glazing and adhesive.
 - f. Surfaces to be immersed in water for prolonged time.
- B. Joint Backing:
1. Install joint backing to maintain sealant joint ratios recommended by Manufacturer.
 2. Install without gaps, twisting, stretching, or puncturing backing material. Use gage to ensure uniform depth to achieve correct profile, coverage, and performance.
 3. Rod for open joints shall be at least 1-1/2 times width of open joint and of thickness to give solid backing. Backing shall fill up joint so depth of sealant bite is no more than 3/8 inch (9.5 mm) deep.
- C. Bond Breaker:
1. Install bond breaker where joint backing is not used or where backing is not feasible.
 - a. Apply bond-breaker tape in shallow joints as recommended by Sealant Manufacturer.
- D. Sealant:
1. Apply sealant with hand-caulking gun with nozzle of proper size to fit joints. Use sufficient pressure to insure full contact to both sides of joint to full depth of joint. Apply sealants in vertical joints from bottom to top.
 2. Fill joint opening to full and proper configuration.
 3. Apply in continuous operation.
 4. Tool joints immediately after application of sealant if required to achieve full bedding to substrate or to achieve smooth sealant surface. Tool joints in opposite direction from application direction, i.e., in vertical joints, from the top down. Do not 'wet tool' sealants.
 5. Depth of sealant bite shall be 1/4 inch (6 mm) minimum and 1/2 inch (12.7 mm) maximum, but never more than one half or less than one fourth joint width.
- E. Caulk gaps between painted or coated substrates and unfinished or pre-finished substrates. Caulk gaps larger than 3/16 inch (5 mm) between painted or coated substrates.

3.4 TOLERANCES

- A. Provide joint tolerances in accordance with Manufacturer's printed instructions.

3.5 FIELD QUALITY CONTROL

- A. Adhesion Test (Installer Option to use adhesion test to determine if primer is required).
1. Perform adhesion tests in accordance with Manufacturer's instructions and ASTM C1193, Method A, Field-Applied Sealant joint Hand-Pull Tab:
 - a. Perform five (5) tests for first 1,000 linear feet (300 meters) of applied silicone sealant and one (1) test for each 1,000 linear feet (300 meters) seal thereafter or perform one (1) test per floor per building elevation minimum.
 - b. For sealants applied between dissimilar materials, test both sides of joints.

2. Sealants failing adhesion test shall be removed, substrates cleaned, sealants re-installed, and re-testing performed.
3. Maintain test log and submit report to Architect indicating tests, locations, dates, results, and remedial actions.

3.6 CLEANING

- A. Remove masking tape and excess sealant.
- B. Clean adjacent materials, which have been soiled, immediately (before setting) as recommended by Manufacturer.
- C. Waste Management: Dispose of products in accordance with manufacturer's recommendation.

END OF SECTION

DIVISION 08: OPENINGS

08 0100 OPERATION AND MAINTENANCE OF OPENINGS

08 0601 HARDWARE GROUP AND KEYING SCHEDULES

08 1000 DOORS AND FRAMES

08 1213 HOLLOW METAL FRAMES

08 1429 FLUSH WOOD DOORS: FACTORY-FINISHED, CLEAR

08 7000 HARDWARE

08 7101 COMMON FINISH HARDWARE REQUIREMENTS

08 7102 HANGING DEVICES

08 7103 SECURING DEVICES

08 7106 CLOSING DEVICES

08 7109 ACCESSORIES

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 08 0601

HARDWARE GROUP AND KEYING SCHEDULES

PART 1 - GENERAL

1.1 SUMMARY

- A. Includes But Not Limited To:
 - 1. Furnish and install door hardware and keying as described in Contract Documents.

1.2 REFERENCES

- A. Definitions:
 - 1. Builders Hardware Manufacturer's Association (BHMA) Hardware Functions:
 - a. F81 Office Door Lock: Dead locking latch bolt operated by lever from either side, except when outside lever is locked by turn button in inside lever. When outside lever is locked, latch bolt is operated by key in outside lever or by rotating inside lever. Turn button must be manually rotated to unlock outside lever.

1.3 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Materials shall be delivered in original, unopened packages with labels intact.

PART 2 - HARDWARE GROUPS

2.1 INTERIOR DOORS

- A. Single Interior Doors:
 - 1. **Group 26:**
 - a. 1 set: Smoke Gaskets.
 - b. 1 each: Acoustic Seal.
 - c. 3 each: Hinges.
 - d. 1 each: Lockset Function F81.
 - e. 1 each: Closer
 - f. 1 each: Stop.
 - g. 1 each: Threshold.

PART 3 - KEYING SCHEDULE for FINISH HARDWARE

3.1 KEYING SCHEDULE

- A. Meetinghouse Keying Schedule:

- 1. Mechanical:

Key	Stamped	Amount	
XAA13	MECH	2	Match existing building key system

END OF SECTION

BLANK PAGE

SECTION 08 1213**HOLLOW METAL FRAMES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Hollow metal frames.
- B. Related Requirements:
 - 1. Section 06 2024: 'Door, Frame, And Finish Hardware Installation' for installation.

1.2 REFERENCES

- A. Reference Standards:
 - 1. American Architectural Manufacturers Association / Window & Door Manufacturers Association / CSA Group:
 - a. AAMA/WDMA/CSA 101/I.S.2/A440-17, 'North American Fenestration Standard/Specification for windows, doors, and skylights'.
 - 2. ASTM International:
 - a. ASTM A568/A568M-17a, 'Standard Specification for Steel, Sheet, Carbon, Structural, and High-Strength, Low-Alloy, Hot-Rolled and Cold-Rolled, General Requirements for.
 - b. ASTM A653/A653M-17, 'Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process'.
 - 3. Steel Door Institute:
 - a. SDI A250.8-2017, 'Specifications for Standard Steel Doors and Frames'.
 - b. SDI A250.11-2012, 'Recommended Erection Instructions for Steel Frames'.

1.3 SUBMITTALS

- A. Informational Submittals:
 - 1. Copy of SDI A250.11.

PART 2 - PRODUCTS**2.1 MANUFACTURED UNITS**

- A. Suppliers:
 - 1. Category Three Approved Suppliers. See Section 01 6200 for definitions of Categories and Section 01 4301 for Qualification Requirements:
 - a. Architectural Building Supply, Salt Lake City, UT www.cookandboardman.com:
 - 1) Contact Information: Russ Farley: phone (800) 574-4369, fax 801-484-6817, or e-mail russf@absdoors.com.
 - b. Beacon Metals Inc, Salt Lake City, UT www.beacon-metals.com:
 - 1) Contact Information: Jared Butler: phone (801) 486-4884, cell (435) 216-2297, FAX 801-485-7647, or e-mail Jared@beacon-metals.com.
 - c. Midwest D-Vision Solutions, Salt Lake City, UT www.mwdsutah.com.
 - 1) Contact Information: Dan Mercer, office (801) 377-4355, cell (801) 618-9456, e-mail danm@mwdsutah.com.
- B. Manufacturers:

1. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - a. Any current member of Steel Door Institute.

- C. Frames:
 1. Cold rolled furniture steel:
 - a. Interior Frames: 16 ga. (1.6 mm).
 2. Provide labeled frame to match fire rating of door.
 3. Finish:
 - a. Use one of following systems:
 - 1) Prime surfaces with rust inhibiting primer.
 - 2) Galvanize.
 4. Anchors: 16 US ga (1.6 mm) minimum meeting UL or other code acceptable requirements for door rating involved.

- D. Fabrication:
 1. General Requirements:
 - a. Frames shall be welded units. Provide temporary spreader on each welded frame.
 - b. Provide Manufacturer's gauge label for each item.
 - c. Make breaks, arrises, and angles uniform, straight, and true. Accurately fit corners.
 2. Frame width dimension:
 - a. Fabricate frame 1/8 inch (3 mm) wider than finished wall thickness as described in Contract Documents.
 3. Provide mortar guards at strikes and hinges.
 4. Anchors:
 - a. Provide three jamb anchors minimum for each jamb. On hinge side, install one anchor at each hinge location. On strike side, install one anchor at strike level and anchors at same level as top and bottom hinges. Tack weld anchors on frames intended for installation in framed walls.
 - b. Frames installed before walls are constructed shall be provided with extended base anchors in addition to other specified anchors.
 - c. Anchor types and configurations shall meet wall conditions.

PART 3 - EXECUTION: Not Used

END OF SECTION

SECTION 08 1429**FLUSH WOOD DOORS: Factory-Finished, Clear****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Factory-finished flush wood doors.
- B. Related Requirements:
 - 1. Section 06 2024: 'Door, Frame, And Finish Hardware Installation' for installation.
 - 2. Section 09 9324: 'Interior Clear-Finished Hardwood'.

1.2 REFERENCES

- A. Abbreviations And Acronyms:
 - 1. AWS: Architectural Woodwork Standards (formerly AWI).
 - 2. FD: Fire-resistant core, fire-resistant materials assembled to stiles and rails according to methods prescribed by the testing agency to meet rigorous smoke, flame, and pressure tests.
 - 3. FD-5: Core with 2 layers on each side.
 - 4. ME: Matching edges, i.e., vertical edges same as decorative faces.
 - 5. PC: Particleboard core, solid core door with stiles and rails bonded to the core and abrasive planed flat prior to the application of the faces.
 - 6. PC-5: Core with 2 layers on each side.
- B. Association Publications:
 - 1. Architectural Woodwork Institute / Architectural Woodwork Manufacturers Association of Canada, 46179 Westlake Drive, Suite 120, Potomac Falls, VA www.awinet.org.
 - a. Architectural Woodwork Standards (AWS), 2nd Edition, 2014.
- C. Definitions:
 - 1. Book-Match: Matching between adjacent veneer leaves on one panel face. Every other piece of veneer is turned over so that the adjacent leaves are "opened" as two pages in a book. The fibers of the wood, slanting in opposite directions in the adjacent leaves, create a characteristic light and dark effect when the surface is seen from an angle.
 - 2. Fire-rated: Fire-retardant particleboard with an Underwriters' Laboratory (UL) stamp for Class 1 fire rating (Flame Spread 20, Smoke Developed 25). Fire-rated doors are available with particleboard and mineral cores for ratings up to 1-1/2 hours.
 - 3. Fire-rated Door: A door made of fire-resistant material that can be closed to prevent the spread of fire and can be rated as resisting fire for 20 minutes (1/3 hour), 30 minutes (1/2 hour), 45 minutes (3/4 hour) (C), 1 hour (B), or 1-1/2 hours (B). The door must be tested and carry an identifying label from a qualified testing and inspection agency.
 - 4. Grade: Unless otherwise noted, this term means Grade rules for Economy, Custom, and/or Premium Grade.
 - a. Custom Grade: Typically specified for and adequately covers most high-quality architectural woodwork, providing a well-defined degree of control over a project's quality of materials, workmanship, or installation.
 - b. Premium Grade: The highest Grade available in both material and workmanship where the highest level of quality, materials, workmanship, and installation is required.
 - 5. Running Match: Each panel face is assembled from as many veneer leaves as necessary. Any portion left over from one panel may be used to start the next.
- D. Reference Standards:

1. American Architectural Manufacturers Association / Window & Door Manufacturers Association / CSA Group:
 - a. AAMA/WDMA/CSA 101/I.S.2/A440-17, 'North American Fenestration Standard/Specification for windows, doors, and skylights'
2. ASTM International:
 - a. ASTM C1036-16, 'Standard Specification for Flat Glass'.
 - b. ASTM C1048-18, 'Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass'.
3. Hardwood, Plywood, and Veneer Association:
 - a. HPVA HP-1-2016 'Standard for Hardwood and Decorative Plywood'.
4. National Particleboard Association / Composite Panel Association:
 - a. NPA A208.1-2009, 'Particleboard'.

1.3 SUBMITTALS

A. Action Submittals:

1. Shop Drawings:

- a. Schedule showing type of door at each location. Included shall be size, veneer, core type, fire rating, hardware prep, openings, blocking, etc.
- b. Indicate factory finish color and type.

2. Samples:

a. Interior Hardwood for Transparent Finish:

- 1) Before performing work of this Section, prepare Control Sample, to match sample available from Owner, to be used as finishing standard for interior clear finished hardwood as specified in Section 09 9324.
- 2) Design Criteria:
 - a) Provide **8 inch by 10 inch (200 mm by 255 mm)** sample of Oak to match Owner provided stain color selected for Project.
 - b) Control Sample will be used as performance standard for evaluating finish provided.

B. Informational Submittals:

1. Source Quality Control Submittals:

a. Samples:

1) Interior Hardwood for Transparent Finish:

- a) Owner will provide Control Sample from project for finish.

C. Closeout Submittals:

1. Include following information in Operations And Maintenance Manuals specified in Section 01 7800:

a. Record Documentation:

1) Manufacturers Documentation:

- a) Manufacturer's product literature on doors and factory finish.
- b) Maintenance and repair instructions.

1.4 DELIVERY, STORAGE, AND HANDLING

A. Delivery And Acceptance Requirements:

1. Deliver in clean truck and, in wet weather, under cover.
2. Deliver to building site only after plaster, cement, and taping compound are completed and dry and after interior painting operations have been completed.
3. Individually wrap in polyethylene bags for shipment and storage.

B. Storage And Handling Requirements:

1. Store doors in a space having controlled temperature and humidity range between 25 and 55 percent.
2. Store flat on level surface in dry, well ventilated space.

3. Cover to keep clean but allow air circulation.
4. Do not subject doors to direct sunlight, abnormal heat, dryness, or humidity.
5. Handle with clean gloves and do not drag doors across one another or across other surfaces.
6. Leave shipping bag on door after installation until immediately before substantial completion inspection.
7. Doors have been acclimated to the field conditions for a minimum of 72 hours before installation is commenced.

1.5 WARRANTY

A. Manufacturer Warranty:

1. Manufacturer's standard full door warranty for lifetime of original installation.
 - a. Warranty shall include finishing, hanging, and installing hardware if manufacturing defect was discovered after door was finished and installed.
 - b. Warranty to include defects in materials including following:
 - 1) Delaminating in any degree.
 - 2) Warp or twist of **1/4 inch (6 mm)** or more in door panel at time of one-year warranty inspection.
 - 3) Telegraphing of core assembly: Variation of **1/100 inch (0.25 mm)** or more in **3 inch (75 mm)** span.

PART 2 - PRODUCTS

2.1 MANUFACTURED UNITS

A. Suppliers:

1. Category Three Approved Suppliers. See Section 01 6200 for definitions of Categories and Section 01 4301 for Qualification Requirements:
 - a. Architectural Building Supply, Salt Lake City, UT www.cookandboardman.com:
 - 1) Contact Information: Russ Farley: phone (800) 574-4369, fax 801-484-6817, or e-mail russf@absdoors.com.
 - b. Beacon Metals Inc, Salt Lake City, UT www.beacon-metals.com:
 - 1) Contact Information: Jared Butler: phone (801) 486-4884, cell (435) 216-2297, FAX 801-485-7647, or e-mail Jared@beacon-metals.com.
 - c. Midwest D-Vision Solutions, Salt Lake City, UT www.mwdsutah.com.
 - 1) Contact Information: Dan Mercer, office (801) 377-4355, cell (801) 618-9456, e-mail danm@mwdsutah.com.

B. Manufacturers:

1. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - a. Graham Wood Doors, Mason City, IA.
 - b. Marshfield Door Systems Inc, Marshfield, WI.
 - c. VT Industries, Holstein, IA.

C. Wood Doors:

1. Type: AWS PC-5ME or FD-5ME.
2. Grade: AWS Premium, except face veneer.
3. Fully Type I Construction: Adhere all glue lines with Type I adhesive, including veneer lay-up.
4. Face Veneer:
 - a. Plain sliced Oak meeting requirements of AWS Grade A, **1/50 inch (0.5 mm)** thick minimum immediately before finishing.
 - b. Face veneers shall be running book matched.
5. Core:
 - a. Fully bonded to stiles and rails and sanded as a unit before applying veneers.
 - b. Non-Rated:

- 1) 32 lb density meeting requirements of ANSI A208.1 Mat Formed Wood Particle Board, Grade 1-L-1 minimum.
 - 2) Stiles:
 - a) 1-3/8 inches (35 mm) deep minimum before fitting.
 - b) Stile face to be hardwood matching face veneer material, thickness manufacturer's standard.
 - 3) Rails:
 - a) 1-1/8 inches (28 mm).
 - b) Manufacturer's option.
- D. Fabrication:
1. Doors shall be factory-machined. Coordinate with Section 08 1213 and Sections under 08 7000.
- E. Finishes:
1. Factory Finishing:
 - a. Applied by Door Manufacturer before leaving factory.
 - b. Performance / Design Criteria:
 - 1) Finish factory-finish to match Owner selected sample as specified in Section 09 9324.
 - c. Match existing Project Color Scheme:
 - 1) Control Sample provided by Owner:
 - a) Control Sample will be existing wood item from Project.
 - d. Finish: AWS Finish System TR-6 Catalyzed Polyurethane Premium Grade for unfilled, open-grain woods.

2.2 SOURCE QUALITY CONTROL

- A. Inspections:
1. Verification of Performance:
 - a. Doors shall have following information permanently affixed on top of door:
 - 1) Manufacturer:
 - 2) Door designation or model.
 - 3) Veneer species.
 - 4) Factory finish.
 2. Clear Finished Hardwood:
 - a. Color matches Owner provided sample specified in Section 09 9324.

PART 3 - EXECUTION: Not Used

END OF SECTION

SECTION 08 7101**COMMON FINISH HARDWARE REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. General requirements for finish hardware related to architectural wood and hollow metal doors.
- B. Related Requirements:
 - 1. Section 06 2024: 'Door, Frame, And Finish Hardware Installation' for installation of hardware.
 - 2. Section 08 0601: 'Hardware Group and Keying Schedules'.

1.2 REFERENCES

- A. Association Publications:
 - 1. Builders Hardware Manufacturers Association (BHMA), 355 Lexington Avenue, 15th Floor, New York, NY 10017-6603, Tel: 212-297-2122 Fax: 212-370-9047, www.buildershardware.com.
- B. Reference Standards:
 - 1. International Code Council / American National Standards Institute:
 - a. ICC / ANSI A117.1-2009, 'Accessible and Usable Buildings and Facilities'.
 - 2. Underwriters Laboratories (UL):
 - a. UL 10B, 'Fire Tests of Door Assemblies' (10th Edition).
 - b. UL 10C, 'Positive Pressure Fire Tests of Door Assemblies' (Third Edition).

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Hardware Templates:
 - a. Provide hardware templates to Sections 08 1213, 08 1313, and 08 1429 within fourteen (14) days after Architect approves hardware schedule.
 - b. Supply necessary hardware installation templates to Section 06 2024 before pre-installation conference.

1.4 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Manufacturer's cut sheets.
 - b. Two (2) copies of Manufacturer's installation, adjustment, and maintenance instructions for each piece of hardware. Include one (1) set in 'Operations And Maintenance Manual' and send one (1) set with hardware when delivered.
 - c. Copy of hardware schedule.
 - d. Written copy of keying system explanation.
 - 2. Shop Drawings:
 - a. Submit hardware schedule indicating hardware to be supplied.
 - b. Schedule shall indicate details such as proper type of strikeplates, spindle lengths, hand, backset, and bevel of locks, hand and degree opening of closer, length of kickplates, length of rods and flushbolts, type of door stop, and other necessary information necessary to determine exact hardware requirements.

B. Closeout Submittals:

1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Operations and Maintenance Data:
 - 1) Manufacturer's installation, adjustment, and maintenance instructions for each piece of hardware.
 - b. Record Documentation:
 - 1) Manufacturers documentation:
 - a) Manufacturer's literature and/or cut sheets.
 - b) Include keying plan and bitting schedule.

1.5 DELIVERY, STORAGE, AND HANDLING**A. Storage And Handling Requirements:**

1. Neatly and securely package hardware items by hardware group and identify for individual door with specified group number and set number used on Supplier's hardware schedule.
2. Include fasteners and accessories necessary for installation and operation of finish hardware in same package.

PART 2 - PRODUCTS**2.1 SUPPLIERS****A. Existing Projects (Doors and Door Hardware):**

1. USA Projects:
 - a. Category Three Approved Suppliers. See Section 01 6200 for definitions of Categories:
 - 1) Architectural Building Supply, Salt Lake City, UT www.cookandboardman.com:
 - a) Contact Information: Russ Farley: phone (800) 574-4369, fax 801-484-6817, or e-mail russf@absdoors.com.
 - 2) Beacon Metals Inc, Salt Lake City, UT www.beacon-metals.com:
 - a) Contact Information: Jared Butler: phone (801) 486-4884, cell (435) 216-2297, FAX 801-485-7647, or e-mail Jared@beacon-metals.com.
 - 3) Midwest D-Vision Solutions, Salt Lake City, UT www.mwdsutah.com.
 - a) Contact Information: Dan Mercer, office (801) 377-4355, cell (801) 618-9456, e-mail danm@mwdsutah.com.

B. Hardware Finishes:

1. Finishes for brass or bronze hardware items shall be:
 - a. ANSI / BHMA Finish Code 626.
 - 1) Description: Satin Chromium Plated.
 - 2) Base Metal: Brass. Bronze.
2. Finishes for flat goods items may be:
 - a. ANSI / BHMA Finish Code 630.
 - 1) Description: Satin Stainless Steel.
 - 2) Base Metal: Stainless Steel (300 Series).
3. Materials other than steel, brass, or bronze shall be finished to match appearance satin chromium plated, except flat goods which shall be satin stainless steel.

2.2 FASTENERS

- A. Fasteners shall be of suitable types, sizes and quantities to properly secure hardware. Fasteners shall be of same material and finish as hardware unless otherwise specified. Fasteners exposed to weather shall be non-ferrous or corrosion resisting steel.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before ordering materials, examine Contract Documents to be assured that material to be ordered is appropriate for thickness and substrate to which it is to be secured and will function as intended.

END OF SECTION

BLANK PAGE

SECTION 08 7102**HANGING DEVICES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Hinges for flush wood and hollow metal doors.
- B. Related Requirements:
 - 1. Section 08 7101: 'Common Hardware Requirements'.

PART 2 - PRODUCTS**2.1 MANUFACTURED UNITS**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Hager Companies, St Louis, MO www.hagerhinge.com.
 - b. Ives, New Haven, CT www.iveshardware.com.
 - c. McKinney, Scranton, PA www.mckinneyhinge.com.
 - d. PBB, Ontario, CA www.pbbinc.com.
 - e. Stanley (dormakaba Americas), Indianapolis IN www.stanleyhardwarefordoors.com/products/.
- B. Hinges:
 - 1. Doors:
 - a. Sizes:
 - 1) Non-Fire-Rated Doors:
 - a) 1-3/4 inch 44.5 mm non-fire-rated wood doors in wood frames: 4 inches by 4 inches (100 mm by 100 mm).
 - b) 1-3/8 inch 35 mm wood or metal doors: 3-1/2 inches by 3-1/2 inches (89 mm by 89 mm).
 - 2. Use non-removable pins on exterior opening doors.
 - 3. Hinges on exterior doors shall be solid brass, plated to achieve specified finish.
 - 4. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a. Interior:
 - 1) Hager: BB 1279.
 - 2) Ives: 5BBI.
 - 3) McKinney: TA 2714.
 - 4) MacPro / McKinney: MPB79.
 - 5) PBB: BB81.
 - 6) Stanley: FBB 179.
 - b. Exterior:
 - 1) Hager: BB 1191.
 - 2) Ives: 5BBI.
 - 3) McKinney: TA 2314.
 - 4) PBB: BB21.
 - 5) Stanley: FBB 191.

PART 3 - EXECUTION: Not Used

END OF SECTION

SECTION 08 7103**SECURING DEVICES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Items for architectural wood or hollow metal doors:
 - a. Locksets and latchsets.
- B. Related Requirements:
 - 1. Section 08 7101: Common Hardware Requirements.

1.2 REFERENCES

- A. Definitions:
 - 1. Grade 1 Heavy Duty Key-In Lever Cylindrical Lockset:
 - a. Performance Features:
 - 1) Exceeds 1,000,000 ANSI cycles.
 - 2) Clutching mechanism standard.
 - 3) Thru-bolt design and heavy-duty spring tension provides longer performance life and prevents lever sag.
 - 4) ADA-compliant thumbturn.
 - 5) Mortise case is easily field reversible.
 - 6) Pre-assembled trims with spring-loaded spindles automatically adjust to door thickness.
 - 7) Partial security separator prevents spindle manipulation.
 - 8) Anti-friction throwbolt.
 - 2. Grade 2 Standard Duty Key-In Lever Cylindrical Lockset:
 - a. Performance Features:
 - 1) Exceeds 400,000 ANSI cycles.
 - 2) Single motion egress provides easy emergency exit.
 - 3) Full 1 inch (25 mm) throwbolt with saw resistant hardened steel roller pin.
 - 4) Anti-drill design deadbolt. Two (2) ball bearings inserted to prevent drill attacks.
 - 5) ADA-compliant thumbturn.

1.3 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Standard Key Delivery:
 - a. Include change keys with hardware.

PART 2 - PRODUCTS**2.1 MANUFACTURED UNITS**

- A. Manufacturers:
 - 1. Manufacturer List:
 - a. Best Locks by Stanley, Indianapolis IN www.stanleysecuritysolutions.com.
 - b. Glynn-Johnson, Indianapolis, IN www.glynn-johnson.com.
 - c. Hager, St Louis, MO www.hagerhinge.com.
 - d. Ives, New Haven, CT www.iveshardware.com.

- e. Knape & Vogt, Grand Rapids, MI www.knapeandvogt.com.
 - f. Marks USA, Amityville, NY www.marksusa.com.
 - g. Precision Hardware, Romulus, MI www.precisionhardware.com.
 - h. Rockwood, Manufacturing Co, Rockwood, PA www.rockwoodmfg.com.
 - i. Sargent, New Haven, CT www.sargentlock.com.
 - j. Schlage, Colorado Springs, CO www.schlage.com.
 - k. Von Duprin, Indianapolis, IN www.vonduprin.com.
 - l. Yale Commercial Locks, Lenoir City, TN www.yalecommercial.com.
- B. General:
- 1. Backsets shall be **2-3/4 inches (70 mm)**.
 - 2. Furnish lead shields where required.
- C. Locksets And Latchsets:
- 1. Design Criteria:
 - a. Grade 2 Standard Duty Key-In Lever Cylindrical Lockset:
 - 1) ANSI/BHMA A156.02 Series 4000 Grade 2.
 - 2) Meet UL 3 hour fire rating.
 - 3) Meet ADA Compliant ANSI A117.1 Accessibility Code.
 - 4) Door Lever:
 - a) Meet California code for **1/2 inch (12.7 mm)** or less return to door.
 - 2. Lever Operated:
 - a. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Grade 2 Standard Duty Key-In Lever Cylindrical Locksets:
 - a) 7K Series Best Lock with 15D Lever by Stanley standard cylinders - (I/C cores may be used when authorized by AEC).
 - b) 175 Series with American Lever by Marks USA.
 - c) 7 Line Series with L Lever by Sargent.
 - d) AL Series with Saturn (SAT) Lever by Schlage.
 - e) 5300LN Series with Augusta (AU) Lever by Yale.

PART 3 - EXECUTION

3.1 CLOSE-OUT ACTIVITIES

- A. Owner's Instructions:
- 1. Before Final Acceptance Meeting, send master keys to Facilities Manager.

END OF SECTION

SECTION 08 7106**CLOSING DEVICES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Closers for flush wood doors.
- B. Related Requirements:
 - 1. Section 08 7101: 'Common Finish Hardware Requirements'.

1.2 SUBMITTALS

- A. Closeout Submittals:
 - 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Warranty Documentation:
 - 1) Manufacturer's final executed copy of warranty.

1.3 WARRANTY

- A. Manufacturer Warranty:
 - 1. Manufacturer's Standard Warranty, five (5) years minimum.

PART 2 - PRODUCTS**2.1 MANUFACTURED UNITS**

- A. Manufacturers:
 - 1. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - a. 8900 Series by Dorma Architectural Hardware, Reamstown, PA www.dorma.com/usa.
 - b. 1461 Series by LCN Closers, Princeton, IL www.lcnclosers.com.
 - c. 8501 Series by Norton Door Controls, Charlotte, NC www.nortondoorcontrols.com.
 - d. 1431 Series by Sargent, New Haven, CT www.sargentlock.com.
 - e. D-3550/D-3551 Series by Stanley (dormakaba Americas), Indianapolis IN www.stanleyhardwarefordoors.com/products/.
- B. Surface-Mounted Overhead Door Closers:
 - 1. Closers provided under this Section shall be from same Manufacturer.
 - 2. Provide parallel arms on closers unless door position in relation to adjacent wall requires otherwise. Provide covers.
 - 3. Door Closers on doors that swing 180 degree as shown on Contract Documents:
 - a. Closers shall allow for 180 degree opening without engaging stop function. Wall stop or Floor stop is specified in Door Schedule and Section 08 7108, 'Stops And Holders'.
 - b. Closers shall have following features:
 - 1) Adjustable sweep speed.
 - 2) Adjustable backcheck.
 - 3) Non-handed, non-sized.
 - 4) Hold open arm function (Friction Hold Open) (Non-Fire-Rated Corridors).
 - 5) Delayed action closing where noted on Door Schedule.
 - 4. Door Closers on doors that swing 90 degree as shown on Contract Documents:

- a. Closers shall allow for 100 degree opening with engaging stop function.
- b. Closers shall have following features:
 - 1) Adjustable sweep speed.
 - 2) Adjustable backcheck.
 - 3) Non-handed, non-sized.
 - 4) Hold open arm function with thumb turn or handle control (Cush And Hold) (Non-Fire-Rated Corridors).
 - 5) Delayed action closing where noted on Door Schedule.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Mount closers on stop side of door wherever conditions permit.
- B. Through-bolt hardware-to-door connections.

3.2 ADJUSTING

- A. Adjust closers to provide maximum opening force as required by governing code authority and proper backcheck and sweep speed.

END OF SECTION

SECTION 08 7109**ACCESSORIES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under This Section:
 - 1. Acoustical seals.
 - 2. Smoke Gaskets.
 - 3. Thresholds (metal) where required for wood doors and hollow metal doors.
 - 4. Door bottoms/door sweeps.

- B. Related Requirements:
 - 1. Section 08 7101: 'Common Finish Hardware Requirements' for general finish hardware requirements and Approved Suppliers.

1.2 REFERENCES

- A. Association Publications:
 - 1. American Architectural Manufacturers Association (AAMA):
 - a. AAMA 609 & 609-09, 'Cleaning and Maintenance Guide for Architecturally Finished Aluminum' (combined document).
 - b. AAMA 611-12, 'Voluntary Standards for Anodized Architectural Aluminum'.
 - c. AAMA 701/702-11, 'Voluntary Specification for Pile Weatherstripping and Replaceable Fenestration Weatherseals'.
 - 2. National Association of Architectural Metal Manufacturers (NAAMM):
 - a. AMP 500-06, 'Metal Finishes Manual' for Architectural and Metal Products.

- B. Reference Standards:
 - 1. American National Standards Institute / Builders Hardware Manufacturers Association:
 - a. ANSI / BHMA A156.18-2012, 'Materials and Finishes'.
 - b. ANSI / BHMA A156.21-2014, 'American National Standard for Thresholds'.
 - 2. International Code Council / American National Standards Institute:
 - a. ICC / ANSI A117.1-2009, 'Accessible and Usable Buildings and Facilities'.

PART 2 - PRODUCTS**2.1 MANUFACTURED UNITS**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Hager, St Louis, MO www.hagerhinge.com.
 - b. NGP - National Guard Products, Memphis, TN www.ngpinc.com.
 - c. Pemko Manufacturing, Ventura, CA www.pemko.com.

- B. Acoustical Seals:
 - 1. Color as selected by Architect.
 - 2. Type One Acceptable Products:
 - a. Door Bottom Shoe for Wood Door:
 - 1) 13VDkB by NGP.
 - 2) 211DV by Pemko.
 - b. Door Bottom Shoe for Metal Door:

- 1) 779S-A by Hager.
 - 2) 35EV by NGP.
 - 3) 217AV by Pemko.
 - c. Equal as approved by Architect before bidding. See Section 01 6200.
- C. Smoke Gaskets:
1. Color as selected by Architect.
 2. Type One Acceptable Products:
 - a. 726 by Hager.
 - b. 5050 by NGP.
 - c. PK 55 by Pemko.
 - d. Equal as approved by Architect before bidding. See Section 01 6200.
- D. Thresholds:
1. Type One Acceptable Products:
 - a. Design Criteria:
 - 1) Meet handicap accessibility requirements (ADA):
 - b. Interior Doors at Acoustic Seals, Approved Products:
 - 1) Carpet threshold (carpet to carpet):
 - a) 505S DBA by Hager.
 - b) 414 DKB by NGP.
 - c) 236 D by Pemko.
 - 2) Carpet threshold (carpet to concrete, wood, synthetic, or resilient flooring):
 - a) 417 DKB by NGP.
 - b) 174 D by Pemko.
 - 3) Saddle threshold:
 - a) 418S DBA by Hager.
 - b) 411 DKB by NGP.
 - c) 151 D by Pemko.
 - c. Equals as approved by Architect before bidding. See Section 01 6200.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install smoke gaskets and acoustical seals in manner to give continuous air-tight fit.
1. Install smoke gaskets as per Manufacturer's installation requirements:
 - a. Hinge Jamb: Install smoke gaskets on jamb face of door frame so door will compress smoke gasket.
 - b. Header and Strike Jamb: Install smoke gaskets on face of stop of door frame so door will compress smoke gasket.
 2. Install acoustical seal with seal under door.

END OF SECTION

DIVISION 09: FINISHES

09 0500 COMMON WORK RESULTS FOR FINISHES

09 0503 FLOORING SUBSTRATE PREPARATION

09 2000 PLASTER AND GYPSUM BOARD

09 2900 GYPSUM BOARD

09 6000 FLOORING

09 6816 SHEET CARPET: BACK CUSHION, DIRECT GLUE

09 9000 PAINTS AND COATINGS

09 9001 COMMON PAINTING AND COATING REQUIREMENTS

09 9112 EXTERIOR PAINTED FERROUS METAL

09 9113 EXTERIOR PAINTED GALVANIZED METAL

09 9121 INTERIOR PAINTED POURED CONCRETE

09 9123 INTERIOR PAINTED GYPSUM BOARD, PLASTER

09 9124 INTERIOR PAINTED METAL

09 9324 INTERIOR CLEAR-FINISHED HARDWOOD

09 9413 INTERIOR TEXTURED FINISHING

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 09 0503**FLOORING SUBSTRATE PREPARATION****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Preparing floor substrate to receive flooring as described in Contract Documents.
 2. Remove existing carpet and prepare floor as described in Contract Documents.
 3. Perform building modifications and repairs to accommodate carpet and carpet base as described in Contract Documents.
- B. Related Requirements:
1. Pre-Installation conferences held jointly with Section 09 0503 as described in Administrative Requirements on Part 1 of this specification section.
 2. Section 01 1200: 'Multiple Contract Summary'.
 3. Section 01 3100: 'Project Management and Coordination' for pre-installation conference.
 4. Section 01 4000: 'Quality Requirements' for administrative and procedural requirements for quality assurance and quality control.
 5. Section 01 4301: 'Quality Assurance – Qualifications' establishes minimum qualification levels required.
 6. Section 01 7800: 'Closeout Submittals'.
 7. Section 03 3111: 'Cast-In-Place Structural Concrete' for installation tolerances for concrete slabs.
 8. Section 09 6816: 'Sheet Carpeting'.

1.2 REFERENCES

- A. Association Publications:
1. American Concrete Institute, Farmington Hills, MI www.concrete.org. Abstracts of ACI Periodicals and Publications.
 - a. ACI 302.2R-06, *Guide for Concrete Slabs that Receive Moisture-Sensitive Flooring Materials* (August 15, 2006).
 2. International Concrete Repair Institute: '*ICRI Concrete Slab Moisture Testing Program*' Rosemont, IL www.icri.org.
 - a. ICRI Certification: 'Concrete Slab Moisture Testing Technician, Tier 2, Grade 1'.
- B. Reference Standards:
1. ASTM International:
 - a. ASTM F710-11, 'Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring'.
 - b. ASTM F1869-16, 'Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride'.
 - c. ASTM F2170-16, 'Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
1. Participate in pre-installation conference held jointly if possible for all related Division 09 6000 'Flooring' used for Project.
 2. Schedule conference after substrate preparation and before installation of flooring system. (If more than one (1) flooring system is included for project, hold conference at same time if schedule permits).

3. Conference may be held at project site or other convenient site. Participants may also attend by video or audio conference if approved by Project Manager.
4. In addition to agenda items specified in Section 01 3100, review following:
 - a. Review condition of floor with regard to compliance with concrete installation tolerances and other work necessary to prepare floors for installation of flooring.
 - b. Review Testing Agency testing report of Concrete Moisture of concrete:
 - 1) Installer may verify Concrete Moisture of concrete.
5. Review condition of floor with regard to compliance with concrete installation tolerances and other work necessary to prepare floors for installation of flooring.
6. Review additional agenda items all related flooring sections.

1.4 SUBMITTALS

1.5 QUALITY ASSURANCE

- A. Testing and Inspection.
 1. Owner will provide Field Testing for Alkalinity and Concrete Moisture of concrete slab before installation as specified in Field Quality Control in Part 3 of this specifications for flooring:
 - a. See Section 01 1200: 'Multiple Contract Summary'.
 - b. See Section 01 4523: 'Testing and Inspecting Services' for testing and inspection, and testing laboratory services for materials, products, and construction methods.
 2. Category One VMR Testing Agency. See Section 01 6200 for definitions of Categories:
 - a. IFTI - Independent floor Testing & Inspection, Inc.:
 - 1) Contact Information: James Pouliot:
 - a) 1850 Gateway Blvd. Suite 230 Concord, CA 94520.
 - b) Phone: Office (800) 490-3657 x 207 or Cell (925) 819-1780.
 - c) Fax (877) 814-0338.
 - d) E-mail james.pouliot@ifti.com.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Storage And Handling Requirements:
 1. Provide storage space and protection for flooring and installation accessories if materials are delivered before start of flooring installation.

1.7 FIELD CONDITIONS

- A. Existing Conditions:
 1. If asbestos containing materials are suspected or discovered upon removing carpet, stop work and report to Architect and Owner's Representative before proceeding:
 - a. Do not use solvents to wash substrate during abatement process.

PART 2 - PRODUCTS Not Used

PART 3 - EXECUTION

3.1 PREPARATION

- A. Flooring Preparation:
 1. General:

- a. Prepare floor substrate in accordance with ASTM F710, 'Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring' (This standard is used for preparing concrete floors for all flooring).
 - 1) Required RH test and alkalinity test of concrete slab has been performed.
 - b. Concrete floor slab patching:
 - 1) Cracks, chips and joints must be properly patched or repaired.
 - c. Concrete surface cured, clean, dry, and free of foreign substances that will compromise carpet and/or other flooring installations.
 - 1) Removal of curing compounds.
 - 2) Remove paint, sealer, grease, oil, silicone sealants, and other materials incompatible with flooring adhesives.
 - 3) Removal of overspray from painted walls (essential so glue will stick).
 - d. Vacuum and damp mop floor areas to receive flooring before flooring installation.
2. Carpeted floor areas:
 - a. Prepare floor substrate in accordance with Carpet And Rug Institute (CRI) best practices to receive carpet installation and to provide installation that meets Carpet Manufacturer's warranty requirements.
- B. Carpet Accessories:
1. Sundry items, such as adhesives, shall be conditioned to building ambient conditions before use.

END OF SECTION

BLANK PAGE

SECTION 09 2900**GYPSUM BOARD****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install gypsum board as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 09 9413: 'Interior Textured Finishing'.

1.2 REFERENCES

- A. Definitions:
 - 1. Accessories: Metal or plastic beads, trim, or moulding used to protect or conceal corners, edges, or abutments of the gypsum board construction.
 - 2. Drywall Primer: Paint material specifically formulated to fill the pores and equalize the suction difference between gypsum board surface paper and the compound used on finished joints, angles, fastener heads, and accessories and over skim coatings.
 - 3. Skim Coat: Either a thin coat of joint compound trowel applied, or a material manufactured especially for this purpose and applied in accordance with manufacturer's recommendations, over the entire surface.
 - 4. Texturing: Regular or irregular patterns typically produced by applying a mixture of joint compound and water, or proprietary texture materials including latex base texture paint, to a gypsum board surface previously coated with drywall primer.
- B. Reference Standards:
 - 1. ASTM International:
 - a. ASTM C11-16, 'Standard Terminology Relating to Gypsum and Related Building Materials and Systems'.
 - b. ASTM C475/C475M-15, 'Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board'.
 - c. ASTM C840-17, 'Standard Specification for Application and Finishing of Gypsum Board'.
 - d. ASTM C1002-16, 'Standard Specification for Steel Self-Piercing Tapping Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs'.
 - e. ASTM C1047-14a, 'Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base'.
 - f. ASTM C1178/C1178M-13, 'Standard Specification for Coated Glass Mat Water-Resistant Gypsum Backing Panel'.
 - g. ASTM C1396/C1396M-14a, 'Standard Specification for Gypsum Board'.
 - h. ASTM E84-16, 'Standard Test Method for Surface Burning Characteristics of Building Materials'.
 - i. ASTM E119-16a, 'Standard Test Method for Fire Tests of Building Construction and Materials'.
 - 2. Gypsum Association:
 - a. GA-214-15, 'Recommended Levels of Gypsum Board Finish'.
 - b. GA-216-16: 'Application and Finishing of Gypsum Panel Products'.
 - c. GA-600-15, 'Fire Reference Design Manual'.
 - d. GA-801-07, 'Handling and Storage of Gypsum Panel Products: A Guide for Distributors, Retailers, and Contractors'.
 - 3. International Building Code (IBC) (2015 or latest approved version):

- a. Chapter 25, 'Gypsum Board And Plaster'.
4. National Building Code of Canada / Underwriters Laboratories of Canada:
 - a. CAN/ULC-S102: 'Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies' (7th Edition).
5. Underwriters Laboratories, Inc.
 - a. UL 263: 'Test Method for Fire Tests of Building Construction and Materials' (14th Edition).
 - b. UL 723: 'Test for Surface Burning Characteristics of Building Materials; (10th Edition).

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 1. Schedule MANDATORY pre-installation conference immediately before installation of gypsum wallboard.
 2. In addition to agenda items specified in Section 01 3100, review following:
 - a. Finish requirements necessary for installation of finish materials over gypsum wallboard, and location and installation of ceramic tile backerboard.

1.4 SUBMITTALS

- A. Informational Submittals:
 1. Test And Evaluation Reports:
 - a. Fire test results or assembly diagrams and numbers confirming products used will provide required fire ratings with installation configurations used.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. General:
 1. Following recommendations of GA-801 Guide for Handling and Storage of Gypsum Panel Products unless local, state or federal laws or agency rules differing from the recommendations shall take precedence.
- B. Delivery And Acceptance Requirements:
 1. Deliver materials in original packages, containers, or bundles bearing brand name, applicable standard designation, and Manufacturer's name.
- C. Storage And Handling Requirements:
 1. Store material under roof and keep dry and protected against damage from weather, condensation, direct sunlight, construction traffic, and other causes. Stack gypsum board flat to prevent sagging.

1.6 FIELD CONDITIONS

- A. Ambient Conditions:
 1. Comply with ASTM C840 or GA-216 requirements, whichever are more stringent:
 - a. Do not install interior products until installation areas are enclosed and conditioned.
 - 1) Temperature shall be 50 deg F (10 deg C) and 95 deg F (35 deg C) maximum day and night during entire joint operation and until execution of Certificate of Substantial Completion.
 - 2) Provide ventilation to eliminate excessive moisture.
 - 3) Avoid hot air drafts that will cause too rapid drying.
 - b. Do not install panels that are wet, those that are moisture damaged, and those that are mold damaged.

PART 2 - PRODUCTS

2.1 MATERIALS

A. Manufacturers:

1. Manufacturer Contact List:
 - a. American Gypsum, Dallas, TX www.americangypsum.com.
 - b. CertainTeed Gypsum, Inc; Tampa, FL www.certainteed.com.
 - c. Georgia Pacific, Atlanta, GA www.gp.com.
 - d. National Gypsum, Charlotte, NC www.nationalgypsum.com.
 - e. Pabco Gypsum, Newark, CA www.pabco gypsum.com.
 - f. United States Gypsum Co, Chicago, IL www.usg.com.

B. Materials:

1. Interior Gypsum Board:
 - a. General:
 - 1) Size:
 - a) Provide maximum lengths and widths available that will minimize joints in each area and that correspond with support system indicated.
 - 2) Class Two Quality Standard:
 - a) Core: Fire-resistant rated gypsum core.
 - b) Complies with Type X requirements of ASTM C1396/C1396M (Section 5).
 - c) Surface paper: Face paper suitable for painting.
 - d) Long edges: Tapered edge.
 - e) Overall thickness: **5/8 inch (15.9 mm)**.
 2. Glass Mat Gypsum Tile Backer:
 - a. Product meeting requirements of ASTM C1178/C1178M.
 - b. Type X, **5/8 inch (15.9 mm)**.
 - c. Square edges.
 - d. Category Four Approved Manufacturer. See Section 01 6200 for definitions of Categories:
 - 1) DensShield Fireguard Type X by Georgia Pacific.
 - 2) GlasRoc Tilebacker Type X by CertainTeed.

2.2 ACCESSORIES

A. Manufacturers:

1. Manufacturer Contact List:
 - a. Kinetics Noise Control, Dublin, OH www.kineticsnoise.com.
 - b. Magnum Products, Lenaxa, KS www.levelcoat.com.
 - c. National Gypsum, Charlotte, NC www.nationalgypsum.com.
 - d. Soundproofing Co, San Marcos, CA www.soundproofing.org.
 - e. United States Gypsum Co, Chicago, IL www.usg.com.
 - f. Westpac Materials Inc, Orange, CA www.westpacmaterials.com.
 - g. Wm. Zinsser & Co, Somerset, NJ www.zinsser.com.
2. Gypsum Board Mounting Accessories:
 - a. Furring Channels:
 - 1) Class Two Quality Standards. See Section 01 6200 for definitions:
 - a) Walls: Galvanized DWFC-25.
 - b) Ceilings: Galvanized DWFC-20.
 - 2) Accessories as required by Manufacturer's fire tests to provide necessary fire ratings.
 - b. Corner And Edge Trim:
 - 1) Metal, paper-faced metal, paper-faced plastic, or solid vinyl meeting requirements of ASTM C1047. Surfaces to receive bedding cement treated for maximum bonding.
 - c. Control Joint:
 - 1) Bent zinc sheet with V-shaped slot, perforated flanges, covered with plastic tape meeting requirements of ASTM C1047.

3. Joint Compound:
 - a. Best grade or type recommended by Board Manufacturer and meeting requirements of ASTM C475/C475M.
 - 1) Use Taping Compound for first coat to embed tape and accessories.
 - 2) Use Taping Compound or All-Purpose Compound for subsequent coats except final coat.
 - 3) Use Finishing Compound for final coat and for skim coat.
 4. Joint Reinforcing:
 - a. Paper reinforcing tape acceptable to Gypsum Board Manufacturer.
 5. Fasteners:
 - a. Bugle head screws meeting requirements of ASTM C1002:
 - 1) Gypsum Board:
 - a) Type W: For fastening gypsum board to wood members, of length to penetrate wood framing **5/8 inch (15.9 mm)** minimum.
 - b) Type S: For fastening gypsum board to steel framing and ceiling suspension members, of length to penetrate steel framing **3/8 inch (9.5 mm)** minimum.
 - 2) Glass Mat Gypsum Tile Backer:
 - a) Wood Framing: **11 ga (0.1233 in) (3.1318 mm)**, galvanized with **7/16 inch (11 mm)** head, hot dipped. Screws: Type W or Type S Hi-Lo, bugle head, rust resistant.
 - b) Metal Framing:
 - (1) Light-gauge metal framing: Type S Hi-Lo, bugle or wafer head, self-tapping, rust resistant. Hi-Lo screws.
 - (2) Heavy-gauge metal framing: Type S-12 Hi-Lo, bugle or wafer head, rust resistant.
- B. Primer / Surfer On Surfaces To Receive Texturing:
1. Type Two Acceptable Products:
 - a. Sheetrock First Coat by USG.
 - b. Prep Coat by Westpac Materials.
 - c. Level Coat by Magnum Products.
 - d. Equal as approved by Architect before bidding. See Section 01 6200.
- C. Primer On Surfaces To Receive Wallcovering:
1. White, self-sizing, water based, all purpose wallcovering primer.
 2. Type Two Acceptable Products:
 - a. Shieldz Universal Pre-Wallcovering Primer by Wm. Zinsser and Company.
 - b. Equal as approved by Architect before application. See Section 01 6200.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification Of Conditions:
1. Examine substrate and verify framing is suitable for installation of gypsum board.
 2. Examine gypsum board before installation. Reject panels that are wet, moisture damaged, and mold damaged.
 3. Notify Architect of unsuitable conditions in writing.
 - a. Do not install board over unsuitable conditions.
 4. Commencement of Work by installer is considered acceptance of substrate.

3.2 INSTALLATION

- A. Interface With Other Work:
1. Coordinate with Division 06 for location of backblocking for edges and ends of gypsum board and for blocking required for installation of equipment and building specialties.

2. Do not install gypsum board until required blocking is in place.

B. General: Install and finish as recommended in ASTM C840 or GA-216 unless specified otherwise in this Section.

C. Mounting Accessories:

1. Furring Channels: Apply with screws through flanges into each framing member.

D. Interior Gypsum Board:

1. General:

- a. Install so trim and reinforcing tape are fully backed by gypsum board. No hollow spaces between pieces of gypsum board over **1/8 inch (3 mm)** wide before taping are acceptable.
- b. Rout out backside of gypsum board to accommodate items that extend beyond face of framing, but do not penetrate face of gypsum board, such as metal door frame mounting brackets, etc.
- c. On walls over **108 inches (2 700 mm)** high, apply board perpendicular to support
- d. Butt edges in moderate contact. Do not force in place. Shim to level.
- e. Leave facings true with joint, finishing flush. Vertical work shall be plumb and ceiling surfaces level.
- f. Scribe work closely:
 - 1) Keep joints as far from openings as possible.
 - 2) If joints occur near an opening, apply board so vertical joints are centered over openings.
 - 3) No vertical joints shall occur within **8 inches (200 mm)** of external corners or openings.
- g. Install board tight against support with joints even and true. Tighten loose screws.
- h. Caulk perimeter joints in sound insulated rooms with specified acoustical sealant.

2. Ceilings:

- a. Apply ceilings first using minimum of two (2) men.
- b. Use board of length to give minimum number of joints.
- c. Apply board perpendicular to support.

3. Fastening:

- a. Apply from center of board towards ends and edges.
- b. Apply screws **3/8 inch (9.5 mm)** minimum from ends and edges, **one inch (25 mm)** maximum from edges, and **1/2 inch (13 mm)** maximum from ends.
- c. Spacing:
 - 1) Ends: Screws not over **7 inches (175 mm)** on center at edges where blocking or framing occurs.
 - 2) Wood Framed Walls And Ceilings: Screws **7 inches (175 mm)** on center in panel field.
 - 3) Metal Framed Walls: Screws **12 inches (300 mm)** on center in panel field.
- d. Set screw heads **1/32 inch (0.8 mm)** below plane of board, but do not break face paper. If face is accidentally broken, apply additional screw **2 inches (50 mm)** away.
- e. Screws on adjacent ends or edges shall be opposite each other.
- f. Drive screws with shank perpendicular to face of board.

4. Trim:

a. Corner Beads:

- 1) Attach corner beads to outside corners.
 - a) Attach metal corner bead with staples spaced **4 inches (100 mm)** on center maximum and flat taped over edges of corner bead. Also, apply screw through edge of corner bead where wood trim will overlay corner bead.
 - b) Set paper-faced trim in solid bed of taping compound.
- 2) Corner beads to be rounded to match existing outside corners in building.

b. Edge Trim: Apply where gypsum board abuts dissimilar material. Hold channel and 'L' trim back from exterior window and door frames **1/8 inch (3 mm)** to allow for caulking.

5. Finishing:

a. General:

- 1) Tape and finish joints and corners throughout building as specified below to correspond with final finish material to be applied to gypsum board. When sanding, do not raise nap of gypsum board face paper or paper-faced trim.

- 2) First Coat:
 - a) Apply tape over center of joint in complete, uniform bed of specified taping compound and wipe with a joint knife leaving a thin coating of joint compound. If metal corner bead is used, apply reinforcing tape over flange of metal corner bead and trim so half of tape width is on flange and half is on gypsum board.
 - b) Completely fill gouges, dents, and fastener dimples.
 - c) Allow to dry and sand lightly if necessary to eliminate high spots or excessive compound.
 - 3) Second Coat:
 - a) Apply coat of specified joint compound over embedded tape extending **3-1/2 inches (88 mm)** on both sides of joint center. Use finishing compound only if applied coat is intended as final coat.
 - b) Re-coat gouges, dents, and fastener dimples.
 - c) Allow to dry and sand lightly to eliminate high spots or excessive compound.
 - 4) Third Coat: Apply same as second coat except extend application **6 inches (150 mm)** on both sides of joint center. Allow to dry and sand with fine sandpaper or wipe with damp sponge.
 - 5) Fourth Coat: Apply same as second coat except extend application **9 inches (425 mm)** on both sides of joint center. Allow to dry and sand with fine sandpaper or wipe with damp sponge.
- a. Finishing Levels: Finish panels to levels indicated below and according to ASTM C840, GA-214 and GA-216:
- 1) Gypsum Board Surfaces to Receive: Painted Texturing - Section 09 9413: 'Interior Textured Finishing':
 - a) GA-214 Level 4: 'All and interior angles shall have tape embedded in joint compound and two separate coats of joint compound applied over all flat joints and one separate coat of joint compound applied over interior angles. Fastener heads and accessories shall be covered with three separate coats of joint compound. All joint compound shall be smooth and free of tool marks and ridges. Coat prepared surface with specified primer'.
 - 2) Gypsum Board Surfaces to Receive: Smooth Gypsum Board Surfaces:
 - a) GA-214 Level 4: 'All and interior angles shall have tape embedded in joint compound and two separate coats of joint compound applied over all flat joints and one separate coat of joint compound applied over interior angles. Fastener heads and accessories shall be covered with three separate coats of joint compound. All joint compound shall be smooth and free of tool marks and ridges. Coat prepared surface with specified primer'.
 - 3) Painted, Untextured Gypsum Board Surfaces, Except in Mechanical, Storage, And Utility Areas:
 - a) GA-214 Level 5: 'All joints and interior angles shall have tape embedded in joint compound and two separate coats of joint compound applied over flat joints and one separate coat of joint compound applied over interior angles. Fastener heads and accessories shall be covered with three separate coats of joint compound. A thin skim coat of joint compound trowel applied, or a material manufactured especially for this purpose and applied in accordance with manufacturer's recommendations, shall be applied to the entire surface. The surface shall be smooth and free of tool marks and ridges. Coat prepared surface with specified primer'.
- E. Glass Mat Gypsum Tile Backer:
1. Apply glass mat gypsum tile backer to framing. Attach using specified fasteners spaced **6 inches (150 mm)** on center on edges and into all framing members. Drive screws flush with surface of board.
 2. Shim board to be plumb and flat or level and flat, depending on location.
 3. Apply reinforcing only at joints where abutting different materials.

3.3 FIELD QUALITY CONTROL

A. Non-Conforming Work:

1. Remove and replace panels that are wet, moisture damaged, and mold damaged.
 - a. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.
 - b. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

3.4 CLEANING

- A. Remove from site debris resulting from work of this Section including taping compound spills.

END OF SECTION

BLANK PAGE

SECTION 09 6816**SHEET CARPETING: Back Cushion, Direct Glue****PART 1 - GENERAL****1.1 SUMMARY**

- A. Section Includes But Is Not Limited To:
1. Coordination, sequencing, and scheduling installation of Owner-Furnished carpet, carpet base, carpet accessories, leveling compounds as described in Contract Documents and including following:
 - a. Pre-Installation Conference held in conjunction with Section 09 6813.
 - b. Maintain Building Ambient Conditions including normal levels of humidity, lighting, heating, and air conditioning for acceptability for beginning floor preparation and carpet installation.
 - c. Protection of carpet after installation of carpeting as required.
- B. Products Installed But Not Furnished Under This Section:
1. Carpet Tile.
- C. Related Requirements:
1. Section 01 1200: 'Multiple Contract Summary' for carpet and carpet base excluded from Contract and furnished and installed by Owner. This Section establishes quality of materials and installation for information of Contractor, Architect, and Owner's Representatives.
 2. Section 03 3111: 'Cast-In-Place Structural Concrete' for provision of acceptable concrete substrate.
 3. Section 09 0503: 'Flooring Substrate Preparation' for:
 - a. Floor substrate preparation.
 - b. Pre-installation conference for Sections under 09 6000 heading 'Flooring'.

1.2 REFERENCES

- A. Association Publications:
1. The Carpet and Rug Institute (CRI), Dalton, GA www.carpet-rug.org. Standard for Installation Specification of Commercial Carpet:
 - a. CRI Indoor Air Quality (IAQ):
 - 1) CRI Green Label Plus Certification.
- B. Reference Standards:
1. The Carpet and Rug Institute (CRI):
 - a. CRI 104, 'Standard For Installation of Commercial Carpet' (Sept 2015).
 - b. CRI TM-102, 'School Carpet Minimum Average Specifications'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
1. Coordinate completion of carpet installation with other trades.
- B. Pre-Installation Conference:
1. Participate in MANDATORY pre-installation conference as specified in Section 09 0503 and held jointly with Section 09 6813 pre-installation conference.
 2. Schedule pre-installation conference before installation of flooring system.
 3. Conference may be held at project site or another convenient site. Participants may also attend by video or audio conference if approved by Project Manager.

4. Schedule conference after substrate preparation and ONE (1) week before installation of flooring system.
 5. In addition to agenda items specified Section 01 3100 and Section 09 0503, review following:
 - a. Review Owner's Representative schedule for furnishing and installation carpet.
 - b. Review Flooring Manufacturer's installation conditions verification procedure and requirements.
 - c. Review Building Ambient Conditions including normal levels of humidity, lighting, heating, and air conditioning for acceptability for beginning floor preparation and carpet installation.
 - d. Review cleaning and disposal requirements.
 - e. Review protection requirements of carpet after installation of carpeting.
- C. Scheduling:
1. Notify Flooring Installer when Building Ambient Conditions requirements are met before installation of flooring system.
 2. Notify Owner's Representative to coordinate installation of carpet.

1.4 SUBMITTALS

- A. Closeout Submittals:
1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Warranty Documentation:
 - 1) Copy of Warranty.
 - b. Record Documentation:
 - 1) Owner will provide Project Carpet Request Documentation forms in both hard copy and digital format:
 - a) Carpet Request Information Sheet.
 - b) Carpet Vendor Quotation.
 - c) Carpet Preinstallation Meeting Agenda.
 - d) Carpet Installation Notice to Proceed or Cancel.
 - e) Carpet Inspection and Completion.
 - f) Carpet Overage Report and Completion.
 - g) Carpet Quotation Change Request.
- B. Maintenance Material Submittals:
1. Extra Stock Materials:
 - a. Leave excess pieces of carpet, **6 feet square (1 800 sq mm)** or larger and **25 lineal feet (7.620 m)** minimum of carpet cove base.
 - b. Roll up and tie securely.

1.5 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
1. All products provided will meet requirements of all federal, state, and local codes having jurisdiction.
 2. Label meeting Federal Labeling Requirements, as stated in Textile Products Identification Act under Federal Trade Commission, shall be attached to certification samples and products delivered.
- B. Qualifications: Section 01 4301 applies, but is not limited to following:
1. Carpet Installer Qualifications:
 - a. Certified CFI Master or Contract II grade installer or FCIB certified.
 - b. Not less than five (5) years of experience in installation of commercial carpet tile of type, quantity and installation methods similar to work of this section.
 - c. Qualified and approved by Carpet Manufacturer.
 2. Carpet Manufacturer Qualifications:
 - a. Not less than five (5) years of production experience, whose published literature clearly indicates general compliance of products with requirements of this section.

- b. Category One Approved Carpet Manufacturers:
 - 1) Approval subject to agreement process approval.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. General:
 1. Comply with instructions and recommendations of Manufacturer for special delivery, storage, and handling requirements.
- B. Delivery And Acceptance Requirements:
 1. Deliver materials and accessories necessary for completion of carpet installation to site before beginning installation of carpet.
 2. Do not deliver materials before date scheduled for installation.
 3. Transport carpet in manner that prevents damage and distortion. Bending or folding individual carpet rolls or cuts from rolls is not recommended. When bending or folding is unavoidable for delivery purposes, carpet is required to be unrolled and allowed to lie flat immediately upon arrival at installation site.
- C. Storage And Handling Requirements:
 1. Store carpet and related materials in a climate-controlled, dry space.
 2. Protect carpet from soil, dust, moisture and other contaminants and store on a flat surface.
 3. Stacking heavy objects on top of carpet rolls or stacking more than three rolls is prohibited.

1.7 FIELD CONDITIONS

- A. Ambient Conditions:
 1. Building Conditions:
 - a. Conditions inside building shall be brought to levels to be normal at occupancy of building. Conditions include normal levels of humidity, lighting, heating, and air conditioning. (HVAC must be in operation thru out carpet installation):
 - 1) Carpet installation is not to begin until HVAC system is operational and following conditions are maintained for at least forty-eight (48) hours before, during and seventy-two (72) hours after completion:
 - a) Carpet is to be installed when indoor temperature is between 65° - 95° F (18° - 35° C) with maximum relative humidity of 65%.
 - b) Substrate surface temperature should not be less than 65° F (18° C) at time of installation.
 - c) Do not allow temperature of indoor carpeted areas to fall below 50° F (10° C), regardless of age of installation.
 - 2) Maintain fresh air ventilation after installation for seventy-two (72) hours minimum or until lingering odors are gone.
 2. Concrete Slab:
 - a. General:
 - 1) Do not install carpet over concrete slabs until slabs have cured and are sufficiently dry to bond with adhesive.

1.8 WARRANTY

- A. Manufacturer Warranty:
 1. Provide Carpet Manufacturer's standard Warranty which includes following:
 - a. Warranty shall cover defects in installation, workmanship, and installation materials.
 - b. Warranty includes specific workmanship warranties for delamination, edge raveling, fuzzing, pilling, and other textural changes which can be controlled through proper manufacturing (no fraying, zippering, delamination, edge raveling, fuzzing, pilling in carpet is acceptable for any reason).

- c. Warranty terms will include inspection of defective area within fifteen (15) days of receipt of written notice from Owner and completion of corrective work within forty-five (45) days, unless other arrangements are made in writing with Owner on case-by-case basis.
 - d. Carpet defect or installation defect:
 - 1) Carpet Manufacturer may use any reasonable means to cure first three (3) breaches of warranty affecting an area of carpeting bounded by natural breaks such as doorways, stairs, rostrum and platform ('affected carpet area'). Such cure must preserve as uniform a blended appearance, acceptable to Carpet Manufacturer and Owner, as exists throughout Installation Site at time of breach.
 - 2) If carpet defect or installation defect continues to appear after three (3) separate notices for correction from Owner, replace carpet where defects have occurred.
 - e. If Carpet Manufacturer follows installation requirements of Section 09 0503 'Floor Substrate Preparation' Carpet Manufacture accepts liability of carpet installation for said given time as outlined in Special Warranty regardless of any climate or condition changes affecting RH levels of floor substrate.
2. Special Warranty:
 - a. Sheet Carpeting:
 - 1) General:
 - a) Appearance Retention to be provided with Special Warranty requirements if not already included in Standard Warranty.
 - 2) Meetinghouse, Mission Office, and O&M / R&I:
 - a) Owner Carpet Program Product: Provide twenty (20) year minimum or Carpet Manufacturer's better Warranty on carpet system.

PART 2 - PRODUCTS

2.1 OWNER-FURNISHED PRODUCTS

1. Carpet:
 - a. Category One Approved Manufacturer and Color / Patterns. See Section 01 6200 for definitions of Categories:
 - 1) Mannington:
 - a) New Horizon, Color: New Grove.
 - b) New Horizon, Color: New Medallion.
 - c) New Horizon, Color: New Seasons.
 - d) New Horizon, Color: New Ocean
 - 2) Mohawk:
 - a) Nauvoo II, Color: 407 Columbine II.
 - b) Nauvoo II, Color: 121 Forest II.
 - c) Nauvoo II, Color: 405 Bountiful II.
 - d) Nauvoo II, Color: 417 Meadow II.
 - 3) Tandus Centiva:
 - a) Style 04425 Ensign II, Color: Emerald II #85669.
 - b) Style 04346 Ensign II, Color: Garnet II #81096.
 - c) Style 04448 Ensign II, Color: Jasper II #85670.
 - d) Style 04346 Ensign II, Color: Sapphire II #86653.
2. Carpet Base:
 - a. **4-1/2 inch (115 mm)** wide base without cushion backing:
 - 1) Top edge of base serged with **1-1/4 inch (32 mm)** polyester binding fabric.
 - 2) Roll edges of binding fabric under and sew along top edge of carpet cove base.
 - b. Carpet:
 - 1) Category One Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Mannington: Ultrabac RE, Color: Black.
 - b) Bigelow Commercial (Mohawk): Spectrum V30, Color: 7234 Ebony Domino.
 - c) Tandus Centiva: Abrasive Action II, Color: Winter Gray 19103.

2.2 ACCESSORIES

- A. Carpet Accessories: Snap-in vinyl reducer strips and vinyl track.
- B. Floor Leveling Compound, Floor Patching Compound, And Latex Underlayment: As recommended and approved by Carpet Manufacturer.

PART 3 - EXECUTION

3.1 APPROVED INSTALLER

- A. Same installer of Section 09 6816: 'Sheet Carpeting' shall install Section 09 6813: 'Tile Carpeting'.

3.2 EXAMINATION

- A. Verification of Conditions:
 - 1. Verify required ambient conditions inside building for required normal levels of humidity, lighting, heating, and air conditioning have been maintained for at least forty-eight (48) hours before and during carpet installation and seventy-two (72) after installation of carpet.
- B. Evaluation And Assessment:
 - 1. Carpet Areas:
 - a. Variation In Grade:
 - 1) Plus or minus **1/8 inch (3 mm)** in any **10 foot (3 meter)** of floor slab and distance between high point and low point of slab of **1/2 inch (13 mm)**.
 - b. Testing Procedure:
 - 1) Place ends of straightedge on **3/8 inch (10 mm)** high shims.
 - 2) Floor is satisfactory if **1/4 inch (6 mm)** diameter steel rod rolled under straightedge will not touch anywhere along **10 foot (3 meter)** length and **1/2 inch (13 mm)** diameter steel rod will not fit under straightedge anywhere along **10 foot (3 meter)** length.
 - c. Notify Owner's Representative in writing if floor surface is not acceptable to install carpet:
 - 1) Do not lay carpet over unsuitable surface. Commencing installation constitutes acceptance of floor and approval of existing conditions.

3.3 PREPARATION

- A. Carpet Areas:
 - 1. Flooring Preparation:
 - a. Owner-Furnished Product Supplier's Responsibility:
 - 1) Prepare floor substrate in accordance with 'CRI Carpet Installation Standard' best practices to receive carpet installation and to provide installation that meets warranty requirements.
 - 2) Verify concrete surface cured, clean, dry, and free of foreign substances that will compromise carpet and/or installation.
 - b. Concrete floor slab patching:
 - 1) Cracks, chips and joints must be properly patched or repaired.
 - c. Concrete surface cured, clean, dry, and free of foreign substances that will compromise carpet and/or other flooring installations:
 - 1) Removal of curing compounds.
 - 2) Remove paint, sealer, grease, oil, silicone sealants, and other materials incompatible with flooring adhesives.
 - 3) Removal of overspray from painted walls (essential so glue will stick).
 - d. Vacuum and damp mop floor areas to receive flooring before flooring installation.
 - 2. Relaxing / Conditioning Carpet:

- a. Highly recommended that carpet be unrolled and allowed to relax in installation area for time period that conforms to requirements of manufacturer of product being installed:
 - b. Protect carpet adequately from soil, dust, moisture and other contaminants.
 - c. Sundry items, such as adhesives, should also be conditioned.
3. Carpet Accessories:
- a. Owner-Furnished Product's Responsibility:
 - 1) Sundry items, such as adhesives, shall be conditioned to building ambient conditions before use.

3.4 INSTALLATION

A. Carpet:

1. General:
 - a. Install carpet and carpet base in accordance with 'CRI Carpet Installation Standard' and Manufacturer's written instructions supplied with product.
 - b. Adhesion of carpet cushion (or secondary backing) to floor substrate and adhesion of carpet primary and secondary backings shall be continuous on floor surface so there are no bubble, ridges, or any separation of carpet from backings or backing from floor substrate caused by failure of carpet, backings or cushion, and adhesives as a system.
 - c. Install carpet under edge of metal thresholds where possible. Use specified carpet accessories at exposed edges.
2. Seaming Requirements:
 - a. Seal seams in accordance with Carpet Manufacturer's instructions and according to CRI Carpet Installation Standard (2009) as applicable. Seam carpet base only at inside corners.
 - b. No seam separation in carpet and no more observable seams from any standing position than that which is unavoidable using best seaming materials and practices available at time of installation.
 - c. Lay rooms parallel to respective Corridors. Seam to permit best use of available carpet.
 - d. Quarter turning allowed only at cross-Corridors longer than **24 feet (7.315 m)**.
 - e. Use single or double seams at doorways (single seams preferred). Run nap of pieced carpet in same direction.
 - f. Carpet over Stairs must be laid in Manufactured roll sequence to coordinate with surrounding carpet on floors. Double fill and end seams should be avoided whenever possible.

B. Carpet Base:

1. Precut base so seams occur only at inside corners.
2. Scribe base to floor.
3. Spread adhesive over back side of base up to bottom of serging on edge or apply three **3/16 inch (4.76 mm)** minimum diameter beads of adhesive placed one inch apart on back of base with top bead placed **2 inch (50 mm)** down from serged edge of base and spread adhesive over back surface of base up to bottom edge of serging.
 - a. Bird's mouth finish should only be required when door frame is flush with wall.
 - b. If bird's mouth is required, terminate at door frames or vertical trim with 45 degree angle, bird mouth cut so serged edge turns down to contact frame or trim.
4. Do not allow adhesive beyond edge of base. Remove excess adhesive.
5. Do not use staples, nails, screws or other mechanical fasteners.

3.5 FIELD QUALITY CONTROL

A. Field Inspections:

1. Carpeting:
 - a. Unacceptable carpet after installation shall include but not be limited to:
 - 1) Delaminating carpet from backings.
 - 2) Fiber loss less than specified.
 - 3) Edge raveling.
 - 4) Fuzzing of carpet fibers.

- 5) Pilling of carpet fibers.
 - 6) Appearance retention less than control samples attached to Agreement.
 - 7) Dye bleeding.
 - 8) Zippering fibers in carpet.
 - 9) Color streaking.
 - 10) Irregular tufts of fiber.
- b. Unacceptable workmanship shall include but not be limited to:
- 1) Improper floor preparation before installation.
 - 2) Failure of adhesive to completely adhere carpet to floor resulting in bubbles, ridges, or ripples where carpet has separated from floor.
 - 3) Seams that do not comply with specified requirements:
 - a) Raveled or untrimmed seams.
 - b) Seams not sealed, level, straight, or even.
 - c) Open seams.
 - d) Seams visibly open when viewed by Project Manager from standing position.
 - 4) Sequence rolls, commercial match issues created by rolls being installed out of sequence will require correction or replacement.
 - 5) Failure to properly install carpet next to walls and door frames to eliminate gaps or puckering of carpet.
 - 6) Use of unspecified carpet.
 - 7) Carpet base ends not finished to terminate at door frames or vertical trim shall have 45 degree angle 'birdsmouth' finish.
 - 8) Adhesive exposed on carpet, on carpet base, beyond edges of carpet base, and on other surfaces of building.
 - 9) Carpet base that is not scribed to fit against floor with no gaps.
 - 10) Carpet base attached by means other than acceptable carpet base adhesive.
- B. Non-Conforming Work:
1. Carpeting:
 - a. Basis of Acceptable Carpeting: Source Quality Control Testing:
 - 1) Carpet products not meeting Design Criteria and Source Quality Control Testing of this specification will be considered unacceptable carpeting.
 - b. Unacceptable Carpeting:
 - 1) Unacceptable carpeting will be rejected and shall be repaired or replaced at no additional cost to Owner. Owner's Representative will determine reasonable location of acceptable transition points for removal of unacceptable carpet. Minimum replacement size shall be:
 - a) Between nearest existing seams.
 - b) Between natural transition points or **12 feet (3.6 meters)** of running length.

3.6 CLEANING

- A. General:
1. Carpeting:
 - a. Carpet Installer's Responsibility:
 - 1) Remove any soiling and/or staining from carpet.
 - 2) Remove excessive adhesive with manufacturer recommended adhesive removers.
 - b. Stair Treads:
 - 1) Carpet Installer's Responsibility:
 - a) Clean all exposed surfaces of stair treads of adhesive spatter before it sets in accordance with Manufacturer's cleaning instructions.
- B. Damage to building:
1. Carpeting:
 - a. Carpet Installer's Responsibility:
 - 1) Carpet Installer responsible for cleaning and repair of all damaged surfaces to their original condition from carpet installation.
- C. Waste Management:

1. Contractor's Responsibility:
 - a. Provide adequate waste receptacles (dumpsters) and dispose of Owner Furnished materials from building and property as specified in Section 01 7400.
2. Carpet Installer's Responsibility:
 - a. All work areas are to be kept clean, clear and free of debris at all times.
 - b. Disposal of rubbish, wrapping paper, scraps, and trimmings in provided dumpster(s).

3.7 PROTECTION

- A. Protection of Carpeting:
 1. Contractor's Responsibility:
 - a. No traffic of any kind on newly installed carpet for minimum of twenty-four (24) hours after installation is completed.
 - b. No wheeled traffic of any kind placement of furniture or equipment on carpet for minimum of forty-eight (48) hours after completion of carpet installation.
 - c. Protect carpet adequately from soil, dust, moisture and other contaminants after carpet installation.
 - d. Protect carpet from abuse, vandalism, or damage occurring after installation is complete.

END OF SECTION

SHEET CARPETING DESIGN CRITERIA (Back Cushion, Direct Glue)

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Design Criteria Requirements of Owner-Furnished carpet and carpet base as specified in Section 09 6816: 'Sheet Carpeting' in contract documents of Church Specifications:
 - a. Design Criteria Requirements are not included in Project Manual Specifications for site adapted Church Projects.
- B. Related Requirements:
 - 1. Section 09 6813: 'Tile Carpeting'.
 - 2. Section 09 6816: 'Sheet Carpeting'.

1.2 REFERENCES

- A. Association Publications:
 - 1. The Carpet and Rug Institute (CRI), Dalton, GA www.carpet-rug.org. Standard for Installation Specification of Commercial Carpet:
 - a. CRI Indoor Air Quality (IAQ):
 - 1) CRI Green Label Plus Certification.
- B. Definitions:
 - 1. Adhesive: Substance that dries to film capable of holding materials together by surface attachment.
 - 2. Antimicrobial: Chemical treatment added to carpet or reduce growth of common bacteria, fungi, yeast, mold and mildew.
 - 3. Appearance Retention: Ability of a fabric to retain its original aesthetics, color, and construction integrity.
 - 4. Backing: Materials comprising back of carpet as opposed to carpet pile or face.
 - a. Tufted carpets: (1) Primary backing, woven or nonwoven fabric in which pile yarn is inserted by tufting needles. (2) Secondary backing, Fabric laminated to back of carpet to reinforce and increase dimensional stability.
 - b. Woven carpets: Backings are 'construction yarns' comprising chain warp, stuffer warp, and shot or fill, which are interwoven with face yarn during carpet fabric formation.
 - 5. Backing Fabric: Fabric into which pile yarn is inserted or reinforcing layer that is adhered to reverse side of fabric.
 - 6. Bonding Agent (Backcoating): Application of latex or adhesive to back of carpet to anchor tufts usually followed immediately by addition of secondary backing material such as nonwoven polypropylene or poly-urethane attached cushion.
 - 7. Carpet: Heavy fabric used to cover floor and made from variety of fibers.
 - 8. Change In Surface Appearance: Cumulative change in surface appearance between unexposed and exposed specimens due to crushing, loss of tuft definition, and matting.
 - 9. Colorfastness: Ability of fiber or carpet to retain color when exposed to (1) ultraviolet light, (2) crocking (wet or dry) and (3) atmospheric conditions.
 - 10. Commercial Match: Matching of colors with acceptable tolerance, or with color variation that is barely detectable to naked eye.
 - 11. Crockfastness: Resistance of transfer of colorant from surface of colored yarn or fabric to another surface, or to an adjacent area of same fabric, principally by rubbing.
 - 12. Crushing: Collapsing of pile yarns, resulting in carpet matting and loss of resilience due to traffic.
 - 13. Delamination: Form of deterioration of tufted carpet in which primary back and face yarns separate from secondary back.

14. Density: Amount of pile yarn per area of carpet or closeness of tufts. Higher density carpet improves resistance to crushing and matting.
15. Dimensional Stability: Ability of carpet to retain its size and shape once installed.
16. Face Weight: Total weight of face (above backing) yarns in carpet.
17. Fiber: Fundamental unit of carpet made from nylon, polyester, cotton, acrylics, wool, and recycled material.
18. Flammability: Procedures that have been developed for assessing flame resistance of carpets.
19. Foot Traffic Classification: Process that classifies areas of intended use and minimum carpeting texture appearance for particular areas of use established for each application based on level of expected foot traffic in specific areas. Classifications are Moderate, Heavy and Severe.
20. Fuzzing: Fluffy particles appear on carpet surfaces caused by fibers that loosen because of weak twist or snags.
21. Lightfastness: Degree of resistance of dyed textile materials to color destroying influence of sunlight.
22. Loss of Tuft Definition: Bursting, opening, and untwisting of pile yarn and/or decrimping of fibers in surface pile of pile yarn floor covering.
23. Matting: Loss of pile definition of a textile floor covering due to entanglement and compression of pile fibers.
24. Modification Ratio: Ratio between circumference of inner core of multi lobar fiber's cross section, and circumference of circle drawn around outer edges of fibers cross sections' outer lobes or tips.
25. Pile: Visible surface of carpet, consisting of yarn tufts in loop and/or cut configuration. Sometimes called face or nap.
26. Relative Humidity (RH) Testing: Testing of concrete slabs is defined as ratio of actual amount of water vapor present in volume of air at given temperature to maximum amount that air could hold at that temperature, expressed as percentage.
 - a. Relative Humidity test method covers quantitative determination of percent relative humidity in concrete slabs for field or laboratory tests.
 - b. Moisture test results indicate moisture condition of slab only at time of test.
27. Resilience: Ability of carpet to spring back to its original texture and thickness after being walked on or compressed weight of furniture.
28. Soil Resistance: Ability of carpet fiber to resist dry soil and maintain its original appearance after intermittent or restorative cleanings.
29. Soiling: Occurs when dirt particles build up in carpet fibers.
30. Stain Resistance: Ability of carpet fiber to resist absorption of stain and maintain its original appearance.
31. Texture: Visual and tactile surface characteristics of carpet pile, including such aesthetic and structural elements.
32. Tile: Carpet module usually 18 inch x 18 inch or 24 inch x 24 inch (450 mm x 450 mm or 600 mm x 600 mm) in size. Extremely dense construction with heavy reinforced backing.
33. Tuft: Cluster of yarns drawn through fabric and projecting from surface in form of cut yarns or loops.
34. Tuft Bind: Force (usually measured in pounds) required to pull tuft from carpet backing.
35. Tufted Carpet: Carpet produced by tufting machine instead of loam.
36. Twist: Winding of yarn around itself. More twist improves carpet performance (especially in cut pile).
37. Woven Carpet: Carpet produced on a loom through weaving process by which lengthwise (warp) yarns and widthwise (weft or filling) yarns are interlaced to form fabric.
38. Woven: Interlacing strands of fiber into yarn forms woven carpet.
39. Yarn: Fibers that are twisted together to form a continuous strand.

C. Reference Standards:

1. American Association of Textile Chemists and Colorists (AATCC):
 - a. Test Method:
 - 1) AATCC 16.3-2014, 'Colorfastness to Light: Xenon-Arc'.
 - 2) AATCC 107-2013, 'Colorfastness to Water'.
 - 3) AATCC 134-2011, 'Electrostatic Propensity of Carpets'.
 - 4) AATCC 165- 2013, 'Colorfastness to Crocking: Textile Floor Coverings--Crockmeter Method'.
 - 5) AATCC 174-2011, 'Antimicrobial Activity Assessment of Carpets'.
 - 6) AATCC 175-2013, 'Stain Resistance: Pile Floor Coverings'.

2. ASTM International:
 - a. ASTM D1335-17, 'Standard Test Method for Tuft Bind of Pile Yarn Floor Coverings'.
 - b. ASTM D2646-18, 'Standard Test Methods for Backing Fabric Characteristics of Pile Yarn Floor Coverings'.
 - c. ASTM D3676-13, 'Standard Specification for Rubber Cellular Cushion Used for Carpet or Rug Underlay'.
 - d. ASTM D3936-17, 'Standard Test Method for Resistance to Delamination of the Secondary Backing of Pile Yarn Floor Covering'.
 - e. ASTM D5116-17, 'Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions From Indoor Materials/Products'.
 - f. ASTM D5252-15, 'Standard Practice for the Operation of the Hexapod Drum Tester'.
 - g. ASTM D5848-10, 'Standard Test Method for Mass Per Unit Area of Pile Yarn Floor Coverings'.
 - h. ASTM D6962-17, 'Standard Practice for Operation of a Roller Chair Tester for Pile Yarn Floor Coverings'.
 - i. ASTM D7330-15, 'Standard Test Method for Assessment of Surface Appearance Change in Pile Floor Coverings Using Standard Reference Scales'.
 - j. ASTM E648-17a, 'Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source'.
 - k. ASTM E662-17a, 'Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials'.
3. British Spill Test:
 - a. Test with protocol but not standardized test (Developed several years ago by West End Medical Association in Great Britain and since has been adopted by several U.S. Manufactures).
4. International Organization for Standardization (ISO).
 - a. ISO 2551:1981, 'Machine-made textile floor coverings - Determination of dimensional changes due to the effects of varied water and heat conditions'.
5. National Fire Protection Association (NFPA):
 - a. NFPA (Fire) 253, 'Standard Method of Test for Critical Radiant Flux of Floor Covering Systems using a Radiant Heat Energy Source' (2015 Edition).
6. The Carpet and Rug Institute (CRI):
 - a. CRI 104, 'Standard For Installation of Commercial Carpet' (Sept 2015).
 - b. CRI TM-101, 'Assessment of Carpet Surface Appearance Change using the CRI Reference Scales'.
 - c. CRI TM-102, 'School Carpet Minimum Average Specifications'.

1.3 SUBMITTALS

- A. Informational Submittals:
 1. Test And Evaluation Reports:
 - a. Provide Source Quality Control testing as specified in this specification if requested by Owner.
 2. Sustainable Design Submittals:
 - a. Provide documentation for compliance of Product Data for Credit EQ 4.3 if requested by Owner:
 - 1) For carpet and cushion, documentation indicating compliance with testing and product requirements of CRI's "Green Label Plus" program.

1.4 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 1. All products provided will meet requirements of all federal, state, and local codes having jurisdiction.
 2. Label meeting Federal Labeling Requirements, as stated in Textile Products Identification Act under Federal Trade Commission, shall be attached to certification samples and products delivered.

PART 2 - PRODUCTS

2.1 OWNER-FURNISHED PRODUCTS

- A. Category One Approved Manufacturers. See Section 01 6200 for definitions of Categories:
1. Materials supplied for carpet installation shall be complete package from specified Carpet Manufacturer:
 - a. Lees, Division of Mohawk Carpets, Glasgow, VA:
 - 1) Contact Information: Help Line (800) 523-5555 or (801) 397-5626.
 - b. Mannington Commercial Carpets, Calhoun, GA:
 - 1) Contact Information: Help Line Voice Mail (800) 241-2262, ext 8045 or Mannington Installation Services, email lds@mannington.com or (855) 466-2664.
 - c. Tandus Centiva: Dalton, GA www.tandus-centiva.com.
 - 1) Contact Information: Tracy Riddle - cell (801) 580-5147 fax (866) 861-7522
Tracy.Riddle@Tarkett.com.
- B. Design Criteria:
1. General:
 - a. Commercial Match:
 - 1) Colors, texture and pile of any product selected as carpet standard or custom designed specifically for Owner needs to be consistent in appearance.
 - 2) When new carpet is installed next to existing carpet, two pieces need to be within tolerance acceptable as commercial match (Two shade variations maximum).
 - 3) Regardless of reason, if commercial match is not achievable, existing carpet needs to be replaced to acceptable breaking point approved by Owner's Representative.
 - 4) If changes in supply chains or unforeseen circumstances require standard pattern to be re-engineered, new carpet must be made close to original as possible.
 - 5) New product must be approved by Owner.
 - b. Compatibility:
 - 1) Materials supplied for carpet installation shall be complete package from specified Carpet Manufacturer. Do not mix items from material packages of different carpet Manufacturers.
 - 2) Provide carpet, seam sealers, adhesives, and other related materials that are compatible with one another and with substrates under conditions of service and application.
 - c. Tested Products:
 - 1) New technology and products not allowed unless pre-approved by Owner.
 2. Carpet Material Requirements:
 - a. Carpet Backing:
 - 1) Broadloom - Attached Cushion.
 - a) Manufacturer's preference that meets or exceeds specification and life cycle warranty expectation.
 - b. Cushion Thickness:
 - 1) Attached cushion thickness shall be 0.10 inch minimum when tested in accordance with ASTM D3676.
 - c. Fiber:
 - 1) Meetinghouse, Mission Office, and O&M / R&I:
 - a) Antron Lumina and/or Legacy only.
 - 2) CES, S&I Module, and O&M / R&I:
 - a) Institute:
 - (1) Antron Lumina and/or Legacy only.
 - b) Seminary:
 - (1) Antron Lumina and/or Legacy only.
 - c) Antron Lumina and/or Legacy only.
 - 3) Bishop's Storehouse, Deseret Industries:
 - a) Office Areas:
 - (1) Antron Lumina and/or Legacy only.
 - b) Retail Space:
 - (1) Antron Lumina and/or Legacy only.

- d. Life Expectancy (Sheet Carpeting):
 - 1) Meetinghouse, Mission Office, and O&M / R&I: twenty (20) years minimum.
 - 2) CES, S&I Module, and O&M / R&I:
 - a) Institute: twenty-five (25) years minimum.
 - b) Seminary: twenty-five (25) years minimum.
 - 3) Bishop's Storehouse, Deseret Industries:
 - a) Office Areas: fifteen (15) years minimum.
 - b) Retail Space: ten (10) years minimum.
 - e. Modification Ratio:
 - 1) Meetinghouse, Mission Office, and O&M / R&I: 1.5 or less.
 - 2) CES, S&I Module, and O&M / R&I:
 - a) Institute: 1.5 or less.
 - b) Seminary: 1.5 or less.
 - 3) Bishop's Storehouse, Deseret Industries:
 - a) Office Areas: 1.5 or less.
 - b) Retail Space: 1.5 or less.
 - f. Pile Yarn Floor Construction:
 - 1) Meet standard for average pile yarn weight tested under ASTM D5848.
 - a) Carpet will retain eighty-five (85) percent of these amounts at end of the warranty period.
3. Carpet Physical Performance:
- a. Appearance Retention Requirements:
 - 1) Foot Traffic Classification and Testing Requirements:
 - a) Severe Traffic Criteria:
 - (1) Carpet is to be tested in accordance to ASTM D5252 with an Actionbac secondary backing meeting short term cycles (4000) grading scale of 3.5 and long-term cycles (12000) grading scale of 3.5 with appearance retention measured according.
 - (2) Carpet needs to be able to maintain 3.5 rating for eighty-five (85) percent of its warranty expected life cycle in accordance to ASTM D7330.
 - 2) Severe Traffic:
 - a) Meetinghouse, Mission Office, and O&M / R&I.
 - b) CES, S&I Module, and O&M / R&I.
 - c) Bishop's Storehouse, Deseret Industries:
 - (1) Office Areas.
 - (2) Retail Space.
 - b. British Spill Test:
 - 1) Carpet must pass British Spill Test (formally known as the National Health Service Patient Area Requirement for the United Kingdom, Method E: Part 2):
 - a) Test involves controlled spilling of blue dyed liquid from 1-meter (39 inches) height onto carpet product.
 - b) Spill is allowed to stand for period of twenty-four (24) hours, after which cuts are made through carpet in area of spill to establish whether there was penetration into or through carpet composite.
 - c. Colorfastness:
 - 1) Colorfastness to Crocking: AATCC 165:
 - a) Color transfer Class 4 minimum, wet and dry, when tested as specified.
 - 2) Colorfastness to Light: AATCC 16.3:
 - a) Not less than 4 after 40 AFU (AATCC fading units). Colorfastness to Light, Xenon-Arc (60 AFU) (AATCC Fading Unit).
 - 3) Colorfastness to Water: AATCC 107:
 - a) Color transfer Class 4 minimum, AATCC Transference Scale (only yarn dyed carpets) (grade change in color and staining).
 - d. Compression Resistance and Compression Set Attached Cushion:
 - 1) Minimum CLD of 7 lb per cu in (0.194 kg per cu cm) at 25 percent deflection, and maximum compression set of 10 percent after 50 percent constant compression when tested in accordance with ASTM D3676 with modification to allow recovery at 158 deg F (70 deg C) instead of room temperature for thirty (30) minutes.
 - e. Critical Radiant Flux (CRF):

- 1) Meet requirements of ASTM E648 Standard Test Method - Minimum Class 1 Critical Radiant Flux (CRF) of 0.45 watts/cm² or greater when tested in accordance with flooring radiant panel test using ASTM E648 Standard Test Method for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source as the test method.
- f. Delamination:
 - 1) Resistance to Delamination (Actionbac secondary backing): Not less than 3.5 lbf/in (15 N/mm) when tested in accordance with ASTM D3936.
 - 2) Resistance to Delamination (Attached Cushion): Not less than 15,000 cycles when tested in accordance with ASTM D6963.
- g. Dimensional Stability:
 - 1) 0.2 percent or less when tested in accordance with ISO 2551, 'Dimensional Stability (Aachen Test)'.
- h. Dry Breaking Strength:
 - 1) Not less than 100 lbs (445 N) when tested in accordance with ASTM D2646.
- i. Electrostatic Propensity of Carpets:
 - 1) Electrostatic shock propensity with maximum 3.5 kV when tested in accordance with AATCC 134, 'Step Method'.
- j. Flammability and Smoke Resistant:
 - 1) Smoke Density:
 - a) Smoke density generated from carpet and backing must not exceed 450 when tested in the flaming mode using ASTM E662, 'Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials'.
 - or
 - b) NFPA 258, 'Standard Research Test Method for Determining Smoke Generation of Solid Materials as test methods'.
- k. Indoor Air Quality (IAQ):
 - 1) CRI Test Program ASTM D5116.
 - 2) Method for determination of VOC emitted from carpet using specific sorbent tube and thermal desorption/gas chromatography as per ASTM 7339.
 - 3) Carpet, adhesives, and seam sealers shall be VOC compliant as certified with CRI Indoor Air Quality Carpet Testing Program Green Label Plus or tested for compliance to meet the CRI IAQ Carpet Testing Program requirements and criteria as per ASTM D5116 CRI Test Program.
- l. Soil Resist Treatment:
 - 1) Minimum average of 350 ppm fluorine on the pile fiber when 3 separate tests are conducted in accordance with CRI TM-102 test method.
 - 2) Installed carpet shall exhibit stain resisting ability equal to or exceeding that of any other premium carpet available at time of manufacture allowing removal of most foreign substances using generally accepted cleaning procedures and more aggressive cleaning procedures for stubborn stains without leaving any more visible stain and/or change in color than the most stain resistant premium carpet available at time of manufacture.
- m. Stain Resistance:
 - 1) Minimum stain resistance rating of 8 when tested in accordance with AATCC 175, 'Stain Resistance: Pile Floor Coverings'.
- n. Tuff Bind (dry):
 - 1) Not less than 10 lbs (45 N) when tested in accordance with ASTM D1335.

2.2 SOURCE QUALITY CONTROL

- A. Tests:
 1. Carpet:
 - a. Appearance Retention Rating:
 - 1) Hexapod Test Method: ASTM D5252.
 - 2) Grading: ASTM D7330.
 - b. Antimicrobial Activity: AATCC 174.
 - c. British Spill Test: Test Protocol.
 - d. Colorfastness:

- 1) Crocking: AATCC 165.
- 2) Light: AATCC 16.3.
- 3) Water: AATCC 107.
- e. Delamination: ASTM D3936 and ASTM D6962.
- f. Dimensional Stability: ISO 2551.
- g. Dry Breaking Strength: ASTM 2646.
- h. Electrostatic Propensity of Carpets: AATCC 134.
- i. Flame and Smoke Resistant. Provide carpet complying with ratings as indicated for following:
 - 1) Flooring Radiant Panel Test (Critical Radiant Flux), ASTM E648, NFPA 253.
 - 2) Smoke Density Test: ASTM E662.
- j. Indoor Air Quality:
 - 1) ASTM 7339.
 - 2) Indoor Air Quality: CRI Test Program ASTM D5116.
- k. Pile Yarn Weight: ASTM D5848.
- l. Soil Resist Treatment: CRI TM-102.
- m. Stain Resistance: AATCC 175.
- n. Turf Bind: ASTM D1335.
2. Attached Backing:
 - a. Carpet Backing: ASTM D3676.
 - b. Compression Resistance (constant deflection): ASTM D3676.
 - c. Compression Set (constant force): ASTM D3676.
 - d. Cushion Density: ASTM D3676.
 - e. Cushion Thickness: ASTM D3676.

PART 3 - EXECUTION

3.1 FIELD QUALITY CONTROL

- A. Field Tests:
 1. Carpet Manufacturer is responsible that concrete slab Alkalinity and Concrete Moisture Vapor Emission Rate (MVER) Testing for each Project is within Carpet Manufacturer's acceptable levels.
- B. Field Inspections:
 1. Carpeting:
 - a. Unacceptable carpet after installation shall include but not be limited to:
 - 1) Delaminating carpet from backings.
 - 2) Fiber loss less than specified.
 - 3) Edge raveling.
 - 4) Fuzzing of carpet fibers.
 - 5) Pilling of carpet fibers.
 - 6) Appearance retention less than control samples attached to Agreement.
 - 7) Dye bleeding.
 - 8) Zippering fibers in carpet.
 - 9) Color streaking.
 - 10) Irregular tufts of fiber.
 - b. Unacceptable workmanship shall include but not be limited to:
 - 1) Improper floor preparation before installation.
 - 2) Failure of adhesive to completely adhere carpet to floor resulting in bubbles, ridges, or ripples where carpet has separated from floor.
 - 3) Seams that do not comply with specified requirements:
 - a) Raveled or untrimmed seams.
 - b) Seams not sealed, level, straight, or even.
 - c) Open seams.
 - d) Seams visibly open when viewed by Project Manager from standing position.
 - 4) Sequence rolls, commercial match issues created by rolls being installed out of sequence will require correction or replacement.

- 5) Failure to properly install carpet next to walls and door frames to eliminate gaps or puckering of carpet.
- 6) Use of unspecified carpet.
- 7) Carpet base ends not finished to terminate at door frames or vertical trim shall have 45 degree angle 'birdsmouth' finish.
- 8) Adhesive exposed on carpet, on carpet base, beyond edges of carpet base, and on other surfaces of building.
- 9) Carpet base that is not scribed to fit against floor with no gaps.
- 10) Carpet base attached by means other than acceptable carpet base adhesive.

C. Non-Conforming Work:

1. Carpeting:

a. Basis of Acceptable Carpeting: Source Quality Control Testing:

- 1) Carpet products not meeting Design Criteria and Source Quality Control Testing of this specification will be considered unacceptable carpeting.

b. Unacceptable Carpeting:

- 1) Unacceptable carpeting will be rejected and shall be repaired or replaced at no additional cost to Owner. Owner's Representative will determine reasonable location of acceptable transition points for removal of unacceptable carpet. Minimum replacement size shall be:

- a) Between nearest existing seams.
- b) Between natural transition points or **12 feet (3.6 meters)** of running length.

END OF SECTION

SECTION 09 9001

COMMON PAINTING AND COATING REQUIREMENTS

PART 1 - GENERAL

1.1 SUMMARY

- A. Includes But Not Limited To:
 - 1. Common procedures and requirements for field-applied painting and coating.
- B. Related Requirements:
 - 1. Section 05 0503: 'Shop-Applied Metal Coatings' for quality of shop priming of steel and iron.
 - 2. Section 07 9213: 'Elastomeric Joint Sealants' for quality of Elastomeric Joint Sealants.
 - 3. Section 09 0162: 'Finishing New Or Sanded Wood Athletic Flooring' for finishing of hardwood flooring and painting of game lines.
 - 4. Sections under 09 9000 heading 'Paints and Coatings'.
 - a. Pre-Installation conferences held jointly with Section 09 9001.
 - 5. Divisions 22 and 23: Painting of plumbing and HVAC identification, refrigerant line insulation, and duct interiors.

1.2 REFERENCES

- A. Definitions:
 - 1. Damage Caused By Others: Damage caused by individuals other than those under direct control of Painting Applicator (MPI(a), PDCA P1.92).
 - 2. Gloss Levels:
 - a. Specified paint gloss level shall be defined as sheen rating of applied paint, in accordance with following terms and values, unless specified otherwise for a specific paint system.

Gloss Level '1'	Traditional matte finish - flat	0 to 5 units at 60 degrees to 10 units maximum at 85 degrees.
Gloss Level '2'	High side sheen flat - 'velvet-like' finish	10 units maximum at 60 degrees and 10 to 35 units at 85 degrees.
Gloss Level '3'	Traditional 'eggshell-like' finish	10 to 25 units at 60 degrees and 10 to 35 units at 85 degrees.
Gloss Level '4'	'Satin-like' finish	20 to 35 units at 60 degrees and 35 units minimum at 85 degrees.
Gloss Level '5'	Traditional semi-gloss	35 to 70 units at 60 degrees.
Gloss Level '6'	Traditional gloss	70 to 85 units at 60 degrees.
Gloss Level '7'	High gloss	More than 85 units at 60 degrees.

- 3. Properly Painted Surface:
 - a. Surface that is uniform in appearance, color, and sheen and free of foreign material, lumps, skins, runs, sags, holidays, misses, strike-through, and insufficient coverage. Surface free of drips, spatters, spills, and overspray caused by Paint Applicator. Compliance will be determined when viewed without magnification at a distance of 5 feet (1.50 m) minimum under normal lighting conditions and from normal viewing position (MPI(a), PDCA P1.92).
- 4. Latent Damage: Damage or conditions beyond control of Painting Applicator caused by conditions not apparent at time of initial painting or coating work.

- B. Reference Standards:

1. The latest edition of the following reference standard shall govern all painting work:
 - a. MPI(a), 'Architectural Painting Specification Manual' by Master Painters Institute (MPI), as issued by local MPI Accredited Quality Assurance Association having jurisdiction.
 - b. MPI(r), 'Maintenance Repainting Manual' by Master Painters Institute (MPI), as issued by local MPI Accredited Quality Assurance Association having jurisdiction.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 1. Schedule painting pre-installation conference after delivery of paint or coatings and before or at same time as application of field samples.
 - a. Coordinate pre-installation conferences of all related painting and coating Sections under 09 9000 heading 'Paints and Coatings'.
 - b. Schedule conference before preparation of control samples as specified in Sections under 09 9000 heading 'Paints and Coatings'.
 - c. Conference to be held at same time as Section 09 2900 to review gypsum board finish preparation.
 2. In addition to agenda items specified in Section 01 3100, review following:
 - a. Review Quality Assurance for Approval requirements.
 - b. Review Quality Assurance Field Sample requirements.
 - c. Review Submittal requirements for compliance for MPI Approved Products.
 - d. Review Design Criteria requirements.
 - e. Review Cleaning requirements.
 - f. Review painting schedule.
 - g. Review safety issues.
 3. Review additional agenda items from Sections under 09 9000 heading 'Paints and Coatings'.

1.4 SUBMITTALS

- A. Action Submittals:
 1. Product Data:
 - a. Include following information for each painting product, arranged in same order as in Project Manual.
 - 1) Manufacturer's cut sheet for each product indicating ingredients and percentages by weight and by volume, environmental restrictions for application, and film thicknesses and spread rates.
 - 2) Provide one (1) copy of 'MPI Approved Products List' showing compliance for each MPI product specified.
 - a) MPI Information is available from MPI Approved Products List using the following link: <http://www.paintinfo.com/mpi/approved/index.shtml>.
 - 3) Confirmation of colors selected and that each area to be painted or coated has color selected for it.
 2. Samples: Provide two 4 inch by 6 inch (100 mm by 150 mm) minimum draw-down cards for each paint or coating color selected for this Project.
- B. Informational Submittals:
 1. Manufacturer Instructions:
 - a. Manufacturer's substrate preparation instructions and application instruction for each painting system used on Project.
 2. Qualification Statement:
 - a. Applicator:
 - 1) Provide Qualification documentation if requested by Architect or Owner.
- C. Closeout Submittals:
 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Record Documentation:
 - 1) Manufacturer's documentation:

- a) Manufacturer's cut sheet for each component of each system.
- b) Schedule showing rooms and surfaces where each system was used.

1.5 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approval:
 1. Conform to work place safety regulations and requirements of those authorities having jurisdiction for storage, mixing, application and disposal of all paint and related hazardous materials.
 2. Paint and painting materials shall be free of lead and mercury, and have VOC levels acceptable to local jurisdiction.
 3. Master Painters Institute (MPI) Standards:
 - a. Products: Comply with MPI standards indicated and listed in 'MPI Approved Products List'.
 - b. Preparation and Workmanship: Comply with requirements in 'MPI Architectural Painting Specification Manual' for products and coatings indicated.
- B. Qualifications:
 1. Applicator: Requirements of Section 01 4301 applies, but not limited to following:
 - a. Minimum five (5) years' experience in painting installations.
 - b. Minimum five (5) satisfactorily completed projects of comparable quality, similar size, and complexity in past three (3) years before bidding.
 - c. Maintain qualified crew of painters throughout duration of the Work.
 - d. Upon request, submit documentation.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 1. Deliver specified products in sealed, original containers with Manufacturer's original labels intact on each container.
 2. Deliver amount of materials necessary to meet Project requirements in single shipment.
- B. Storage And Handling Requirements:
 1. Store materials in single place.
 2. Keep storage area clean and rectify any damage to area at completion of work of this Section.
 3. Maintain storage area at 55 deg F (13 deg C) minimum.

1.7 FIELD CONDITIONS

- A. Ambient Conditions:
 1. Perform painting operations at temperature and humidity conditions recommended by Manufacturer for each operation and for each product for both interior and exterior work.
 2. Apply painting systems at lighting level of 540 Lux (50 foot candles) minimum on surfaces to be painted.
 - a. Inspection of painting work shall take place under same lighting conditions as application.
 - b. If painting and coating work is applied under temporary lighting, deficiencies discovered upon installation of permanent lighting will be considered latent damage as defined in MPI Manual, PDCA P1-92.

PART 2 - PRODUCTS

2.1 SYSTEMS

- A. Performance:
 1. Design Criteria:

- a. Provide materials for use within each coating system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
 - b. All materials, preparation and workmanship shall conform to requirements of 'Architectural Painting Specification Manual' by Master Painters Institute (MPI).
 - c. All paint manufacturers and products used shall be as listed under Approved Product List section of MPI Painting Manual.
 - d. Provide Premium Grade systems (2 top coats) as defined in MPI Architectural Painting Specification Manual, except as otherwise indicated.
 - e. Where specified paint system does not have Premium Grade, provide Budget Grade.
 - f. Provide products of same manufacturer for each coat in coating system.
 - g. Where required to meet LEED (Leadership in Energy and Environmental Design) program requirements, use only MPI listed materials having an "L" rating designation.
 - h. Color Levels:
 - 1) Color Level II:
 - a) Number and placement of interior and exterior paint colors and gloss levels shall be as defined by Color Level II from MPI Manual, PDCA P3-93 as modified in following paragraph.
 - b) No more than one paint color or gloss level will be selected for same substrate within designated interior rooms or exterior areas.
 - 2) Color Level III:
 - a) Number and placement of interior and exterior paint colors and gloss levels shall be Color Level III from MPI Manual, PDCA P3-93 as modified in following paragraph.
 - b) Several paint colors or gloss levels will be selected for same substrate within designated interior rooms or exterior areas.
- B. Materials:
1. Materials used for any painting system shall be from single manufacturer unless approved otherwise in writing by painting system manufacturers and by Architect. Include manufacturer approvals in Product Data submittal.
 2. Linseed oil, shellac, turpentine, and other painting materials shall be pure, be compatible with other coating materials, bear identifying labels on containers, and be of highest quality of an approved manufacturer listed in MPI manuals. Tinting color shall be best grade of type recommended by Manufacturer of paint or stain used on Project.

PART 3 - EXECUTION

3.1 APPLICATORS

- A. Approved Applicators:
1. Meet Quality Assurance Applicator Qualifications as specified in Part 1 of this specification.

3.2 EXAMINATION

- A. Verification Of Conditions:
1. Directing applicator to begin painting and coating work will indicate that substrates to receive painting and coating materials have been previously inspected as part of work of other Sections and are complete and ready for application of painting and coating systems as specified in those Sections.
- B. Pre-Installation Testing:
1. Before beginning work of this Section, examine, and test surfaces to be painted or coated for adhesion of painting and coating systems.
 2. Report in writing to Architect of conditions that will adversely affect adhesion of painting and coating work.

3. Do not apply painting and coating systems until party responsible for adverse condition has corrected adverse condition.

C. Evaluation And Assessment:

1. Report defects in substrates that become apparent after application of primer or first finish coat to Architect in writing and do not proceed with further work on defective substrate until such defects are corrected by party responsible for defect.

3.3 PREPARATION

A. Protection Of In-Place Conditions:

1. Protect other finish work and adjacent materials during painting. Do not splatter, drip, or paint surfaces not intended to be painted. These items will not be spelled out in detail but pay special attention to the following:
 - a. Do not paint finish copper, bronze, chromium plate, nickel, stainless steel, anodized aluminum, or monel metal except as explicitly specified.
 - b. Keep cones of ceiling speakers completely free of paint. In all cases where painting of metal speaker grilles is required, paint without grilles mounted to speakers and without grilles on ceiling.
 - c. On existing work where ceiling is to be painted, speakers and grilles are already installed, and ceiling color is not being changed, mask off metal grilles installed on ceiling speakers. If ceiling color is being changed, remove metal grilles and paint, and mask off ceiling speakers.

B. Surface Preparation:

1. Prepare surfaces in accordance with MPI requirements and requirements of Manufacturer for each painting system specified, unless instructed differently in Contract Documents. Bring conflicts to attention of Architect in writing.
2. Fill minor holes and cracks in wood surfaces to receive paint or stain.
3. Surfaces to be painted shall be clean and free of loose dirt. Clean and dust surfaces before painting or finishing.
4. Do no exterior painting while surface is damp, unless recommended by Manufacturer, nor during rainy or frosty weather. Interior surfaces shall be dry before painting. Moisture content of materials to be painted shall be within tolerances acceptable to Paint Manufacturer.
5. Sand woodwork smooth in direction of grain leaving no sanding marks. Clean surfaces before proceeding with stain or first coat application.

3.4 APPLICATION

A. Interface With Other Work:

1. Coordinate with other trades for materials and systems that require painting before installation.
2. Schedule painting and coating work to begin when work upon which painting and coating work is dependent has been completed. Schedule installation of pre-finished and non-painted items, which are to be installed on painted surfaces, after application of final finishes.

B. Paint or finish complete all surfaces to be painted or coated as described in Contract Documents, including but not limited to following items.

1. Finish casework and wood trims that are specified to be installed under Section 06 2001 and that are not called out to be factory-or shop-finished. Back prime wood elements to be installed against concrete or masonry or that may be subjected to moisture.
2. Paint mechanical, electrical, and audio/visual items that require field painting as indicated in Contract Documents. These include but are not limited to:
 - a. Gas pipe from gas meter into building.
 - b. Mechanical flues and pipes penetrating roof.
 - c. Electrical panel and disconnect enclosures.
 - d. Metal protective structures for refrigerant lines.
3. Metal reveals at ceiling access doors.

4. Paint inside of chases in occupied spaces flat black for **18 inches (450 mm)** or beyond sightline, whichever is greater.
- C. Apply sealant in gaps **3/16 inch (5 mm)** and smaller between two substrates that are both to be painted or coated. Sealants in other gaps furnished and installed under Section 07 9213.
- D. On wood to receive a transparent finish, putty nail holes in wood after application of stain using natural colored type to match wood stain color. Bring putty flush with adjoining surfaces.
- E. In multiple coat paint work, tint each succeeding coat with slightly lighter color, but approximating shade of final coat, so it is possible to check application of specified number of coats. Tint final coat to required color.
- F. Spread materials smoothly and evenly. Apply coats to not less than wet and dry film thicknesses and at spreading rates for specified products as recommended by Manufacturer.
- G. Touch up suction spots after application of first finish coat.
- H. Paint shall be thoroughly dry and surfaces clean before applying succeeding coats.
- I. Use fine sandpaper between coats as necessary to produce even, smooth surfaces.
- J. Make edges of paint adjoining other materials or colors clean, sharp, and without overlapping.
- K. Finished work shall be a 'Properly Painted Surface' as defined in this Section.

3.5 FIELD QUALITY CONTROL

- A. Non-Conforming Work:
 1. Correct deficiencies in workmanship as required to leave surfaces in conformance with 'Properly Painted Surface,' as defined in this Section.
 2. Correction of 'Latent Damage' and 'Damage Caused By Others,' as defined in this Section, is not included in work of this Section.

3.6 CLEANING

- A. General:
 1. As work proceeds and upon completion of work of any painting Section, remove paint spots from floors, walls, glass, or other surfaces and leave work clean, orderly, and in acceptable condition.
- B. Waste Management:
 1. Remove rags and waste used in painting operations from building each night. Take every precaution to avoid danger of fire.
 2. Paint, stain and wood preservative finishes and related materials (thinners, solvents, caulking, empty paint cans, cleaning rags, etc.) shall be disposed of subject to regulations of applicable authorities having jurisdiction.
 3. Remove debris caused by work of paint Sections from premises and properly dispose.
 4. Retain cleaning water and filter out and properly dispose of sediments.

END OF SECTION

ATTACHMENTS**PART 4 - PAINT COLOR SCHEDULE**

A. Related Requirements:

1. Section 09 9112 'Exterior Painted Ferrous Metal'.
2. Section 09 9122 'Interior Painted CMU'.
3. Section 09 9123 'Interior Painted Gypsum Board-Plaster'.
4. Section 09 9124 'Interior Painted Metal'.
5. Section 09 9125 'Interior Wood Paint'.
6. Section 09 9324 'Interior Clear-Finished Hardwood'.

B. Colors:

1. Interior:
 - a. Interior Clear Finished Wood (See Section 09 9324):
 - 1) Match other interior clear finished wood building elements.
 - b. Interior Gypsum Board, Plaster (See Section 09 9123):
 - 1) Class One Color Quality Standard. See Section 01 6200:
 - 2) Match other interior painted gypsum board building elements.
 - c. Interior Metal (See Section 09 9124):
 - 1) Class One Color Quality Standard. See Section 01 6200:
 - a) Match other interior painted metal building elements.
 - d. Interior Painted Wood (See Section 09 9125):
 - 1) Class One Color Quality Standard. See Section 01 6200:
 - 2) Match other interior painted wood building elements.
2. Exterior:
 - a. Exterior Metal (See Section 09 9112):
 - 1) Class One Color Quality Standard. See Section 01 6200.
 - a) Match other Exterior painted metal building elements.

BLANK PAGE

SECTION 09 9112**EXTERIOR PAINTED FERROUS METAL****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Preparing and painting new exterior ungalvanized iron and steel surfaces as described in Contract Documents including but not limited to metal guardrail at mechanical enclosure.
 - 2. Preparing and painting following existing exterior ungalvanized iron and steel surfaces as described in Contract Documents:
 - a. Paint existing surfaces effected by renovation and as noted in the contract documents.
- B. Related Requirements:
 - 1. Section 09 9001: 'Common Painting And Coating Requirements':
 - a. Pre-installation conference for Sections under 09 9000 heading 'Paints and Coatings'.
 - b. 'Attachment: Paint Color Schedule' for O&M / R&I Projects.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 09 9001.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Category Four Approved Products and Manufacturers. See Section 01 6200 for definitions of Categories:
 - a. Products listed in edition of MPI Approved Product List current at time of bidding and later are approved.
- B. Description:
 - 1. New Surfaces: Use MPI(a) EXT 5.1M Waterborne Light Industrial Coating system .
 - 2. Previously Finished Surfaces: Use MPI(r) REX 5.1K Waterborne Light Industrial Coating.
- C. Design Criteria:
 - 1. Systems specified are in addition to prime coats provided under other Sections of Project Manual.
 - 2. Finish Requirements: Use MPI Premium Grade finish requirements for work of this Section.
 - 3. Gloss / Sheen Level Required: Gloss Level 5.
- D. Materials:
 - 1. All paints and coatings.
 - a. Primer Coat: MPI Product 107, 'Primer, Rust-Inhibitive, Water Based'.
 - b. Finish Coats: MPI Product 163, 'Light Industrial Coating, Exterior, Water Based, Semi-Gloss (MPI Gloss Level 5).

PART 3 - EXECUTION**3.1 APPLICATION**

- A. General: See appropriate paragraphs of Section 09 9001.
- B. New Surfaces: Clean metal to be painted of rust, mill scale, grease, oil, and welding spatters, burrs, flux, slag, and fume. If all traces of rust cannot be removed, apply rust blocker recommended by Paint Manufacturer before applying primer coat.
- C. Existing Painted Surfaces:
 - 1. Remove deteriorated and chalked existing paint and rust down to sound substrate by scraping or power tools.
 - 2. Clean existing sound painted surfaces as well as scraped and sanded existing painted surfaces as recommended by Paint Manufacturer. If all traces of rust cannot be removed, apply rust blocker recommended by Paint Manufacturer before applying primer coat.
 - 3. Spot prime bare metal surfaces followed by a prime coat over entire surface to be painted.
 - 4. Lightly sand entire surface.
 - 5. Clean surface as recommended by Paint Manufacturer.
 - 6. Apply specified finish coats.

END OF SECTION

SECTION 09 9113**EXTERIOR PAINTED GALVANIZED METAL****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Preparing and painting new exterior exposed galvanized metal surfaces as Described in Contract Documents.
 - 2. Preparing and painting following existing exterior exposed galvanized metal surfaces as described in Contract Documents.
 - a. Paint existing exterior painted galvanized metal that is affected by construction operations.
- B. Related Requirements:
 - 1. Section 09 9001: 'Common Painting And Coating Requirements':
 - a. Pre-installation conference for Sections under 09 9000 heading 'Paints and Coatings'.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 09 9001.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Category Four Approved Products and Manufacturers. See Section 01 6200 for definitions of Categories.
 - a. Products listed in edition of MPI Approved Product List current at time of bidding and later are approved, providing they meet VOC requirements in force where Project is located.
- B. Description:
 - 1. Exposed Miscellaneous Structural Steel:
 - a. New Surfaces: Use MPI(a) EXT 5.3D Pigmented Polyurethane Finish system.
 - b. Previously Finished Work: Use MPI(r) REX 5.3D Pigmented Polyurethane Finish system.
 - 2. All Other:
 - a. New Surfaces: Use MPI(a) EXT 5.3H Latex Finish system.
 - b. Previously Finished Surfaces: Use MPI(r) REX 5.3H Latex Finish system.
- C. Performance:
 - 1. Design Criteria:
 - a. New Surfaces: MPI Premium Grade finish requirements.
 - b. Deteriorated Existing Surfaces: MPI Premium Grade finish requirements.
 - c. Sound Existing Surfaces: MPI Custom Grade finish requirements.
 - d. Gloss / Sheen Level Required: Gloss Level 5.
- D. Materials:
 - 1. Polyurethane:
 - a. Vinyl Wash Primer Coat: MPI Product 80: 'Primer, Vinyl Wash'.
 - b. Finish Coats:
 - 1) Epoxy MPI Product 101: 'Primer, Epoxy, Anti-Corrosive, for Metal'.

- 2) Polyurethane MPI Product 72: 'Polyurethane, Two-Component, Pigmented, Gloss (MPI Gloss Level 6-7)'.
2. Latex:
 - a. Waterborne Primer Coat: MPI Product 134: 'Primer, Galvanized, Water Based'.
 - b. Finish Coats: MPI Product 11: 'Latex, Exterior Semi-Gloss (MPI Gloss Level 5)'.

PART 3 - EXECUTION

3.1 APPLICATION

- A. General: See appropriate paragraphs of Section 09 9001.
- B. New Surfaces:
 1. Clean 'passivated' or 'stabilized' galvanized steel as specified in SSPC-SP1.
 2. After removal of 'passivated' or 'stabilized' coating or for surfaces without coating, clean surfaces to be painted with mineral spirits or product recommended by Paint Manufacturer. Change to clean rags or wiping cloths regularly to reduce possibility of re-contamination of surface.
 3. Apply prime coat.
 4. Apply finish coats.
- C. Existing Painted Surfaces:
 1. Remove deteriorated and chalked existing paint and rust deposits down to sound substrate by sanding, scraping, or wire brushing.
 2. Clean existing sound painted surfaces as well as scraped and sanded existing painted surfaces as recommended by Paint Manufacturer.
 3. Apply prime coat.
 4. Apply finish coats.
- D. Existing Unpainted Surfaces:
 1. Wirebrush or power wash as necessary to remove 'white rust'.
 2. Apply prime coat.
 3. Apply finish coats.

END OF SECTION

SECTION 09 9121**INTERIOR PAINTED POURED CONCRETE****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Preparing and painting of new concrete floors to be left exposed in finished building, as described in Contract Documents.
 - 2. Preparing and painting following existing concrete floors as described in Contract Documents:
 - a. Lower mechanical room concrete floor.
 - b. Mechanical Room 124.
- B. Related Requirements:
 - 1. Section 09 9001: 'Common Painting And Coating Requirements':
 - a. Pre-installation conference for Sections under 09 9000 heading 'Paints and Coatings'.
 - b. 'Attachment: Paint Color Schedule' for O&M / R&I Projects.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 09 9001.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Category Four Approved Products and Manufacturers. See Section 01 6200 for definitions of Categories.
 - a. Products listed in edition of MPI Approved Product List current at time of bidding and later are approved, providing they meet VOC requirements in force where Project is located.
- B. Description:

EDIT REQUIRED: Change system letter designation as necessary for surfaces to be painted, if specified water-based latex system is not suitable.

- 1. New Surfaces: Use MPI(a) INT 3.2A Latex Finish system
 - 2. Previously Finished Surfaces: Use MPI(r) RIN 3.2A Latex Finish system.
 - 3. Finish Requirements: Use MPI Custom Grade finish requirements.
- C. Performance:
 - 1. Design Criteria:
 - a. Gloss / Sheen Level Required: Semi-Gloss.
 - D. Materials:
 - 1. MPI Product 60: 'Floor Paint, Latex, Low Gloss'.

PART 3 - EXECUTION

3.1 APPLICATION

- A. General: See appropriate paragraphs of Section 09 9001.
- B. Existing Painted Surfaces:
 - 1. Remove deteriorated existing paint down to sound substrate by scraping and sanding. Feather edges of existing paint by sanding to be smooth with adjacent surfaces. Acid etch bare concrete areas, if necessary.
 - 2. Clean floors as recommended by Paint Manufacturer.
 - 3. Apply coating system.

END OF SECTION

SECTION 09 9123**INTERIOR PAINTED GYPSUM BOARD, PLASTER****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Preparing, priming, and finish painting new interior gypsum board and plaster surfaces as described in Contract Documents.
 - 2. Preparing and painting following existing interior gypsum board and plaster surfaces as described in Contract Documents:
 - a. Preparing and painting existing surfaces on all affected by renovation and as noted in the contract documents Related Requirements.
- B. Related Requirements:
 - 1. Section 09 2900: 'Gypsum Board' for:
 - a. Priming new interior gypsum board surfaces to receive sheet wall covering system or texturing.
 - b. Pre-installation conference.
 - 2. Section 09 9001: 'Common Painting And Coating Requirements':
 - a. Pre-installation conference for Sections under 09 9000 heading 'Paints and Coatings'.
 - b. 'Attachment: Paint Color Schedule' for O&M / R&I Projects.
 - 3. Section 09 9413: 'Interior Textured Finishing' for textured finishes.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 09 2900.
 - a. In addition to agenda items specified in Section 01 3100 and Section 09 2900, review following:
 - 1) Review finish level requirements of gypsum wallboard as specified in Section 09 2900.
 - 2. Participate in pre-installation conference as specified in Section 09 9001.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Category Four Approved Manufacturers and Products. See Section 01 6200 for definitions of Categories.
 - a. Products listed in edition of MPI Approved Product List current at time of bidding and later are approved, providing they meet VOC requirements in force where Project is located.
- B. Description:
 - 1. All Other:
 - a. New Surfaces: Use MPI(a) INT 9.2B Latex Finish system.
 - b. Previously Finished Work: Use MPI(r) RIN 9.2B Latex Finish system.
- C. Performance:
 - 1. Design Criteria:

- a. New Surfaces: MPI Premium Grade finish requirements.
 - b. Deteriorated Existing Surfaces: MPI Premium Grade finish requirements.
 - c. Sound Existing Surfaces: MPI Custom Grade requirements.
 - d. Gloss / Sheen Required:
 - 1) Remaining Painted Surfaces: Gloss Level 5 as a minimum. Match existing gloss level of room(s) to be painted.
- D. Materials:
1. Primers:
 - a. MPI Product 50, 'Primer Sealer, Latex, Interior'.
 2. Finish Coats:
 - a. Remaining Painted Surfaces:
 - 1) MPI Product 141, 'Latex, Interior, High Performance Architectural, Semi-Gloss (MPI Gloss Level 5)'. Use gloss level of paint in same room.

PART 3 - EXECUTION

3.1 APPLICATION

- A. General: See appropriate paragraphs of Section 09 9001.
- B. New Surfaces:
 1. Primer: Apply primer to be covered with other paint coats with roller only, or with spray gun and back-rolled.
- C. Existing Painted Surfaces:
 1. Remove deteriorated existing paint down to sound substrate by scraping or sanding. Feather edges of existing paint by sanding to be smooth with adjacent surfaces.
 2. Clean surface with mild soap and water, or with tri-sodium phosphate (TSP). Wash surfaces that have been defaced with marking pens, crayons, lipstick, etc, with solvent recommended by Paint Manufacturer. Spot prime such surfaces.
 3. Spackle and tape cracks. Sand to smooth finish and spot prime.
 4. Sand or chemically etch existing painted surface as required to prepare surface to accept new paint.
 5. Re-clean surface.
 6. Apply primer coat.
 7. Apply finish coats.

END OF SECTION

SECTION 09 9124**INTERIOR PAINTED METAL****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Preparing and painting new interior metal surfaces as described in Contract Documents.
 - 2. Preparing and painting following existing interior metal surfaces as described in Contract Documents:
 - a. Any metal surface affected by the renovation.
- B. Related Requirements:
 - 1. Section 05 5871: 'Metal Brackets'.
 - 2. Section 09 9001: 'Common Painting And Coating Requirements':
 - a. Pre-installation conference for Sections under 09 9000 heading 'Paints and Coatings'.
 - b. 'Attachment: Paint Color Schedule' for O&M / R&I Projects.
 - 3. Section 23 0553: 'I. D. For HVAC Piping And Equipment' for field painting requirements of HVAC piping and equipment.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 09 9001.
- B. Sequencing:
 - 1. Paint brackets furnished under Section 05 5871 before installation of bracket.
 - 2. Paint metal speaker grilles, which are to be painted to match ceiling, before attachment to speakers and before installation of sound system.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Category Four Approved Products and Manufacturers. See Section 01 6200 for definitions of Categories.
 - a. Products listed in edition of MPI Approved Product List current at time of bidding and later are approved, providing they meet VOC requirements in force where Project is located.
- B. Description:
 - 1. Ferrous Metal:
 - a. New Surfaces: Use MPI(a) INT 5.1B Waterborne Light Industrial Finish system.
 - b. Previously Finished Surfaces: Use MPI(r) RIN 5.1B Waterborne Light Industrial Finish system.
 - 2. Galvanized Metal:
 - a. New Surfaces: Use MPI(a) INT 5.3J Latex Finish system
 - b. Previously Finished Surfaces: Use MPI(r) RIN 5.3AH Latex Finish system.
 - 3. Aluminum:
 - a. New Surfaces: Use MPI(a) INT 5.4E Waterborne Light Industrial Finish system.
 - b. Previously Finished Surfaces: Use MPI(r) REX 5.4E Light Industrial Finish system.

- C. Performance:
 - 1. Design Requirements:
 - a. New Surfaces: MPI Premium Grade finish requirements.
 - b. Deteriorated Existing Surfaces: MPI Premium Grade finish requirements.
 - c. Sound Existing Surfaces: MPI Custom Grade finish requirements.
 - d. Gloss / Sheen Level Required: Gloss Level 5.
- D. Materials:
 - 1. Primers:
 - a. Ferrous Metal: MPI Product 107, 'Primer, Rust-Inhibitive, Water Based'.
 - b. Galvanized Metal: MPI Product 134: 'Primer, Galvanized, Water Based'.
 - c. Aluminum: MPI Product 95: 'Primer, Quick Dry, for Aluminum'.
 - 2. Finish Coats: MPI Product 153: 'Light Industrial Coating, Interior, Water Based, Semi-Gloss (MPI Gloss Level 5)'.

PART 3 - EXECUTION

3.1 APPLICATION

- A. General:
 - 1. See appropriate paragraphs of Section 09 9001.
 - 2. Systems specified are in addition to prime coats furnished under other Sections.
- B. New Surfaces: Remove rust spots by sanding and immediately spot prime. If all traces of rust cannot be removed, apply rust blocker recommended by Paint Manufacturer before applying full primer coat.
- C. Existing Painted Surfaces:
 - 1. Remove deteriorated existing paint down to sound substrate by scraping and sanding. Feather edges of existing paint by sanding to be smooth with adjacent surfaces. Spot prime bare metal surfaces immediately.
 - 2. Remove rust spots by sanding and immediately spot prime. If all traces of rust cannot be removed, apply rust blocker recommended by Paint Manufacturer before applying full primer coat.
 - 3. Clean existing sound painted surfaces as well as scraped and sanded existing painted surfaces as recommended by Paint Manufacturer.
 - 4. Apply prime coat over entire surface to be painted.
 - 5. Lightly sand entire surface.
 - 6. Clean surface as recommended by Paint Manufacturer.
 - 7. Apply finish coats.

END OF SECTION

SECTION 09 9324**INTERIOR CLEAR-FINISHED HARDWOOD****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Preparing and finishing of new interior clear finished hardwood as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 06 2210: 'Miscellaneous Wood Trim'.
 - 2. Section 06 4512: 'Architectural Woodwork Wood Trim'.
 - 3. Section 08 1429: 'Interior Flush Wood Doors'.
 - 4. Section 09 9001: 'Common Painting And Coating Requirements':
 - a. Pre-installation conference for Sections under 09 9000 heading 'Paints and Coatings'.
 - b. 'Attachment': Paint Color Schedule' for O&M / R&I Projects.

1.2 REFERENCES

- A. Reference Standards:
 - 1. Kitchen Cabinet Manufacturers Association / American National Standards Institute:
 - a. ANSI/KCMA A161.1-2000 (R2005) 23-Jan-2001 'Recommended Performance and Construction Standards for Kitchen and Vanity Cabinets.'

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 09 9001.
 - 2. In addition to agenda items specified in Section 01 3100 and Section 09 9001, review following:
 - a. Review control sample(s).

1.4 SUBMITTALS

- A. Action Submittals:
 - 1. Samples:
 - a. Interior Hardwood for Transparent Finish:
 - 1) Requirements for samples are specified in Related Requirement Sections listed above.
 - b. Design Criteria:
 - 1) Sample will be used as performance standard for evaluating finish provided.
- B. Informational Submittals:
 - 1. Test And Evaluation Reports:
 - a. Before beginning finish work, submit Finish Manufacturer's literature or certification that finish material meets requirements of ANSI / KCMA A161.1.

PART 2 - PRODUCTS

2.1 SYSTEM

- A. Materials:
1. Design Criteria:
 - a. See appropriate paragraphs of Section 09 9001.
 2. Stain: MPI 90, 'Stain, Semi-Transparent, for Interior Wood'.
 3. Clear Finish Coats:
 - a. Field Finished:
 - 1) Chemcraft International Inc:
 - a) First, Second, And Third Coats: 20 Sheen Opticlear Pre-Catalyzed Lacquer.
 - 2) ICI Dulux / Trinity:
 - a) First Coat: ICE Vinyl Sanding Sealer.
 - b) Second And Third Coats: ICI Pre-Catalyzed Lacquer.
 - 3) Lilly / Valspar:
 - a) First, Second, And Third Coats: 20 Sheen Pre-Catalyzed Lacquer 587E208.
 - 4) Sherwin-Williams:
 - a) First Coat: T67F3 Vinyl Sealer.
 - b) Second And Third Coats: T77F38 Sherwood Pre-Catalyzed Lacquer DRE.
 - b. Mill Finished: Architectural Woodwork finished in a mill may use one (1) coat of Vinyl Sealer and two (2) coats of Conversion Varnish or three (3) coats of Conversion Varnish from one (1) of the approved Finish Manufacturers, as recommended by Finish Manufacturer.
 - c. Products meeting testing requirements for finishes of ANSI / KCMA A161.1 may be used upon approval of submission by Architect before use. See Section 01 6200.
 4. Color:
 - a. Design Criteria:
 - 1) Finish to match Owner selected sample from existing wood in building.

PART 3 - EXECUTION

3.1 APPLICATION

- A. General:
1. See appropriate paragraphs of Section 09 9001.
 2. Sand entire exposed surface of item to be finished lightly with 120 to 150 non-stearated sandpaper and clean before applying dye or stain.
 3. Apply stain in accordance with Manufacturer's recommendations and as necessary to attain correct color.
 4. Scuff sand with 220 non-stearated sandpaper between application of application stain and first finish coat.
 5. If wood is finished before installation, finish cut ends and other unfinished, exposed surfaces same as previously finished surfaces after installation of wood.
- B. Where back-priming is required, apply one coat of finish material.
- C. Architectural Woodwork Door Surfaces (cabinetry doors only):
1. Finish tops, bottoms, and edges before faces.
 2. Finish architectural woodwork doors with no hardware applied to doors.

END OF SECTION

SECTION 09 9413**INTERIOR TEXTURED FINISHING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and apply texturing on walls and ceilings as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 09 2900: 'Gypsum Board' for priming.
 - 2. Section 09 9001: 'Common Painting And Coating Requirements' for:
 - a. Pre-installation conference for Sections under 09 9000 heading 'Paints and Coatings'.
 - 3. Section 09 9123: 'Interior Painted Gypsum Board, Plaster' for finish painting.

1.2 REFERENCES

- A. Definitions:
 - 1. Drywall Texture: Compound rolled, sprayed, or troweled onto sheetrock after taping and floating of joints is complete. Uses same material as joint compound, but thinned down with water and applied to wall surface:
 - a. Hawk and Trowel, Multi-Directional: Lightly sanded, (80/20) 80 percent smooth with 20 percent random voids. Resembles aged plaster.
 - b. Smooth - Smooth application of texture over sheetrock wall that feathers out sheetrock joints, and creates even, non-textured wall.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conferences:
 - 1. Participate in pre-installation conference as specified in Section 09 9001.
 - 2. In addition to agenda items specified in Section 01 3100 and Section 09 9001, review following:
 - a. Review control samples.

1.4 SUBMITTALS

- A. Action Submittals:
 - 1. Samples:
 - a. Hawk and Trowel, Multi-Directional (lightly sanded) Texture:
 - 1) Provide minimum of three (3) 24 inch (600 mm) square control samples on primed gypsum wallboard of 'multi-directional' texture (70/30, 80/20, and 90/10) to show possible variations. Match existing hall Hawk and Trowel texture.

1.5 QUALITY ASSURANCE

- A. Field Samples:
 - 1. Before performing work of this Section, prepare control samples.
 - 2. Architect will inspect control sample at pre-installation conference following preparation of control sample. When sample is approved, work of this Section may proceed. Approved samples will be kept at site at all times work of this section is being performed.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. National Gypsum, Charlotte, NC www.nationalgypsum.com.
 - b. U S Gypsum Co, Chicago, IL www.usg.com.
- B. Materials:
 - 1. Class Two Quality Standards: See Section 01 6200.
 - a. ProForm Perfect Spray EM/HF by National Gypsum.
 - b. Sheetrock Wall & Ceiling Texture by U S Gypsum.

PART 3 - EXECUTION**3.1 APPLICATION**

- A. Location:
 - 1. Walls:
 - a. Hawk And Trowel, Multi-Directional (lightly sanded) Texture:
 - 1) All areas except those listed in following paragraph.
 - b. Smooth:
 - 1) Where existing smooth finishes exist in areas being renovated.
- B. Finishing:
 - 1. Hawk And Trowel, Multi-Directional (lightly sanded) Texture:
 - a. After gypsum board is taped and sanded, apply texture. Closely match samples accepted by Architect. Match existing hall Hawk and Trowel texture.
 - 1) After wall has been textured, apply priming and finish paint as specified in Section 09 9123.
 - 2. Smooth:
 - a. No applied texture is required. Apply priming and paint as specified in Section 09 9123.

END OF SECTION

DIVISION 23: HEATING, VENTILATING, AND AIR-CONDITIONING

23 0500 COMMON WORK RESULTS FOR HVAC

- 23 0501 COMMON HVAC REQUIREMENTS
- 23 0529 HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT
- 23 0553 IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT
- 23 0713 DUCT INSULATION
- 23 0719 HVAC PIPING INSULATION
- 23 0933 ELECTRIC AND ELECTRONIC CONTROL SYSTEM FOR HVAC

23 1000 FACILITY FUEL SYSTEMS

- 23 1123 FACILITY NATURAL GAS PIPING

23 2000 HVAC PIPING AND PUMPS

- 23 2300 REFRIGERANT PIPING
- 23 2600 CONDENSATE DRAIN PIPING

23 3000 HVAC AIR DISTRIBUTION

- 23 3001 COMMON DUCT REQUIREMENTS
- 23 3114 LOW-PRESSURE METAL DUCTS
- 23 3123 UNDERGROUND DUCTS
- 23 3300 AIR DUCT ACCESSORIES
- 23 3316 FIRE DAMPERS
- 23 3713 DIFFUSERS REGISTERS AND GRILLES
- 23 3723 HVAC GRAVITY VENTILATORS

23 4000 HVAC AIR CLEANING DEVICES

- 23 4100 AIR FILTERS

23 5000 CENTRAL HEATING EQUIPMENT

- 23 5135 AIR PIPING
- 23 5417 GAS-FIRED FURNACES

23 6000 CENTRAL COOLING EQUIPMENT

- 23 6214 COMPRESSOR UNITS: AIR CONDITIONING (5 TONS OR LESS)

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 23 0501**COMMON HVAC REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Common requirements and procedures for HVAC systems.
 - 2. Responsibility for proper operation of electrically powered equipment furnished under this Division.
 - 3. Interface with Testing And Balancing Agency.
 - 4. Furnish and install sealants relating to installation of systems installed under this Division.
 - 5. Furnish and install Firestop Penetration Systems for HVAC system penetrations as described in Contract Documents.
 - 6. Furnish and install sound, vibration, and seismic control elements.
- B. Products Furnished But Not Installed Under This Section:
 - 1. Sleeves, inserts, and equipment for mechanical systems installed under other Sections.
- C. Related Requirements:
 - 1. Section 07 9213: Quality of sealants used at building exterior.
 - 2. Section 07 9219: Quality of acoustical sealants.
 - 3. Sections Under 09 9000 Heading: Painting of mechanical items requiring field painting.
 - 4. Section 26 2913: Magnetic starters and thermal protective devices (heaters) not factory mounted integral part of mechanical equipment.
 - 5. Division 26: Raceway and conduit, unless specified otherwise, line voltage wiring, outlets, and disconnect switches.
 - 6. Slots and openings through floors, walls, ceilings, and roofs provided under other Divisions in their respective materials.

1.2 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Manufacturer's catalog data for each manufactured item.
 - 1) Provide section in submittal for each type of item of equipment. Include Manufacturer's catalog data of each manufactured item and enough information to show compliance with Contract Document requirements. Literature shall show capacities and size of equipment used and be marked indicating each specific item with applicable data underlined.
 - 2) Include name, address, and phone number of each supplier.
 - 2. Shop Drawings:
 - a. Schematic control diagrams for each separate fan system, heating system, control panel, etc. Each diagram shall show locations of all control and operational components and devices. Mark correct operating settings for each control device on these diagrams.
 - b. Diagram for electrical control system showing wiring of related electrical control items such as firestats, fuses, interlocks, electrical switches, and relays. Include drawings showing electrical power requirements and connection locations.
 - c. Drawing of each temperature control panel identifying components in panels and their function.
 - d. Other shop drawings required by Division 23 trade Sections.
- B. Informational Submittals:
 - 1. Qualification Statement:

- a. HVAC Firm:
 - 1) Provide Qualification documentation if requested by Architect or Owner.
 - b. Installer:
 - 1) Provide Qualification documentation if requested by Architect or Owner.
- C. Closeout Submittals:
- 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Operations and Maintenance Data (Modify and add to requirements of Section 01 7800):
 - 1) At beginning of HVAC section of Operations And Maintenance Manual, provide master index showing items included.
 - a) Provide name, address, and phone number of Architect, Architect's Mechanical Engineer, General Contractor, and HVAC, Sheet Metal, Refrigeration, and Temperature Control subcontractors.
 - b) Identify maintenance instructions by using same equipment identification used in Contract Drawings. Maintenance instructions shall include:
 - (1) List of HVAC equipment used indicating name, model, serial number, and nameplate data of each item together with number and name associated with each system item.
 - (2) Manufacturer's maintenance instructions for each piece of HVAC equipment installed in Project. Instructions shall include name of vendor, installation instructions, parts numbers and lists, operation instructions of equipment, and maintenance and lubrication instructions.
 - (3) Summary list of mechanical equipment requiring lubrication showing name of equipment, location, and type and frequency of lubrication.
 - (4) Manual for Honeywell LCBS controls published by Honeywell.
 - c) Provide operating instructions to include:
 - (1) General description of each HVAC system.
 - (2) Step by step procedure to follow in putting each piece of HVAC equipment into operation.
 - (3) Provide diagrams for electrical control system showing wiring of items such as smoke detectors, fuses, interlocks, electrical switches, and relays.
 - b. Warranty Documentation:
 - 1) Include copies of warranties required in individual Sections of Division 23.
 - c. Record Documentation:
 - 1) Manufacturers documentation:
 - a) Copies of approved shop drawings.
 - d. Equipment Start-Ups:
 - 1) Include copies of equipment start-up checklists required in individual Sections of Division 23.

1.3 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Perform work in accordance with applicable provisions of Gas Ordinances applicable to Project. Provide materials and labor necessary to comply with rules, regulations, and ordinances.
 - 2. In case of differences between building codes, laws, local ordinances, utility company regulations, and Contract Documents, the most stringent shall govern. Notify Architect in writing of such differences before performing work affected by such differences.
 - 3. Identification:
 - a. Motor and equipment name plates as well as applicable UL / ULC and AGA / CGA labels shall be in place when Project is turned over to Owner.
- B. Qualifications: Requirements of Section 01 4301 applies, but not limited to following:
 - 1. Company:
 - a. Company specializing in performing work of this section.
 - 1) Minimum five (5) years' experience in HVAC installations.
 - 2) Minimum five (5) satisfactorily completed installations in past three (3) years of projects similar in size, scope, and complexity required for this project before bidding.
 - b. Upon request, submit documentation.

2. Installer:
 - a. Licensed for area of Project.
 - b. Designate one (1) individual as project foremen who shall be on site at all times during installation and experienced with installation procedures required for this project.
 - c. Upon request, submit documentation.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 1. Accept valves on site in shipping containers with labeling in place.
- B. Storage And Handling Requirements:
 1. In addition to requirements specified in Division 01:
 - a. Stored material shall be readily accessible for inspection by Architect until installed.
 - b. Store items subject to moisture damage, such as controls, in dry, heated spaces.
 - c. Provide temporary protective coating on cast iron and steel valves.
 - d. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.
 2. Protect bearings during installation. Thoroughly grease steel shafts to prevent corrosion.

1.5 WARRANTY

- A. Manufacturer Warranty:
 1. Provide certificates of warranty for each piece of equipment made out in favor of Owner. Clearly record 'start-up' date of each piece of equipment on certificate.
- B. Special Warranty:
 1. Guarantee HVAC systems to be free from noise in operation that may develop from failure to construct system in accordance with Contract Documents.
 2. If HVAC sub-contractor with offices located more than 150 miles from Project site is used, provide service / warranty work agreement for warranty period with local HVAC sub-contractor approved by Architect. Include copy of service / warranty agreement in warranty section of Operation And Maintenance Manual.

PART 2 - PRODUCTS

2.1 COMPONENTS

- A. Components shall bear Manufacturer's name and trade name. Equipment and materials of same general type shall be of same make throughout work to provide uniform appearance, operation, and maintenance.
- B. Pipe And Pipe Fittings:
 1. Use domestic made pipe and pipe fittings on Project.
 2. Weld-O-Let and Screw-O-Let fittings are acceptable.
- C. Sleeves:
 1. In Framing: Standard weight galvanized iron pipe, Schedule 40 PVC, or 14 ga galvanized sheet metal two sizes larger than bare pipe or insulation on insulated pipe.
 2. In Concrete And Masonry: Sleeves through outside walls, interior shear walls, and footings shall be schedule 80 black steel pipe with welded plate.
- D. Valves:
 1. Valves of same type shall be of same manufacturer.

PART 3 - EXECUTION

3.1 INSTALLERS

- A. Acceptable Installers:
1. AMS – Justin Vigh (801) 973-4707 Robert Bender (801) 755-0463
 2. Custom Mechanical Design – Kurt Giles (801) 296-2600
 3. Allied Mechanical – Josh Richins (801) 510-1377 Wally Erickson (801) 319-8083
 4. Sorenson Heating & A/C – Harold Sorenson (801) 446-6412
 5. Triple T – Les Johnson (801) 420-1353

3.2 EXAMINATION

- A. Drawings:
1. HVAC Drawings show general arrangement of piping, ductwork, equipment, etc. Follow as closely as actual building construction and work of other trades will permit.
 2. Consider Architectural and Structural Drawings part of this work insofar as these drawings furnish information relating to design and construction of building. These drawings take precedence over HVAC Drawings.
 3. Because of small scale of Drawings, it is not possible to indicate all offsets, fittings, and accessories that may be required. Investigate structural and finish conditions affecting this work and arrange work accordingly, providing such fittings, valves, and accessories required to meet conditions.
- B. Verification Of Conditions:
1. Examine premises to understand conditions that may affect performance of work of this Division before submitting proposals for this work. Examine adjoining work on which mechanical work is dependent for efficiency and report work that requires correction.
 2. No subsequent allowance for time or money will be considered for any consequence related to failure to examine site conditions.
 3. Ensure that items furnished fit space available. Make necessary field measurements to ascertain space requirements including those for connections and furnish and install equipment of size and shape so final installation suits true intent and meaning of Contract Documents. If approval is received by Addendum or Change Order to use other than originally specified items, be responsible for specified capacities and for ensuring that items furnished will fit space available.
 4. Check that slots and openings provided under other Divisions through floors, walls, ceilings, and roofs are properly located. Perform cutting and patching caused by neglecting to coordinate with Divisions providing slots and openings at no additional cost to Owner.
- C. Unforeseen Conditions:
1. Relocate/or remove and reinstall ducts, piping, grilles, dampers, louvers, fixtures or any other mechanical equipment or devices which are encountered during demolition which conflict with the new construction or which are to accommodate the new construction. Any equipment, piping, grilles, dampers, louvers or fixtures to remain shall be reinstalled at the completion of this work.

3.3 PREPARATION

- A. Changes Due To Equipment Selection:
1. Where equipment specified or otherwise approved requires different arrangement or connections from that shown in Contract Documents, submit drawings, if requested by Architect, showing proposed installations.
 2. If proposed changes are approved, install equipment to operate properly and in harmony with intent of Contract Documents. Make incidental changes in piping, ductwork, supports, installation, wiring, heaters, panelboards, and as otherwise necessary.
 3. Provide any additional motors, valves, controllers, fittings, and other additional equipment required for proper operation of system resulting from selection of equipment.

4. Be responsible for the proper location of roughing-in and connections provided under other Divisions.

3.4 INSTALLATION

- A. Interface With Other Work:
 1. Furnish sleeves, inserts, supports, and equipment that are to be installed by others in sufficient time to be incorporated into construction as work proceeds. Locate these items and see they are properly installed.
 2. Electrical: Furnish exact location of electrical connections and complete information on motor controls to installer of electrical system.
 3. Testing And Balancing:
 - a. Put HVAC systems into full operation and continue their operation during each working day of testing and balancing.
 - b. Make changes in pulleys, belts, fan speeds, and dampers or add dampers as required for correct balance as recommended by Testing And Balancing Agency and at no additional cost to Owner.
- B. Cut carefully to minimize necessity for repairs to previously installed or existing work. Do not cut beams, columns, or trusses.
- C. Locating Equipment:
 1. Arrange pipes, ducts, and equipment to permit ready access to valves, cocks, unions, traps, filters, starters, motors, control components, and to clear openings of doors and access panels.
 2. Adjust locations of pipes, ducts, switches, panels, and equipment to accommodate work to interferences anticipated and encountered.
 3. Install HVAC work to permit removal of equipment and parts of equipment requiring periodic replacement or maintenance without damage to or interference with other parts of equipment or structure.
 4. Determine exact route and location of each pipe and duct before fabrication.
 - a. Right-Of-Way:
 - 1) Lines that pitch shall have right-of-way over those that do not pitch. For example, steam, steam condensate, and drains shall normally have right-of-way.
 - 2) Lines whose elevations cannot be changed shall have right-of-way over lines whose elevations can be changed.
 - b. Offsets, Transitions, and Changes in Direction:
 - 1) Make offsets, transitions, and changes in direction in pipes and ducts as required to maintain proper head room and pitch of sloping lines whether or not indicated on Drawings.
 - 2) Furnish and install all traps, air vents, sanitary vents, and devices as required to effect these offsets, transitions, and changes in direction.
- D. Piping:
 1. Furnish and install complete system of piping, valved as indicated or as necessary to completely control entire apparatus.
 - a. Pipe drawings are diagrammatic and indicate general location and connections. Piping may have to be offset, lowered, or raised as required or directed at site. This does not relieve this Division from responsibility for proper erection of systems of piping in every respect.
 - b. Arrange piping to not interfere with removal of other equipment, ducts, or devices, or block access to doors, windows, or access openings.
 - 1) Arrange so as to facilitate removal of tube bundles.
 - 2) Provide accessible flanges or ground joint unions, as applicable for type of piping specified, at connections to equipment and on bypasses.
 - a) Make connections of dissimilar metals with di-electric unions.
 - b) Install valves and unions ahead of traps and strainers. Provide unions on both sides of traps.
 - 3) Do not use reducing bushings, street elbows, bull head tees, close nipples, or running couplings.

- 4) Install piping systems so they may be easily drained. Provide drain valves at low points and manual air vents at high points in hot water heating and cooling water piping.
- 5) Install piping to insure noiseless circulation.
- 6) Place valves and specialties to permit easy operation and access. Valves shall be regulated, packed, and glands adjusted at completion of work before final acceptance.
- c. Do not install piping in shear walls.
2. Properly make adequate provisions for expansion, contraction, slope, and anchorage.
 - a. Cut piping accurately for fabrication to measurements established at site. Remove burr and cutting slag from pipes.
 - b. Work piping into place without springing or forcing. Make piping connections to pumps and other equipment without strain at piping connection. Remove bolts in flanged connections or disconnect piping to demonstrate that piping has been so connected, if requested.
 - c. Make changes in direction with proper fittings.
 - d. Expansion of Thermoplastic Pipe:
 - 1) Provide for expansion in every 30 feet of straight run.
 - 2) Provide 12 inch offset below roof line in each vent line penetrating roof.
3. Provide sleeves around pipes passing through concrete or masonry floors, walls, partitions, or structural members. Do not place sleeves around soil, waste, vent, or roof drain lines passing through concrete floors on grade. Seal sleeves with specified sealants.
 - a. Sleeves through floors shall extend 1/4 inch above floor finish in mechanical equipment rooms above basement floor. In other rooms, sleeves shall be flush with floor.
 - b. Sleeves through floors and foundation walls shall be watertight.
4. Provide spring clamp plates (escutcheons) where pipes run through walls, floors, or ceilings and are exposed in finished locations of building. Plates shall be chrome plated heavy brass of plain pattern and shall be set tight on pipe and to building surface.
5. Remove dirt, grease, and other foreign matter from each length of piping before installation.
 - a. After each section of piping used for movement of water or steam is installed, flush with clean water, except where specified otherwise.
 - b. Arrange temporary flushing connections for each section of piping and arrange for flushing total piping system.
 - c. Provide temporary cross connections and water supply for flushing and drainage and remove after completion of work.
- E. Penetration Firestops: Install Penetration Firestop System appropriate for penetration at HVAC system penetrations through walls, ceilings, roofs, and top plates of walls.
- F. Sealants:
 1. Seal openings through building exterior caused by penetrations of elements of HVAC systems.
 2. Furnish and install acoustical sealant to seal penetrations through acoustically insulated walls and ceilings.

3.5 REPAIR / RESTORATION

- A. Each Section of this Division shall bear expense of cutting, patching, repairing, and replacing of work of other Sections required because of its fault, error, tardiness, or because of damage done by it.
 1. Patch and repair walls, floors, ceilings, and roofs with materials of same quality and appearance as adjacent surfaces unless otherwise shown.
 2. Surface finishes shall exactly match existing finishes of same materials.

3.6 FIELD QUALITY CONTROL

- A. Field Tests:
 1. Perform tests on HVAC piping systems. Furnish devices required for testing purposes.
- B. Non-Conforming Work:
 1. Replace material or workmanship proven defective with sound material at no additional cost to Owner.

2. Repeat tests on new material, if requested.

3.7 SYSTEM START-UP

- A. Off-Season Start-up:
 1. If Substantial Completion inspection occurs during heating season, schedule spring start-up of cooling systems. If inspection occurs during cooling season, schedule autumn start-up for heating systems.
 2. Notify Owner seven days minimum before scheduled start-up.
 3. Time will be allowed to completely service, test, check, and off-season start systems. During allowed time, train Owner's representatives in operation and maintenance of system.
 4. At end of off-season start-up, furnish Owner with letter confirming that above work has been satisfactorily completed.
- B. Preparations that are to be completed before start up and operation include, but are not limited to, following:
 1. Dry out electric motors and other equipment to develop and properly maintain constant insulation resistance.
 2. Make adjustments to insure that:
 - a. Equipment alignments and clearances are adjusted to allowable tolerances.
 - b. Nuts and bolts and other types of anchors and fasteners are properly and securely fastened.
 - c. Packed, gasketed, and other types of joints are properly made up and are tight and free from leakage.
 - d. Miscellaneous alignments, tightenings, and adjustings are completed so systems are tight and free from leakage and equipment performs as intended.
 3. Motors and accessories are completely operable.
 4. Inspect and test electrical circuitry, connections, and voltages to be properly connected and free from shorts.
 5. Adjust drives for proper alignment and tension.
 6. Make certain filters in equipment for moving air are new and of specified type.
 7. Properly lubricate and run-in bearings in accordance with Manufacturer's directions and recommendations.

3.8 CLEANING

- A. Clean exposed piping, ductwork, and equipment.
- B. No more than one week before Final Inspection, flush out bearings and clean other lubricated surfaces with flushing oil. Provide best quality and grade of lubricant specified by Equipment Manufacturer.
- C. Replace filters in equipment for moving air with new filters of specified type no more than one week before Final Inspection.

3.9 CLOSEOUT ACTIVITIES

- A. Instruction Of Owner:
 1. Instruct building maintenance personnel and Stake Physical Facilities Representative in operation and maintenance of mechanical systems utilizing Operation And Maintenance Manual when so doing.
 - a. Minimum Instruction Periods:
 - 1) HVAC: Four hours.
 - 2) Temperature Control: Four hours. (refer to Section 23 0933 for Training Requirements)
 - b. Conduct instruction periods after Substantial Completion inspection when systems are properly working and before final payment is made. None of these instructional periods shall overlap another.

3.10 PROTECTION

- A. Protect piping systems from entry of foreign materials by temporary covers, completing sections of the work, and isolating parts of completed system. Cap or plug open ends of pipes and equipment to keep dirt and other foreign materials out of system. Do not use plugs of rags, wool, cotton waste, or similar materials.
- B. Do not operate pieces of equipment used for moving supply air without proper air filters installed properly in system.
- C. After start-up, continue necessary lubrication and be responsible for damage to bearings while equipment is being operated up to Substantial Completion.

3.11 SEISMIC RESTRAINT

- A. Restrain all equipment, piping, and ductwork in compliance with the Authority Having Jurisdiction and the Building Code.

END OF SECTION

SECTION 23 0529

HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 SUMMARY

- A. Includes But Not Limited To:
 - 1. Common hanger and support requirements and procedures for HVAC systems.
- B. Related Requirements:
 - 1. Section 05 0523: 'Metal Fastening' for quality and requirements for welding.
 - 2. Section 07 8400: 'Firestopping' for quality of Penetration Firestop Systems to be used on Project and submittal requirements.
 - 3. Sections Under 09 9000 Heading: Painting of mechanical items requiring field painting.
 - 4. Slots and openings through floors, walls, ceilings, and roofs provided under other Divisions in their respective materials.

1.2 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Manufacturer's catalog data for each manufactured item.

PART 2 - PRODUCTS

2.1 ASSEMBLIES

- A. Manufacturers:
 - 1. Class Two Quality Standard Approved Manufacturers. See Section 01 6200:
 - a. Anvil International, Portsmouth, NH www.anvilintl.com.
 - b. Cooper B-Line, Highland, IL www.cooperblines.com.
 - c. Erico International, Solon, OH www.erico.com.
 - d. Hilti Inc, Tulsa, OK www.hilti.com.
 - e. Minerallac, Hampshire, IL www.minerallac.com.
 - f. Thomas & Betts, Memphis, TN www.superstrut.com.
 - g. Unistrut, Wayne, MI www.unistrut.com.

- B. Performance:
 - 1. Design Criteria:
 - a. Support rods for single pipe shall be in accordance with following table:

Rod Diameter	Pipe Size
3/8 inch	2 inches and smaller
1/2 inch	2-1/2 to 3-1/2 inches

- b. Support rods for multiple pipes supported on steel trapeze hangers shall be in accordance with following table:

Rods		Number of Pipes per Hanger for Each Pipe Size						
No.	Diameter	2 Inch	2.5 Inch	3 Inch	4 Inch	5 Inch	6 Inch	8 Inch
2	3/8 Inch	Two	0	0	0	0	0	0
2	1/2 Inch	Three	Three	Two	0	0	0	0

- 1) Size trapeze angles so bending stress is less than 10,000 psi.

C. Materials:

1. Hangers, Rods, Channels, Attachments, And Inserts:
 - a. Galvanized and UL approved for service intended.
 - b. Support horizontal piping from clevis hangers or on roller assemblies with channel supports, except where trapeze type hangers are explicitly shown on Drawings. Hangers shall have double nuts.
 - c. Class Two Quality Standards:
 - 1) Support insulated pipes with clevis hanger equal to Anvil Fig 260 or roller assembly equal to Anvil Fig 171 with an insulation protection shield equal to Anvil Fig 167. Gauge and length of shield shall be in accordance with Anvil design data.
 - 2) Except uninsulated copper pipes, support uninsulated pipes from clevis hanger equal to Anvil Fig 260. Support uninsulated copper pipe from hanger equal to Anvil Fig CT-65 copper plated hangers and otherwise fully suitable for use with copper tubing.
 - d. Riser Clamps For Vertical Piping:
 - 1) Class Two Quality Standard: Anvil Figure 261.
 - e. Concrete Inserts:
 - 1) Suitable for special nuts size 3/8 inch through 7/8 inch with yoke to receive concrete reinforcing rods, and with malleable iron lugs for attaching to forms.
 - 2) Class Two Quality Standards:
 - a) Standard Inserts: Anvil Figure 282.
 - 3) Class One Quality Standards:
 - a) Continuous Inserts: Unistrut P-3200 series.
 - b) Acceptable Manufacturers: Hilti, Thomas & Betts.
 - c) Equal as approved by Architect before installation. See Section 01 6200.
 - f. Equipment Support Channel:
 - 1) Class One Quality Standard: Unistrut P1000.
 - 2) Acceptable Manufacturers: Hilti, Thomas & Betts.
 - 3) Equal as approved by Architect before installation. See Section 01 6200.
 - g. Swivel Attachment:
 - 1) Class One Quality Standard: Unistrut EM3127.
 - 2) Acceptable Manufacturers: Hilti, Thomas & Betts.
 - 3) Equal as approved by Architect before installation. See Section 01 6200.

EXECUTION**2.2 INSTALLATION****A. Piping:**

1. Properly support piping and make adequate provisions for expansion, contraction, slope, and anchorage.
 - a. Except for underground pipe, suspend piping from roof trusses or clamp to vertical walls using support channels and clamps. Do not hang pipe from other pipe, equipment, or ductwork. Laying of piping on any building element is not allowed.
 - b. Supports For Horizontal Piping:
 - 1) Support metal piping at 96 inches mm on center maximum for pipe 1-1/4 inches or larger and 72 inches on center maximum for pipe 1-1/8 inch or less.
 - 2) Support thermoplastic pipe at 48 inches on center maximum.
 - 3) Provide support at each elbow. Install additional support as required.
 - c. Supports for Vertical Piping:
 - 1) Place riser clamps at each floor or ceiling level.
 - 2) Securely support clamps by structural members, which in turn are supported directly from building structure.
 - 3) Provide clamps as necessary to brace pipe to wall.

END OF SECTION

SECTION 23 0553**IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But not Installed Under This Section:
1. Identification of HVAC piping and equipment as described in Contract Documents including:
 - a. Paint identification for gas piping used in HVAC equipment.
 - b. Stencils and band colors for gas piping used in HVAC equipment.
- B. Related Requirements:
1. Section 22 0529: 'Hangers And Supports For Plumbing' for field installation of pipe stencils and band colors for identification for piping used with HVAC equipment.

PART 2 - PRODUCTS**2.1 SYSTEMS**

- A. Description:
1. Abbreviations for Pipe Stencils and Equipment Identification and Band Colors for Pipe Identification:
 - a. Apply stenciled symbols and continuous painting as follows:

Pipe Type	Pipe Color	Symbol
Gas	Yellow	GAS
- B. Materials:
1. Category Four Approved Products and Manufacturers. See Section 01 6200 for definitions of Categories:
 - a. Products listed in edition of MPI Approved Product List current at time of bidding and later are approved, providing they meet VOC requirements in force where Project is located.
 2. Description:
 - a. Ferrous Metal:
 - 1) New Surfaces: Use MPI(a) INT 5.1B Waterborne Light Industrial Finish system.
 - 2) Previously Finished Surfaces: Use MPI(r) RIN 5.1B Waterborne Light Industrial Finish system.
 3. Performance Requirements:
 - a. New Surfaces: MPI Premium Grade finish requirements.
 - b. Deteriorated Existing Surfaces: MPI Premium Grade finish requirements.
 - c. Sound Existing Surfaces: MPI Custom Grade finish requirements.
 - d. Maintain specified colors, shades, and contrasts.
 4. Paint (one coat):
 - a. Primer:
 - 1) Ferrous Metal:
 - a) MPI 107, 'Primer, Rust-Inhibitive, Water Based'.
 - (1) Color: white.
 - b. Finish Coat (two coats):
 - 1) Ferrous Metal:
 - a) MPI 153, 'Light Industrial Coating, Interior, Water Based, Semi-Gloss (MPI Gloss Level 5)'.
 5. Labels:
 - a. Equipment Identification:
 - 1) Black formica, with white reveal when engraved.

- 2) Lettering to be 3/16 inch high minimum.

PART 3 - EXECUTION

3.1 APPLICATION

- A. Labels:
 1. Identify following items with specified labels fastened to equipment with screws (unless noted otherwise):
 - a. ATC relay panels.
 - b. Unitary Controllers in mechanical spaces (attach label to wall directly above or below controllers).
 - c. New Furnaces.
 - d. New Condensing Units.
 2. Engrave following data from Equipment Schedules on Drawings onto labels:
 - a. Equipment mark.
 - b. Area served.
 - c. Thermostat zone number, when different from equipment mark.
 - d. Panel and breaker from which unit is powered.
- B. Painting:
 1. New Surfaces:
 - a. Remove rust spots by sanding and immediately spot prime. If all traces of rust cannot be removed, apply rust blocker recommended by Paint Manufacturer before applying full primer coat.
 2. Existing Surfaces:
 - a. Remove deteriorated existing paint down to sound substrate by scraping and sanding. Feather edges of existing paint by sanding to be smooth with adjacent surfaces. Spot prime bare metal surfaces immediately.
 - b. Remove rust spots by sanding and immediately spot prime. If all traces of rust cannot be removed, apply rust blocker recommended by Paint Manufacturer before applying full primer coat.
 - c. Clean existing sound painted surfaces as well as scraped and sanded existing painted surfaces as recommended by Paint Manufacturer.
 - d. Apply prime coat over entire surface to be painted.
 - e. Lightly sand entire surface.
 - f. Clean surface as recommended by Paint Manufacturer.
 - g. Apply finish coats.
 3. Leave equipment in like-new appearance.
 4. Only painted legends, directional arrows, and color bands are acceptable.
 5. Locate identifying legends, directional arrows, and color bands at following points on exposed piping of each piping system:
 - a. Adjacent to each item of equipment.
 - b. At point of entry and exit where piping goes through wall.
 - c. On each riser and junction.
 - d. Every 25 feet on long continuous lines.
 - e. Stenciled symbols shall be one inch high and black.

END OF SECTION

SECTION 23 0713**DUCT INSULATION****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Furnish and install thermal wrap duct insulation as described in Contract Documents.
- B. Related Requirements:
1. Section 23 3114: 'Low-Pressure Metal Ducts'.
 2. Section 23 3300: 'Acoustic Duct Accessories' for duct liner.

PART 2 - PRODUCTS**2.1 MANUFACTURERS**

- A. Manufacturer Contact List:
1. Certainteed St Gobain, Valley Forge, PA www.certainteed.com.
 2. Johns-Manville, Denver, CO www.jm.com.
 3. Knauf Fiber Glass, Shelbyville, IN www.knauffiberglass.com or Toronto, ON (416) 593-4322.
 4. Manson Insulation Inc, Brossard, QB www.isolationmanson.com.
 5. Owens-Corning, Toledo, OH or Owens-Corning Canada Inc, Willowdale, ON www.owenscorning.com.

2.2 MATERIALS

- A. Thermal Wrap Duct Insulation:
1. 1-1/2 inch (38 mm) or 3 inch (76 mm) thick fiberglass with factory-laminated, reinforced aluminum foil scrim kraft facing and density of 0.75 lb / per cu ft (12 kg / per cu m).
 2. Thermal Conductivity: 0.27 BTU in/HR SF deg F at 75 deg F (24 deg C) maximum.
 3. Type One Acceptable Products:
 - a. Type 75 standard duct insulation by Certainteed St Gobain.
 - b. Microlite FSK by Johns-Manville.
 - c. Duct Wrap FSK by Knauf Fiber Glass.
 - d. Alley Wrap FSK by Manson Insulation Inc.
 - e. FRK by Owens-Corning.
 - f. Equal as approved by Architect before bidding. See Section 01 6200.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Thermal Wrap Duct Insulation:
1. Install insulation as follows:
 - a. Within Building Insulation Envelope:
 - 1) 1-1/2 inches (38 mm) thick on rectangular outside air ducts and combustion air ducts.
 - 2) 1-1/2 inches (38 mm) thick on all round ducts.
 - b. Outside Building Insulation Envelope:
 - 1) 3 inch (76 mm) thick on round supply and return air ducts.

- 2) 1-1/2 inch (38 mm) thick on rectangular, acoustically lined, supply and return air ducts.
2. Wrap insulation tightly on ductwork with circumferential joints butted and longitudinal joints overlapped minimum 2 inches (50 mm).
 - a. Do not compress insulation except in areas of structural interference. Minimum thickness at corners shall be one inch (25 mm) thick.
 - b. Remove insulation from lap before stapling.
 - c. Staple seams at approximately 16 inches (400 mm) on center with outward clenching staples.
 - d. Seal seams with foil vapor barrier tape or vapor barrier mastic. Seal penetrations of facing to provide vapor tight system.
- B. Insulate outside of ceiling diffusers and diffuser drops same as ductwork.

END OF SECTION

SECTION 23 0719**HVAC PIPING INSULATION****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Furnish and install insulation on above ground refrigerant piping and fittings as described in Contract Documents.
- B. Related Requirements:
1. Section 23 0501: 'General HVAC Requirements'.
 2. Section 23 2300: 'Refrigerant Piping'.

1.2 DELIVERY, STORAGE, AND HANDLING

- A. Storage And Handling Requirements:
1. Keep materials and work dry and free from damage.
 2. Replace wet or damaged materials at no additional cost to Owner.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
1. Manufacturer Contact List:
 - a. Armacell, Mebane, NC www.armacell.com.
 - b. Nitron Industries, Thousand Oaks, CA www.nitronindustries.com.
 - c. Nomac, Zebulon, NC www.nomaco.com.
- B. Materials:
1. Refrigeration Piping System:
 - a. Thickness:

Pipe Size, Outside Diameter	Insulation Thickness
One inch and smaller	1/2 Inch
1-1/8 to 2 inch	3/4 Inch

- 1) One inch sheet for fittings as recommended by Manufacturer.
- 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) AP Armaflex 25/50 by Armacell.
 - b) Nitrolite by Nitron Industries. White only for exterior.
 - c) Nomaco K-Flex.
- b. Joint Sealer:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Armacell 520 by Armacell.
 - b) Namaco K-Flex R-373.
- c. Insulation Tape:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Armaflex AP Insul Tape by Armacell.
 - b) FT182 Tape by Nitron Industries.

- c) Elastomeric Foamtape by Nomac K-Flex.
- d. Exterior Finish:
 - 1) For application to non-white, exterior insulation.
 - 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) WB Armaflex Finish by Armacell.
 - b) R-374 Protective Coating by Nomaco K-Flex.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before application of insulating materials, brush clean surfaces to be insulated and make free from rust, scale, grease, dirt, moisture, and any other deleterious materials.
- B. Use drop cloths over equipment and structure to prevent adhesives and other materials spotting the work.

3.2 INSTALLATION

- A. Refrigeration System Piping System:
 - 1. General:
 - a. Install insulation in snug contact with pipe.
 - 1) Insulate flexible pipe connectors.
 - 2) Insulate liquid line upstream of thermal expansion valves with insulating tape.
 - 3) Insulate fittings with sheet insulation and as recommended by Manufacturer.
 - b. Slip insulation on tubing before tubing sections and fittings are assembled keeping slitting of insulation to a minimum.
 - c. Do not install insulation on lines through clamp assembly of pipe support. Butt insulation up against sides of clamp assembly.
 - d. Stagger joints on layered insulation. Seal joints in insulation.
 - e. Install insulation exposed outside building so 'slit' joint seams are placed on bottom of pipe.
 - f. Paint exterior exposed, non-white insulation with two coats of specified exterior finish.
 - 2. System Requirements:
 - a. Condensing Units: Install insulation on above ground refrigerant suction piping and fittings, including thermal bulb and liquid line upstream of thermal expansion valve.

3.3 FIELD QUALITY CONTROL

- A. Non-Conforming Work:
 - 1. Method of installing insulation shall be subject to approval of Architect. Sloppy or unworkmanlike installations are not acceptable.

3.4 CLEANING

- A. Leave premises thoroughly clean and free from insulating debris.

END OF SECTION

SECTION 23 0933**ELECTRIC AND ELECTRONIC CONTROL SYSTEM FOR HVAC****PART 1 - GENERAL****1.1 SUMMARY**

A. Includes But Not Limited To:

1. Furnish and install automatic temperature control system as described in Contract Documents.
2. Furnish and install conductors and make connections to control devices, motors, and associated equipment.
3. Assist in air test and balance procedure.

B. Related Requirements:

1. Section 01 4546: Duct testing, adjusting, and balancing of ductwork.
2. Section 23 0501: Common HVAC Requirements.
3. Section 23 3300: Furnishing and installing of temperature control dampers.
4. Division 26:
 - a. Furnishing and installing of raceway, conduit, and junction boxes, including pull wires, for temperature control system except as noted above.
 - b. Power wiring to magnetic starters, disconnect switches, and motors.
 - c. Motor starters and disconnect switches, unless integral with packaged equipment.

1.2 SUBMITTALS

A. Action Submittals:

1. Product Data:
 - a. Installer to provide product literature or cut sheets for all products specified in Project.
 - b. Installer to provide questions of control equipment locations to Mechanical Engineer prior to installation.

B. Informational Submittals:

1. Certificates:
 - a. Installer must provide 'Certificate of Sponsorship' signed from Approved Distributor with bid confirming Installer sponsorship.

C. Closeout Submittals:

1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Operations and Maintenance Data:
 - 1) Leave with O&M Manual specified in Section 23 0501.
 - b. Record Documentation:
 - 1) Installer's 'Certificate of Sponsorship'.

1.3 QUALITY ASSURANCE

A. Qualifications: Requirements of Section 01 4301 applies, but is not limited to the following:

1. Installer:
 - a. Before bidding, obtain sponsorship from a local, Approved Distributor specified under PART 2 PRODUCTS of this specification. Initial requirements for sponsorship are:
 - 1) Receive LCBS Connect product training from Approved Distributor.
 - 2) Installer to provide Distributor sponsorship by submitting 'Certificate of Sponsorship' as Informational Submittal with bid. Certificate available as Attachment in this Specification.

PART 2 - PRODUCTS**2.1 SYSTEMS****A. Manufacturers:**

1. Manufacturer Contact List:
 - a. Honeywell Inc, Minneapolis, MN www.honeywell.com.
 - 1) Primary Contact: Chris Brinkerhoff, (801) 550-3344, chris.brinkerhoff@honeywell.com.
 - b. Insul_Guard, Salt Lake City, UT:
 - 1) Primary Contact: Dan Craner, (801) 518-3733, insul_guard@comcast.net.
 - c. System Sensor, St Charles, IL www.systemsensor.com.
 - d. Zimmerman Technologies, Renton, WA:
 - 1) Primary Contact: Tracy Zimmerman, (425) 255-1906, zimmtech@yahoo.com.

B. Distributors: Obtain LCBS Connect control devices, RP panels, sensors, actuators and other control equipment from following Sponsoring Approved Distributors. See Section 01 4301:

1. Utah:
 - a. Control Equipment Co: (800) 452-1457 rhowe@controlequiputah.com Ray Howe.
 - b. Building Controls & Solutions: (801) 214-3313 Kathy.Wright@relevantsolutions.com Kathy Wright.

C. Performance:

1. Design Criteria:
 - a. Honeywell LCBS Connect control system with cloud based gateway:
 - 1) General Requirements:
 - a) Controls multistage equipment, dehumidification and ventilation with 2 wire connection to controller interface location in occupied space.
 - b) Adjustable backlight to controller interface module from 15%-100%en after 30 seconds of setting adjustments.
 - c) System controllers can be programmed from the interface module or from the cloud service.
 - d) LCBS Connect controller utilizes echelon communication network with the controller located near the mechanical equipment and the system interface located in the occupied space.
 - e) System shall control outdoor ventilation air based upon system occupancy of electric / electronic actuation of dampers.
 - f) CO2 (Carbon Dioxide) sensors will open ventilation dampers only when CO2 exceeds 1000 ppm.
 - g) LCBS Connect devices access via internet Chrome browser via gateway.
 - h) Wired room temperature sensors may be added as specified.
 - 2) System Requirements:
 - a) Up to 3 Heat/2 Cool Heat Pumps; Up to 3 Heat/2 Cool Conventional Systems.
 - b) Tri-Lingual display (Selectable for English, Spanish, or French).
 - c) 18 to 30 Vac.
 - d) 50 Hz; 60 Hz.
 - e) System switch to include Auto changeover for Heat-Cool.
 - f) 7-Day Programming.
 - g) 365-Day Event Scheduling.
 - h) Display Security Lockout options.
 - i) Minimum/ Maximum Temperature Range Stops.
 - j) Configurable over-ride option.
 - k) Remote Access via internet.
 - l) Dehumidification setting range 40 to 80% RH.

D. Components:

1. Controller, Wall Module:
 - a. Controller and Display Kit:
 - 1) Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - a) Part Number Honeywell YCRL6438SR1000 consisting of following:

- (1) Unitary Controller: Honeywell CRL6438SR1000
 - (2) Wall Module: Honeywell TS120
 - b) Wall Cover Plate: Honeywell. 50002883-001.
 - c) Discharge Air / Return Air Sensors: Honeywell C7041B2005 20k ohms.
 - d) Outdoor Air Sensor: Honeywell C7041F2006.
 - e) Indoor Air Sensor: Sylk bus network; Honeywell TR40
 - f) Averaging sensor: Sylk bus network; Honeywell TR40
 - b. Internet Gateway Module(s): One (1) module per thirty (30) controllers.
 - 1) Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - a) (Existing) LCBS Connect Gateway Module: Honeywell LGW1000.
2. Sealant Compound:
 - a. Description:
 - 1) Non hardening waterproof, vapor proof, self-adhesive for hot or cold application for sealing conduit openings against drafts, dust moisture and noise.
 - b. Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - 1) Duct Seal Compound No. DS-130 by Gardner Bender, Menomonee Falls , WI.
www.gardnerbender.com.
 - 2) Thumb-Tite Sealing Compound No. 4216-92 by Nu-Calgon, St. Louis, MO
www.nucalgon.com.
3. Transformer:
 - a. 120 / 24 V, 50VA Honeywell AT150F.
 - b. 120 / 24 V, 75VA Honeywell AT175F.
4. Damper Actuators:
 - a. Electric type equipped for Class I wiring.
 - b. Shall not consume power during UNOCCUPIED cycle or use chemicals or expandable media.
 - c. Have built in spring return.
 - d. Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - 1) Honeywell MS8105A1030/U.
5. Conductors:
 - a. Color-coded and No. 16 and No. 12 AWG Type TWN, TFN, or THHN, stranded.
 - b. Thermostat Cable: 12, 8, or 4 conductor, 18AWG solid copper wire, insulated with high-density polyethylene. Conductors parallel enclosed in brown PVC jacket (22 AWG cable not allowed).
 - c. Echelon Network Ebus Communicating Cable:
 - 1) Class Two Quality Standard. See Section 01 6200:
 - a) CAT 4, 22 gauge (0.025 in), twisted pair, non-plenum and non-shielded cable.
6. CO₂ (Carbon Dioxide) Return Air Sensor:
 - a. Duct mount with display.
 - b. Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - 1) Honeywell: C7232B1006.
- E. Operation Sequences:
1. Programmable controller shall control Unoccupied and Occupied status of fan system based on adjustable seven-day program. Fan shall run continuously in Occupied Mode and cycle in Unoccupied Mode.
 2. Adjustable heating and cooling set points shall control space temperature by activating either heating or cooling equipment. Programmable thermostat provides automatic change over between heating and cooling.
 3. Controller provides optional override by allowing timed override of program by pushing override on controller touch screen. This shall activate controller to Occupied Mode and system shall control to Occupied set point.
 4. Minimum outdoor ventilation air damper, spring return type, shall open in controller Occupied Mode and remain closed in Unoccupied Mode.
 5. Systems with CO₂ (Carbon Dioxide) sensor to control minimum, spring return type, outdoor ventilation air damper:
 - a. Damper shall open in controller Occupied Mode only when CO₂ sensor setpoint of 1000 ppm is reached. Damper shall close if CO₂ level drops below 900 ppm.

- b. Damper shall remain closed in controller Unoccupied Mode.

PART 3 - EXECUTION

3.1 INSTALLERS

- A. Acceptable Installers. See Section 01 4301:
 1. Meet Quality Assurance Qualifications as specified in Part 1 of this specification.

3.2 INSTALLATION

- A. Interface With Other Work:
 1. Calibrate room controllers as required during air test and balance. Insulate sensor J-box with fiberglass insulation; expandable/ foam insulation is NOT acceptable.
 2. Instruct air test and balance personnel in proper use and setting of control system components.
 3. Install low voltage electrical wiring in accordance with Division 26 of these Specifications.
- B. Echelon Communication: Ebus
 1. Ebus cable needs to be installed at least 12 inches from lighting, motors, or low voltage switching cables.
- C. Safety Controls:
 1. Fresh air dampers shall close on fan shut-down, power failure, open fan motor disconnect switch, and when thermostat is in UNOCCUPIED mode.
- D. Mount damper actuators and actuator linkages external of airflow. Make certain dampers operate freely without binding or with actuator housing moving.

3.3 FIELD QUALITY CONTROL

- A. Field Tests:
 1. Calibrate, adjust, and set controls for proper operation, operate systems, and be prepared to prove operation of any part of control system. This work is to be completed before pre-substantial completion inspection.
 2. Test each individual heating, cooling, and damper control for proper operation using control system.

3.4 SYSTEM STARTUP

- A. For systems with LCBS Controller.
 1. Contractor is responsible for a fully functioning control system accessible via internet web browser. Contractor is responsible to coordinate Network start up with assistance from local IT technician. Local IT technician shall provide available ports on network switch for LCBS gateway.
 2. Contractor is responsible configuring all controllers with proper zone names, zone scheduling, proper Church conference / holiday scheduling, all to be coordinated with local FM manager. Set proper clock setting including day/month/year.
 3. Set Heating / Cooling to proper stages
 4. Set heat cycle rates to 9 cph and cooling to 4 cph.
 5. Set DO1 relay to "Occupancy".
 6. Set System switch operation to "Automatic" changeover.
 7. Set fan switch operation to "ON".
 8. Set minimum UnOcc start time for all days. No days shall be scheduled Unconfigured.
 9. Set Occupied start times to match meeting start times; provided by local FM manager.

10. Place all zone over-ride durations to one (1) hour except for Bishop and Stake area which shall be set to two (2) hours.
11. Set Occupied default heating setpoints to 70 degrees, cooling setpoints to 74 degrees.
12. Set Unoccupied default heating setpoint to 60 degrees, cooling setpoints to 90 degrees.
13. Set each zone to applicable Holiday scheduling for General & Stake Conferences.

3.5 ADJUSTING

A. LCBS controller configuration settings; the following are configuration guidelines for consistent installations:

1. Temperature Units Fahrenheit/ Celsius
2. Equipment Type Conventional/heat pump.
 - a. Stages of Heat 1,2
 - b. Stages of Cool 1,2
 - c. Fan operation in heat mode Enable Fan w/ Heat
3. Equipment Options
 - a. Leave at Default
 - b. Heating Cycles per Hour 6-9 cph
 - c. Cooling Cycles per Hour 3-4 cph
4. Recovery
 - a. Leave at Default
5. Economizer / DLC
 - a. Configure as required by control equipment.
6. Sensor Selection
 - a. Set according to averaging sensors
 - b. Set to multi sensor "Smart" when averaging.
 - c. Set Occupancy Sensor to "Disable".
7. Terminal Assignment
 - a. Set according to equipment
 - b. Set Terminal DO1 to Occupancy to control fresh air damper based upon scheduled occupancy or over-ride.
8. Dehumidification
 - a. Leave at default
 - b. See Accessory Loops
9. Miscellaneous
 - a. Leave at default
10. Sensor setting
 - a. Leave at default
 - b. Set as Required
11. Accessory Loops – Set as required
 - a. Hot water valve
 - b. Dehumidification
 - c. Other
12. Configure Zone Name (display on Home Screen).
13. Set Password to ABCD.
14. Set Occupied Setpoint
15. Set Unoccupied Setpoint
16. Set Schedule
17. MENU/ Holiday-Event Scheduler / Custom Events/ Create new event.
 - a. Eastern Time Zone:
 - 1) First Sunday in April: Occupied Chapel from 11:30 am – 6:00 pm / every year.
 - 2) First Sunday in April: Unoccupied all other zones for all day / every year.
 - 3) First Sunday in October: Occupied Chapel from 11:30 am – 6:00 pm / every year.
 - 4) First Sunday in October: Unoccupied all other zones for all day / every year.
 - b. Central Time Zone:
 - 1) First Sunday in April: Occupied Chapel from 10:30 am – 5:00 pm / every year.
 - 2) First Sunday in April: Unoccupied all other zones for all day / every year.
 - 3) First Sunday in October: Occupied Chapel from 10:30 am – 5:00 pm / every year.
 - 4) First Sunday in October: Unoccupied all other zones for all day / every year.

- c. Mountain Time Zone:
 - 1) First Sunday in April: Unoccupied all zones for all day / every year.
 - 2) First Sunday in April: Unoccupied all zones for all day / every year.
 - 3) First Sunday in October: Unoccupied all zones for all day / every year.
 - 4) First Sunday in October: Unoccupied all zones for all day / every year.
- d. Pacific Time Zone
 - 1) First Sunday in April: Occupied Chapel from 8:30 am – 3:00 pm / every year.
 - 2) First Sunday in April: Unoccupied all other zones for all day / every year.
 - 3) First Sunday in October: Occupied Chapel from 8:30 am – 3:00 pm / every year.
 - 4) First Sunday in October: Unoccupied all other zones for all day / every year.

3.6 CLOSEOUT ACTIVITIES

A. Instruction Of Owner:

- 1. Include as part of training required in Section 23 0501, following training:
 - a. Training shall be by personnel of installing company and utilize operator's manuals and as-built documentation.
 - b. Provide training in (2) two sessions including LCBS Connect sight & smart Apps for up to six (6) hours total:
 - 1) First session will occur between system completion and Substantial Completion.
 - 2) Second session will occur within forty-five (45) days of Substantial Completion when agreed upon by Owner.
 - c. Training shall include sequence of operation review, selection of displays, modification of schedules and setpoints, troubleshooting of sensors, etc, as follows:
 - 1) Control System Overview:
 - a) Show access to system through both individual controllers and Internet browser and how network works. Scheduling building at minimum for Stake and General Conference, special events.
 - 2) Controller Programming from Keypad: Instructions on developing setpoints and schedules and adjusting local zone temperatures.
 - 3) Web Internet training with local Facilities Manager during two (2) sessions.
 - a) Review all features accessible from the 'Settings' tab including Alarm points, user access, scheduling and humidity setpoints (where applied).

END OF SECTION

ATTACHMENTS

CERTIFICATE OF SPONSORSHIP
Electric and Electronic Control System for HVAC Installer

PROJECT INFORMATION (To be filled out by Installer - available from project specification):

Project Name: _____
Project Number: _____
Project Address: _____

INSTALLER INFORMATION (To be filled out by Installer):

Installer Name: _____
Installer Firm: _____
Installer Address: _____

I acknowledge and confirm the above listed Installer has received training and exhibit LCBSConnect System skills and is qualified to install the automation control system as specified for Project identified above. Our company will stand behind the Installer meeting the legal specified performance requirements.

Sponsoring Approved Honeywell Distributor Name: _____

Signature: _____ Printed Signature: _____

Date: _____

SECTION 23 1123**FACILITY NATURAL-GAS PIPING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install gas piping and fittings within building as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 23 0501: 'Common HVAC Requirements'.
 - 2. Section 23 0553: 'Identification for HVAC Piping and Equipment'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A53/A53M-12, 'Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless'.
 - b. ASTM A234/A234M-11a, 'Standard Specification for Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and High Temperature Service'.
 - 2. International Code Council (ICC):
 - a. ICC IFGC-2015: 'International Fuel Gas Code'.

1.3 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Conform to requirements of IFGC International Fuel Gas Code.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. BrassCraft, Novi, MI www.brasscraft.com.
 - b. Cimberio Valve Co Inc, Malvern, PA www.cimberio.com.
 - c. ConBraCo Industries, Inc, Matthews, NC www.conbraco.com or ConBraCo / Honeywell Ltd, Scarborough, ON (416) 293-8111.
 - d. Dormont Manufacturing Company, Export, PA www.dormont.com.
 - e. Jenkins-NH-Canada, Brantford, ON www.jenkins-nh-canada.com.
 - f. Jomar International, Madison Heights, MI www.jomar.com.
 - g. Viega MegaPressG, Wichita, KS www.viega-na.com.
 - h. Watts Regulator Co, North Andover, MA www.wattsreg.com or Watts Industries (Canada) Inc, Burlington, ON (888) 208-8927.
- B. Materials:
 - 1. Above-Ground Pipe And Fittings:
 - a. Black carbon steel, butt welded, Schedule 40 pipe meeting requirements of A53/A53M.
 - b. Welded forged steel fittings meeting requirements of ASTM A234/A234M or standard weight malleable iron screwed or all MegaPressG fittings.

2. Valves:
 - a. 125 psi (862 kPa) bronze body ball valve, UL listed.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) CIM 102.1 by Cimbrio Valve.
 - 2) Apollo Series 80-100 by ConBraCo.
 - 3) 'Red Cap' R602 by Jenkins NH Canada.
 - 4) Model T-204 by Jomar International.
 - 5) Model B-6000-UL by Watts Regulator.
3. Flexible Connector:
 - a. Type 304 stainless steel corrugated tube coated for corrosion protection.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Dormont Supr-Safe.
 - 2) BrassCraft Procoat.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Steel pipe installed through air plenums, in walls, and pipes 2-1/2 inches (64 mm) and larger shall have welded fittings and joints. Other steel pipe may have screwed, MegaPressG, or welded fittings.
 1. Install MegaPressG fittings according to Manufacturer's recommendations and with Manufacturer's recommended tools.
- B. On lines serving gas-fired equipment, install gas valves adjacent to equipment outside of equipment cabinet and easily accessible.
- C. Install 6 inch (150 mm) long minimum dirt leg, with pipe cap, on vertical gas drop serving each gas-fired equipment unit.
- D. Use fittings for changes of direction in pipe and for branch runouts.
- E. Visible gas piping inside building shall be painted yellow and labeled.

3.2 FIELD QUALITY CONTROL

- A. Field tests:
 1. Subject all portions of gas piping system, in sections or in entirety, to air pressure of 75 psig (0.52 MPa) and prove airtight for four (4) hours.
 2. Disconnect equipment not suitable for 75 psig (0.52 MPa) pressure from piping system during test period.

END OF SECTION

SECTION 23 2300**REFRIGERANT PIPING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install piping and specialties for refrigeration systems as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 23 0501: 'Common HVAC Requirements'.
 - 2. Section 23 0719: 'Refrigerant Piping Insulation'.
 - 3. Section 23 6213: 'Compressor Units: Air Conditioning (5 Ton or less)'.

1.2 REFERENCES

- A. Association Publications:
 - 1. Federal Emergency Management Agency (FEMA) / Vibration Isolation and Seismic Control Manufacturers Association (VISCMA) / American Society of Civil Engineers (ASCE):
 - a. FEMA 412, 'Installing Seismic Restraints For Mechanical Equipment' (December 2002).
 - 2. Vibration Isolation and Seismic Control Manufacturers Association (VISCMA):
 - a. VISCMA 101-15, 'Seismic Restraint Specification Guidelines for Mechanical, Electrical, and Plumbing Systems'.
 - b. VISCMA 102-12, 'Vibration Isolation Specification Guidelines for Mechanical, Electrical, and Plumbing Systems'.
- B. Definitions:
 - 1. Refrigerant: Absorbs heat by a change of state (evaporation) from liquid to a gas, and releases heat by a change of state (condenses) from gas back to a liquid.
 - 2. Vibration Isolation: Vibration reduction in which an isolation system is placed between the source of unwanted vibration and an item which needs to be shielded from the vibration.
- C. Reference Standards:
 - 1. American National Standards Institute (ANSI) / American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE):
 - a. ANSI/ASHRAE 15-2016 and 34-2016, 'Safety Standard and Designation and Classification of Refrigerants'.
 - 2. American National Standards Institute / American Welding Society:
 - a. ANSI/AWS A5.8M/A5.8-2011, 'Specification for Filler Metals for Brazing and Braze Welding'.
 - 3. American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE):
 - a. 2011 ASHRAE Handbook - HVAC Applications.
 - 1) Chapter 48, 'Noise and Vibration Control'.
 - 4. ASTM International:
 - a. ASTM A36/A36M-14, 'Standard Specification for Carbon Structural Steel'.
 - b. ASTM B280-18, 'Standard Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service'.
 - 5. National Fire Protection Association / American National Standards Institute:
 - a. NFPA 90A: 'Installation of Air-Conditioning and Ventilating Systems' (2018 or most recent edition adopted by AHJ).
 - 6. Underwriters Laboratories:
 - a. UL 2182, 'Refrigerants' (April 2006).

1.3 SUBMITTALS

- A. Action Submittals:
 - 1. Shop Drawings: Show each individual equipment and piping support.
- B. Informational Submittals:
 - 1. Qualification Statements: Technician certificate for use of HFC and HCFC refrigerants.
 - 2. Test Reports: Submit to Architect within seven days of testing.

1.4 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Refrigerants:
 - a. Underwriters Laboratories:
 - 1) Comply with requirements of UL 2182.
- B. Qualifications. Section 01 4301 applies, but is not limited to the following:
 - 1. Installer: Refrigerant piping shall be installed by refrigeration contractor licensed by State and by technicians certified in use of HFC and HCFC refrigerants.

PART 2 - PRODUCTS

2.1 COMPONENTS

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Airtec, Fall River, MA, www.noventcaps.com.
 - b. Cooper Industries, Houston, TX www.cooperindustries.com.
 - c. Cush-A-Clamp by ZSI Manufacturing, Canton, MI www.cushaclamp.com.
 - d. Elkhart Products Corp, Elkhart, IN www.elkhartproducts.com.
 - e. Emerson Climate Technologies, St Louis, MO www.emersonflowcontrols.com.
 - f. Handy & Harman Products Division, Fairfield, CT www.handy-1.com.
 - g. Harris Products Group, Cincinnati, OH www.harrisproductsgroup.com.
 - h. Henry Valve Co, Melrose Park, IL www.henrytech.com.
 - i. Hilti Inc, Tulsa, OK www.hilti.com.
 - j. Hydra-Zorb Co, Auburn Hills, MI www.hydra-zorb.com.
 - k. JB Industries, Aurora, IL www.jbind.com.
 - l. Mueller Steam Specialty, St Pauls, NC www.muellersteam.com.
 - m. Nibco Inc, Elkhart, IN www.nibco.com.
 - n. Parker Corp, Cleveland, OH www.parker.com.
 - o. Sporlan Valve Co, Washington, MO www.sporlan.com. (also ZoomLock)
 - p. Sherwood Valves, Washington, PA www.sherwoodvalve.com.
 - q. Thomas & Betts, Memphis, TN www.superstrut.com.
 - r. Unistrut, Div of Atkore International, Inc., Harvey, IL www.unistrut.com.
- B. Materials:
 - 1. Refrigerant Piping:
 - a. Meet requirements of ASTM B280, hard drawn straight lengths. Soft copper tubing not permitted.
 - b. Do not use pre-charged refrigerant lines.
 - 2. Refrigerant Fittings:
 - a. Wrought copper with long radius elbows.
 - b. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - 1) Mueller Streamline.
 - 2) Nibco Inc.
 - 3) Elkhart.

- 4) Sporlan - ZoomLock [Flame-Free Refrigerant Fittings]
3. Suction Line Traps:
 - a. Manufactured standard one-piece traps.
 - b. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - 1) Mueller Streamline.
 - 2) Nibco Inc.
 - 3) Elkhart.
 - 4) Sporlan - ZoomLock [Flame-Free Refrigerant Fittings]
4. Tee Access:
 - a. Brass:
 - 1) Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - a) JB Industries: Part #A3 Series with Factory Cap and Valve Core.
5. Connection Material:
 - a. Sporlan - ZoomLock Flame-Free Refrigerant Fittings with factory approved tools.
 - b. Brazing Rods in accordance with ANSI/AWS A5.8M/A5.8:
 - 1) Copper to Copper Connections:
 - a) Classification BCuP-4 Copper Phosphorus (6 percent silver).
 - b) Classification BCuP-5 Copper Phosphorus (15 percent silver).
 - 2) Copper to Brass or Copper to Steel Connections: Classification BAg-5 Silver (45 percent silver).
 - 3) Do not use rods containing Cadmium.
 - c. Flux:
 - 1) Type Two Acceptable Products:
 - a) Stay-Silv White Brazing Flux by Harris Products Group.
 - b) High quality silver solder flux by Handy & Harmon.
 - c) Equal as approved by Architect before use. See Section 01 6200.
6. Valves:
 - a. Manual Refrigerant Shut-Off Valves:
 - 1) Ball valves designed for refrigeration service and full line size.
 - 2) Valve shall have cap seals.
 - 3) Valves with hand wheels are not acceptable.
 - 4) Provide service valve on each liquid and suction line at compressor.
 - 5) If service valves come as integral part of condensing unit, additional service valves shall not be required.
 - 6) Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - a) Henry.
 - b) Mueller.
 - c) Sherwood.
 - d) Virginia.
7. Filter-Drier:
 - a. On lines smaller than 3/4 inch outside diameter, filter-drier shall be sealed type with brazed end connections.
 - b. Size shall be full line size.
 - c. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - 1) Emerson Climate Technologies.
 - 2) Mueller.
 - 3) Parker.
 - 4) Sporlan.
 - 5) Virginia.
8. Sight Glass:
 - a. Combination moisture and liquid indicator with protection cap.
 - b. Sight glass shall be full line size.
 - c. Sight glass connections and sight glass body shall be solid copper or brass, no copper-coated steel sight glasses allowed.
 - d. Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - 1) HMI by Emerson Climate Technologies.
9. Liquid Line Solenoid Valve:
 - a. As recommended by equipment manufacturer for long line applications.

10. Refrigerant Piping Supports:
 - a. Base, Angles, And Uprights: Steel meeting requirements of ASTM A36.
 - b. Securing Channels:
 - 1) At Free-Standing Pipe Support:
 - a) Class One Quality Standard: P-1000 channels by Unistrut.
 - b) Acceptable Manufacturers: Hilti, Thomas & Betts.
 - c) Equal as approved by Architect before installation. See Section 01 6200.
 - 2) At Wall Support:
 - a) Class One Quality Standard: P-3300 channels by Unistrut.
 - b) Acceptable Manufacturers: Hilti, Thomas & Betts.
 - c) Equal as approved by Architect before installation. See Section 01 6200.
 - 3) At Suspended Support:
 - a) Class One Quality Standard: P-1001 channels by Unistrut.
 - b) Acceptable Manufacturers: Hilti, Thomas & Betts.
 - c) Equal as approved by Architect before installation. See Section 01 6200.
 - 4) Angle Fittings:
 - a) Class One Quality Standard: P-2626 90 degree angle by Unistrut.
 - b) Acceptable Manufacturers: Hilti, Thomas & Betts.
 - c) Equal as approved by Architect before installation. See Section 01 6200.
 - c. Pipe Clamps:
 - 1) Type Two Acceptable Manufacturers:
 - a) Hydra-Zorb.
 - b) ZSI Cush-A-Clamp.
 - c) Hilti Cush-A-Clamp.
 - d) Equal as approved by Architect before installation. See Section 01 6200.
 - d. Protective Cover: 18 ga steel, hot-dipped galvanized.
11. Locking Refrigerant Cap:
 - a. Provide and install on charging valves:
 - 1) Class One Quality Standard: 'No Vent' locking refrigerant cap.
 - 2) Acceptable Manufacturers: Airtec.
 - 3) Equal as approved by Architect before installation. See Section 01 6200.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Refrigerant Lines:
 1. Install as high in upper mechanical areas as possible. Do not install underground or in tunnels.
 2. Slope suction lines down toward compressor one inch/10 feet. Locate traps at vertical rises against flow in suction lines.
 3. Comply with condensing unit manufacturer's installation instructions.
- B. Connections:
 1. Refrigeration system connections shall be copper-to-copper, copper-to-brass, or copper-to-steel type properly cleaned and brazed with specified rods. Use flux only where necessary. No soft solder (tin, lead, antimony) connections will be allowed in system.
 2. Braze manual refrigerant shut-off valve, sight glass, and flexible connections.
 3. Circulate dry nitrogen through tubes being brazed to eliminate formation of copper oxide during brazing operation.
- C. Specialties:
 1. Install valves and specialties in accessible locations. Install refrigeration distributors and suction outlet at same end of coil.
 2. Install thermostatic bulb as close to cooling coil as possible. Do not install on vertical lines.
 3. Install equalizing line in straight section of suction line, downstream of and reasonably close to thermostatic bulb. Do not install on vertical lines.
 4. Provide liquid line solenoid valve when required for long line applications.

- D. Refrigerant Supports:
1. Support Spacing:
 - a. Piping 1-1/4 inch And Larger: 8 feet on center maximum.
 - b. Piping 1-1/8 inch And Smaller: 6 feet on center maximum.
 - c. Support each elbow.
 2. Isolate pipe from supports and clamps with Hydrozorb or Cush-A-Clamp systems.
 3. Run protective cover continuous from condensing units to risers or penetrations at building wall. Support entire cover utilizing exterior supports as detailed.
 4. Provide opening through exterior cover with removable plug or cover to observe site glass.

3.2 FIELD QUALITY CONTROL

- A. Field Tests:
1. Make evacuation and leak tests after completing refrigeration piping systems. Positive pressure test will not suffice for procedure outlined below. Submit test reports.
 - a. Draw vacuum on each entire system with two stage vacuum pump. Draw vacuum to 300 microns using micron vacuum gauge capable of reading from atmosphere to 10 microns. Do not use cooling compressor to evacuate system nor operate it while system is under high vacuum.
 - b. Break vacuum with nitrogen and re-establish vacuum test. Vacuum shall hold for 30 minutes at 300 microns without vacuum pump running.
 - c. Conduct tests at 70 deg F ambient temperature minimum.
 - d. Do not run systems until above tests have been made and systems started up as specified. Inform Owner's Representative of status of systems at time of final inspection and schedule start-up and testing if prevented by outdoor conditions before this time.
 - e. After testing, fully charge system with refrigerant and conduct test with Halide Leak Detector.
 - f. Recover all refrigerant in accordance with applicable codes. Do not allow any refrigerant to escape to atmosphere.
- B. Non-Conforming Work:
1. If it is observed that refrigerant lines are being or have been brazed without proper circulation of nitrogen through lines, all refrigerant lines installed up to that point in time shall be removed and replaced at no additional cost to Owner.

END OF SECTION

SECTION 23 2600**CONDENSATE DRAIN PIPING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Related Requirements:
1. Section 23 0501: 'Common HVAC Requirements'.

1.2 REFERENCES

- A. Reference Standards:
1. ASTM International:
 - a. ASTM B88-09, 'Standard Specification for Seamless Copper Water Tube'.
 - b. ASTM D1785 - 06 'Standard Specification for Poly (Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120.'

PART 2 - PRODUCTS**2.1 SYSTEMS**

- A. Materials:
1. Condensate Drains:
 - a. 3 inch **75 mm** deep seal, vented water trap adjacent to cooling coil connection.
 - b. Schedule 40 PVC for condensate drains from furnace combustion chambers and furnace cooling coils.
- B. Condensate Pump:
1. Rated at 225 gph at 15 feet (**4.57 m**) total head. Complete with one gallon (**3.8 liter**) polystyrene tank with pump and automatic float control. 1/5 hp, 120 V, one phase, 60 Hertz.
 2. Condensate piping shall be Schedule 40 PVC.
 3. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a. No. CB501UL by Beckett Corp, Irving, TX www.beckett pumps.com.
 - b. No. VCL45ULS by Little Giant Pump Co, Oklahoma City, OK www.lgpc.com or Little Giant Pump Co/Albany Pump Co Ltd, Downsview, ON (888) 334-3348.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Condensate Drains:
1. Support piping and protect from damage.
 2. Do not combine PVC condensate drain piping from furnace combustion chamber with copper condensate drain piping from cooling coil.

END OF SECTION

BLANK PAGE

SECTION 23 3001**COMMON DUCT REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. General procedures and requirements for ductwork.
 - 2. Repair leaks in ductwork, as identified by duct testing, at no additional cost to Owner.
- B. Related Requirements:
 - 1. Section 01 4546: 'Duct Testing, Adjusting, and Balancing' for ductwork.
 - 2. Section 07 9219: 'Acoustical Joint Sealants' for quality of acoustic sealant.
 - 3. Section 23 0501: 'Common HVAC Requirements'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. Sheet Metal And Air Conditioning Contractors' National Association / American National Standards Institute:
 - a. SMACNA, 'HVAC Duct Construction Standards - Metal and Flexible' (Third Edition).

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Performance:
 - 1. Design Criteria:
 - a. Standard Ducts: Construction details not specifically called out in Contract Documents shall conform to applicable requirements of SMACNA, 'HVAC Duct Construction Standards Metal and Flexible'.
- B. Materials:
 - 1. Duct Hangers:
 - a. One inch (25 mm) by 18 ga (1.27 mm) galvanized steel straps or steel rods as shown on Drawings, and spaced not more than 96 inches (2 400 mm) apart. Do not use wire hangers.
 - b. Attaching screws at trusses shall be 2 inch (50 mm) No. 10 round head wood screws. Nails not allowed.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. During installation, protect open ends of ducts by covering with plastic sheet tied in place to prevent entrance of debris and dirt.
- B. Make necessary allowances and provisions in installation of sheet metal ducts for structural conditions of building. Revisions in layout and configuration may be allowed, with prior written approval of Architect. Maintain required airflows in suggesting revisions.

C. Hangers And Supports:

1. Install pair of hangers as required by spacing indicated in table on Drawings.
2. Install upper ends of hanger securely to floor or roof construction above by method shown on Drawings.
3. Attach strap hangers to ducts with cadmium-plated screws. Use of pop rivets or other means will not be accepted.
4. Where hangers are secured to forms before concrete slabs are poured, cut off flush all nails, strap ends, and other projections after forms are removed.
5. Secure vertical ducts passing through floors by extending bracing angles to rest firmly on floors without loose blocking or shimming. Support vertical ducts, which do not pass through floors, by using bands bolted to walls, columns, etc. Size, spacing, and method of attachment to vertical ducts shall be same as specified for hanger bands on horizontal ducts.

3.2 CLEANING

- A. Clean interior of duct systems before final completion.

END OF SECTION

SECTION 23 3114**LOW-PRESSURE METAL DUCTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install above-grade low-pressure steel ducts and related items as described in Contract Documents.
- B. Products Installed But Not Furnished Under This Section:
 - 1. Duct smoke detectors.
- C. Related Requirements:
 - 1. Section 01 4546: 'Duct Testing, Adjusting, And Balancing' for duct test, balance, and adjust air duct systems services provided by Owner.
 - 2. Section 23 3001: 'Common Duct Requirements'.

1.2 REFERENCES

- A. Association Publications:
 - 1. Sheet Metal And Air Conditioning Contractors' National Association / American National Standards Institute:
 - 2. SMACNA, 'HVAC Duct Construction Standards - Metal and Flexible' (Third Edition).
- B. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A653/A653M-13, 'Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process'.
 - b. ASTM E84-14, 'Standard Test Method for Surface Burning Characteristics of Building Materials'.
 - 2. Underwriters Laboratories, Inc.:
 - a. UL 723: 'Standard for Safety Test for Surface Burning Characteristics of Building Materials'; (2010 - Tenth Edition).

1.3 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Duct Sealer:
 - a. Meet Class A flame spread rating in accordance with ASTM E84 or UL 723.
 - b. Handle, store, and apply materials in compliance with applicable regulations and material safety data sheets (MSDS).

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Storage and Handling Requirements:
 - 1. Duct Sealer:
 - a. Handle, store, and apply materials in compliance with applicable regulations and material safety data sheets (MSDS).
 - b. Handle to prevent inclusion of foreign matter, damage by water, or breakage.

- c. Store in a cool dry location, but never under 35 deg F (1.7 deg C) or subjected to sustained temperatures exceeding 110 deg F (43 deg C) or as per Manufacturer's written recommendations.
- d. Do use sealants that have exceeded shelf life of product.

1.5 FIELD CONDITIONS

A. Ambient Conditions:

1. Duct Sealer:
 - a. Do not apply under 35 deg F (1.7 deg C) or subjected to sustained temperatures exceeding 110 deg F (43 deg C) or as per Manufacturer's written recommendations.
 - b. Do not apply when rain or freezing temperatures will occur within seventy two (72) hours.

PART 2 - PRODUCTS

2.1 SYSTEM

A. Materials:

1. Sheet Metal:
 - a. Fabricate ducts, plenum chambers and casings of zinc-coated, lock-forming quality steel sheets meeting requirements A653/A653M, with G 60 coating.
2. Duct Sealer For Interior Ducts:
 - a. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Duct Butter or ButterTak by Cain Manufacturing Co Inc, Pelham, AL www.cainmfg.com.
 - 2) DP 1010 by Design Polymerics, Fountain Valley, CA www.designpoly.com.
 - 3) PROseal, FIBERseal, EVERseal, or EZ-seal by Ductmate Industries, Inc., Charleroi, PA www.ductmate.com.
 - 4) SAS by Duro Dyne, Bay Shore, NY or Duro Dyne Canada, Lachine, QB www.durodyne.com.
 - 5) Iron Grip 601 by Hardcast Inc, Wylie, TX www.hardcast.com.
 - 6) MTS100 or MTS 200 by Hercules Mighty Tough, Denver CO, www.herculesindustries.com.
 - 7) 15-325 by Miracle / Kingco, Div ITW TACC, Rockland, MA www.taccint.com.
 - 8) 44-39 by Mon-Eco Industries Inc, East Brunswick, NJ www.mon-ecoindustries.com.
 - 9) Airseal Zero by Polymer Adhesive Sealant Systems Inc, Weatherford, TX www.polymeradhesives.com.
 - 10) Airseal #22 Water Base Duct Sealer by Polymer Adhesive Sealant Systems Inc, Weatherford, TX www.polymeradhesives.com.

B. Fabrication:

1. General:
 - a. Straight and smooth on inside with joints neatly finished.
 - b. Duct drops to diffusers shall be round, square, or rectangular to accommodate diffuser neck. Drops shall be same gauge as branch duct. Seal joints air tight.
2. Standard Ducts:
 - a. General:
 - 1) Ducts shall be large enough to accommodate inside acoustic duct liner. Dimensions shown on Drawings are net clear inside dimensions after duct liner has been installed.
 - b. Rectangular Duct:
 - 1) Duct panels through 48 inch (1 200 mm) dimension having acoustic duct liner need not be cross-broken or beaded. Cross-break unlined ducts, duct panels larger than 48 inch (1 200 mm) vertical and horizontal sheet metal barriers, duct offsets, and elbows, or bead 12 inches (300 mm) on center.
 - a) Apply cross-breaking to sheet metal between standing seams or reinforcing angles.

- b) Center of cross-break shall be of required height to assure surfaces being rigid.
- c) Internally line square and rectangular drops. Externally insulate round drops.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Metal duct surface must be clean and free of moisture, contamination and foreign matter before applying duct sealer for interior and exterior ducts.

3.2 INSTALLATION

- A. Install internal ends of slip joints in direction of flow. Seal transverse and longitudinal joints air tight using specified duct sealer as per Manufacturer's written instructions. Cover horizontal and longitudinal joints on exterior ducts with two layers of specified tape installed with specified adhesive.
- B. Securely anchor ducts and plenums to building structure with specified duct hangers attached with screws. Do not hang more than one duct from a duct hanger. Brace and install ducts so they shall be free of vibration under all conditions of operation.
- C. Ducts shall not bear on top of structural members.
- D. Paint ductwork visible through registers, grilles, and diffusers flat black.
- E. Properly flash where ducts protrude above roof.
- F. Under no conditions will pipes, rods, or wires be allowed to penetrate ducts.

3.3 FIELD QUALITY CONTROL

- A. Field Tests:
 - 1. Air Test and Balance Testing as specified in Section 01 4546: 'Duct Testing, Adjusting, and Balancing'.
- B. Non-Conforming Work:
 - 1. Reseal transverse joint duct leaks and seal longitudinal duct joint leaks discovered during air test and balance procedures at no additional cost to Owner.

END OF SECTION

BLANK PAGE

SECTION 23 3123**UNDERGROUND DUCTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install underground ducts as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 23 3001: Common Duct Requirements.

1.2 REFERENCES

- A. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A653/A653M-18, 'Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.'

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference: Participate in conference specified in Section 03 3111.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Materials:
 - 1. Ductwork:
 - a. Blue Duct - HDPE Plastic ductwork material mixed with a safe gaseous blowing agent when manufacturing giving it a property of thick strong foam.
 - 1) Complete duct system (including inlet plenums, round duct, run-outs, diffuser boots, etc.) must be from one manufacturer and be of the same material, construction and connection method throughout. Field made duct components are NOT acceptable.
 - 2) Provide elbows, ducts, diffuser boxes, plenums, clamp & gaskets, boots, saddle registers and caulk as required by drawings for underground installation.
 - 3) Ductwork shall be closed cell plastic material that is recyclable, does not emit volatile organic compounds, and conforms to ASTM-D2412. Ductwork shall be resistant to mildew, mold (UL 181B), and radon gas (BSS 7239-88). Ductwork shall have integral R-10 equivalent thermal insulation value, without the use of external insulation, per NSF's P374 Protocol and verified by a NSF Thermal Testing Report.
 - 4) All joints shall be sealed via gasket or bolts and sealant.
 - 5) Clamps and gaskets shall be used on ductwork without flanges. Clamps shall be polyethylene with stainless steel plates and stainless-steel screws. Gaskets shall comprise of ¼" thick butyl rubber sealant tape that is water and UV resistant and shall not stain. Gaskets shall comply with ASTM-E84 for flame and smoke spread.
 - 6) Flanged joints and duct branches shall use a co-polymer adhesive caulking sealant that is water and UV resistant. Flanges shall be connected with stainless steel bolts.
 - 7) Assembled ductwork shall be able to maintain pressure with no leakage.
 - 8) Duct system installed by manufacture trained installer will be air and water tight system.
 - 9) Duct system shall carry a 10-year Limited Warranty.

- 10) Approved Manufacturer.
 - a) 'The Blue Duct' by AQC Industries, Roseville, MN www.aqcind.com
 - b. Fiberglass-reinforced plastic duct system.
 - 1) Category Four Approved Manufacturer. See Section 01 6200 for definitions of Categories.
 - a) Spunstrand Inc, Post Falls, ID www.spunstrand.com.
 - c. PVS or PVC coated galvanized steel duct with 4 milthick coating on outside and on inside.
 - 1) Duct shall have and bear mark of approval of building code in authority for this Project.
 - 2) Gauges shall be as follows and be marked on each duct section. Corrugate ducts 14 inches in diameter and larger.

	Duct Size	Gauge
a)	4 to 8 inches	26
b)	9 to 12 inches	24
c)	14 to 22 inches	22
d)	24 to 28 inches	20
e)	30 to 40 inches	18
2. Accessories:
- a. Joint Sleeves: Galvanized sheet metal, galvanizing meeting requirements of ASTM A653/A653M, G 60.

	Duct Size	Gauge	Width
1)	4 to 12 inches	26	4 inches
2)	14 to 24 inches	24	4 inches
3)	26 to 36 inches	22	6 inches
 - b. Metal Boots: 20 ga (0.0396 in)galvanized steel, galvanizing meeting requirements of ASTM A653, G 60.
 - c. Connection Tape:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories.
 - a) Spunstrand: Sealtite PS401 sealing tape by Spunstrand Inc.
 - b) Coated Steel: Hardcast tape with Hardcast RTA-50 adhesive by Hardcast Inc, Wylie, TX www.hardcast.com.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. BlueDuct:
 - 1. Follow The BlueDuct Installation Instructions provided by AQC Industries. It is strongly recommended to complete installation training provided by AQC Industries prior to installation.
 - 2. Excavate a trench evenly as per The Blue Duct Installation Instructions. No bedding is required except for cases of bedrock or clay where sand or light aggregate may be used.
 - 3. Backfill material must consist of pea gravel or dry silica sand.
 - 4. The sealant and gasket material provided by AQC Industries must be used as directed. The use of non-approved sealant or gasket will void warranty.
 - 5. Allow 24 hours for The BlueDuct sealant to cure after final assembly before testing the duct system. Additional curing time may be required in high ambient conditions.
- B. Spunstrand:
 - 1. Join duct sections with galvanized sheet metal sleeve inside of duct secured with sheet metal screws.
 - 2. Wipe joint area clean and apply one layer of tape. Tape shall cover all screw heads.
 - 3. Construct sheet metal boot with 1-1/2 inch flange to fit against duct. Attach boot with self-tapping sheet metal screws, pulling boot flange snug to duct surface and tape joints. Tape shall cover screw heads.
 - 4. Encase boot completely in concrete, covering well around and below taped joint.
- C. Coated Steel Duct:
 - 1. Install 6 milpolyethylene vapor barrier around duct.

2. Fittings shall be PVS or PVC.
3. Join duct sections, fittings, and boots with sheet metal screws as detailed on Drawings.
4. Wrap duct connections, including boot connections to ducts, with two layers of specified tape installed in accordance with Manufacturer's recommendations. Cover screw heads with tape.
5. Encase boot completely in concrete, covering well around and below taped joint.
6. Where PVS or PVC coating has been scratched, scuffed, or peeled during shipping or installation, cover exposed metal with coating compound recommended by Manufacturer and in accordance with his recommendations.

END OF SECTION

BLANK PAGE

SECTION 23 3300**AIR DUCT ACCESSORIES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install duct accessories in specified ductwork as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 23 0933: 'Electric And Electronic Control System For HVAC' for temperature control damper actuators and actuator linkages.
 - 2. Section 23 3001: 'Common Duct Requirements'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A653/A653M-15, 'Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process'.
 - b. ASTM C1071-12, 'Standard Specification for Fibrous Glass Duct Lining Insulation (Thermal and Sound Absorbing Material)'.
 - c. ASTM C1338-14, 'Standard Test Method for Determining Fungi Resistance of Insulation Materials and Facings'.

PART 2 - PRODUCTS**2.1 ACCESSORIES**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. AGM Industries, Brockton, MA www.agmind.com.
 - b. Air Balance Inc, Holland, OH www.airbalance.com.
 - c. Air-Rite Manufacturing, Bountiful, UT (801) 295-2529.
 - d. American Warming & Ventilating, Holland, OH www.american-warming.com.
 - e. Arrow United Industries, Wyalusing, PA www.arrowunited.com.
 - f. Cain Manufacturing Company Inc, Pelham, AL www.cainmfg.com.
 - g. C & S Air Products, Fort Worth, TX www.csairproducts.com.
 - h. CertainTeed Corp, Valley Forge, PA www.certainteed.com.
 - i. Cesco Products, Florence, KY www.cescoproducts.com.
 - j. Design Polymerics, Fountain Valley, CA www.designpoly.com.
 - k. Ductmate Industries Inc, East Charleroi, PA www.ductmate.com.
 - l. Duro Dyne, Bay Shore, NY www.durodyne.com.
 - m. Dyn Air Inc. Lachine, QB www.dynair.ca
 - n. Elgen Manufacturing Company, Inc. East Rutherford, NJ www.elgenmfg.com
 - o. Flexmaster USA Inc, Houston, TX www.flexmasterusa.com.
 - p. Greenheck Corp, Schofield, WI www.greenheck.com.
 - q. Gripnail Corp, East Providence, RI www.gripnail.com.
 - r. Hardcast Inc, Wylie, TX www.hardcast.com.
 - s. Hercules Industries, Denver, CO, www.herculesindustries.com.
 - t. Honeywell Inc, Minneapolis, MN www.honeywell.com.
 - u. Johns-Manville, Denver, CO www.jm.com.

- v. Kees Inc, Elkhart Lake, WI www.kees.com.
- w. Knauf Fiber Glass, Shelbyville, IN www.knauffiberglass.com.
- x. Manson Insulation Inc, Brossard, QB www.isolationmanson.com.
- y. Metco Inc, Salt Lake City, UT (801) 467-1572 www.metcospiral.com.
- z. Miracle / Kingco, Rockland, MA www.taccint.com.
- aa. Mon-Eco Industries Inc, East Brunswick, NJ www.mon-ecoindustries.com.
- bb. Nailor Industries Inc, Houston, TX www.nailor.com.
- cc. Owens Corning, Toledo, OH www.owenscorning.com.
- dd. Polymer Adhesive Sealant Systems Inc, Irving, TX www.polymeradhesives.com.
- ee. Pottorff Company, Fort Worth, TX www.pottorff.com.
- ff. Ruskin Manufacturing, Kansas City, MO www.ruskin.com.
- gg. Sheet Metal Connectors Inc, Minneapolis, MN www.smconnectors.com.
- hh. Tamco, Stittsville, ON www.tamco.ca.
- ii. Techno Adhesive, Cincinnati, OH www.technoadhesives.com.
- jj. McGill AirSeal, Columbus, OH www.mcgillairseal.com.
- kk. United Enertech Corp, Chattanooga, TN www.unitedenertech.com.
- ll. Utemp Inc, Salt Lake City, UT (801) 978-9265.
- mm. Ventfabrics Inc, Chicago, IL www.ventfabrics.com.
- nn. Ward Industries, Grand Rapids MI www.wardind.com.
- oo. Young Regulator Co, Cleveland, OH www.youngregulator.com.

B. Materials:**1. Acoustical Liner System:****a. Duct Liner:**

- 1) One inch thick, 1-1/2 lb density fiberglass conforming to requirements of ASTM C1071. Liner will not support microbial growth when tested in accordance with ASTM C1338.
- 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) ToughGard by CertainTeed.
 - b) Duct Liner E-M by Knauf Fiber Glass.
 - c) Akousti-Liner by Manson Insulation.
 - d) Quiet R by Owens Corning.
 - e) Linacoustic RC by Johns-Manville.

b. Adhesive:

- 1) Category Four Approved Water-Based Products. See Section 01 6200 for definitions of Categories:
 - a) Cain: Hydrotak.
 - b) Design Polymerics: DP2501 or DP2502 (CMCL-2501).
 - c) Duro Dyne: WSA.
 - d) Elgen: A-410-WB.
 - e) Hardcast: Coil-Tack.
 - f) Hercules: Mighty Tough Adhesives MTA500 or MTA600.
 - g) Miracle / Kingco: PF-101.
 - h) Mon-Eco: 22-67 or 22-76.
 - i) Polymer Adhesive: Glasstack #35.
 - j) Techno Adhesive: 133.
 - k) McGill AirSeal: Uni-tack.
- 2) Category Four Approved Solvent-Based (non-flammable) Products. See Section 01 6200 for definitions of Categories:
 - a) Cain: Safetak.
 - b) Duro Dyne: FPG.
 - c) Hardcast: Glas-Grip 648-NFSE.
 - d) Miracle / Kingco: PF-91.
 - e) Mon-Eco: 22-24.
 - f) Polymer Adhesive: Q-Tack.
 - g) Techno Adhesive: 'Non-Flam' 106.
- 3) Category Four Approved Solvent-Based (flammable) Products. See Section 01 6200 for definitions of Categories:
 - a) Cain: HV200.
 - b) Duro Dyne: MPG.
 - c) Hardcast: Glas-Grip 636-SE.

- d) Miracle / Kingco: PF-96.
- e) Mon-Eco: 22-22.
- f) Polymer Adhesive: R-Tack.
- g) Techno Adhesive: 'Flammable' 106.
- c. Fasteners:
 - 1) Adhesively secured fasteners not allowed.
 - 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) AGM Industries: 'DynaPoint' Series RP-9 pin.
 - b) Cain.
 - c) Duro Dyne.
 - d) Gripnail: May be used if each nail is installed by 'Grip Nail Air Hammer' or by 'Automatic Fastener Equipment' in accordance with Manufacturer's recommendations.
- 2. Flexible Equipment Connections:
 - a. 30 oz closely woven UL approved glass fabric, double coated with neoprene.
 - b. Fire retardant, waterproof, air-tight, resistant to acids and grease, and withstand constant temperatures of 200 deg F.
 - c. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Cain: N-100.
 - 2) Duro Dyne: MFN.
 - 3) Dyn Air: CPN with G-90 galvanized off-set seam.
 - 4) Elgen: ZLN / SDN.
 - 5) Ventfabrics: Ventglas.
 - 6) Ductmate: ProFlex.
- 3. Duct Access Doors:
 - a. General:
 - 1) Factory built insulated access door with hinges and sash locks, as necessary. Construction shall be galvanized sheet metal, 24 ga minimum.
 - 2) Fire and smoke damper access doors shall have minimum clear opening of 12 inches square or larger as shown on Drawings.
 - b. Rectangular Ducts:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Air Balance: Fire/Seal FSA 100.
 - b) Air-Rite: Model HAD-2.
 - c) Cesco: HDD.
 - d) Elgen: TAB Type / Hinge and Cam.
 - e) Flexmaster: Spin Door.
 - f) Kees: ADH-D.
 - g) Nailor: 08SH.
 - h) Pottorff: 60-HAD.
 - i) Ruskin: ADH-24.
 - j) United Enertech: L-95.
 - c. Round Ducts:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Ductmate: 'Sandwich' Access Door.
 - b) Elgen: Sandwich Access Door.
 - c) Kees: ADL-R.
 - d) Nailor: 0890.
 - e) Pottorff: RAD.
 - f) Ruskin: ADR.
 - g) Ward: DSA.
- 4. Dampers And Damper Accessories:
 - a. Locking Quadrant Damper Regulators:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Duro Dyne: KS-385.
 - b) Dyn Air: QPS-385.
 - c) Elgen: EQR-4.
 - d) Ventfabrics: Ventline 555.
 - e) Young: No. 1.
 - b. Concealed Ceiling Damper Regulators:

- 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Cain.
 - b) Duro Dyne.
 - c) Elgen.
 - d) Metco Inc.
 - e) Ventfabrics: 666 Ventlok.
 - f) Young: 301.
- c. Volume Dampers:
 - 1) Rectangular Duct:
 - a) Factory-manufactured 16 ga galvanized steel, single blade and opposed blade type with 3/8 inch axles and end bearings. Blade width 8 inches maximum. Blades shall have 1/8 inch clearance all around.
 - b) Damper shall operate within acoustical duct liner.
 - c) Provide channel spacer equal to thickness of duct liner.
 - d) Dampers above removable ceiling and in Mechanical Rooms shall have locking quadrant on bottom or side of duct. Otherwise, furnish with concealed ceiling damper regulator and cover plate.
 - e) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) Air-Rite: Model CD-2.
 - (2) American Warming: VC-2-AA.
 - (3) Arrow: OBDAF-207.
 - (4) C & S: AC40.
 - (5) Cesco: AGO.
 - (6) Daniel: CD-OB.
 - (7) Greenheck: VCD-20.
 - (8) Nailor: 1810 or 1820.
 - (9) Pottorff: CD-42.
 - (10) Ruskin: MD-35.
 - (11) United Enertech: MD-115.
 - (12) Utemp: CD-OB.
 - 2) Round Duct:
 - a) Factory-manufactured 20 ga galvanized steel, single blade with 3/8 inch axles and end bearings.
 - b) For use in outside air ducts.
 - c) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) Air Balance: Model AC-22.
 - (2) Air-Rite: Model CD-8.
 - (3) American Warming: V-22.
 - (4) Arrow: Type-70.
 - (5) C & S: AC21R.
 - (6) Cesco: MGG.
 - (7) Nailor: 1890.
 - (8) Pottorff: CD-21R.
 - (9) Ruskin: MDRS-25.
 - (10) United Enertech: RD.
- d. Motorized Outside Air Dampers:
 - 1) General:
 - a) Low leakage type. AMCA certified.
 - b) Make provision for damper actuators and actuator linkages to be mounted external of air flow.
 - 2) Rectangular Ducts:
 - a) Damper Blades:
 - (1) Steel or aluminum airfoil type with mechanically locked blade seals, 8 inch blade width maximum measured perpendicular to axis of damper.
 - (2) Jamb seals shall be flexible metal compression type.
 - (3) Opposed or single blade type.
 - b) Category Four Approved Products. See Section 01 6200 for definitions of Categories:

- (1) Air Balance: AC 526.
 - (2) American Warming: AC526.
 - (3) Arrow: AFD-20.
 - (4) C & S: AC50.
 - (5) Cesco: AGO3.
 - (6) Nailor: 2020.
 - (7) Pottorff: CD-52.
 - (8) Ruskin: CD-60.
 - (9) Tamco: Series 1000.
 - (10) United Enertech: CD-150 or CD-160.
- 3) Round Ducts:
- a) Damper Blades:
 - (1) Steel with mechanically locked blade seals.
 - (2) Blade seals shall be neoprene or polyethylene.
 - (3) Single blade type.
 - b) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) Air Balance: AC 25.
 - (2) American Warming: VC25.
 - (3) Arrow: Type 70 or 75.
 - (4) C & S: AC25R.
 - (5) Cesco: AGG.
 - (6) Nailor: 1090.
 - (7) Pottorff: CD-25R.
 - (8) Ruskin: CD25.
 - (9) Tamco: Square-to-Round Series 1000.
 - (10) United Enertech: RI.
- e. Backdraft Dampers:
- 1) Backdraft blades shall be nonmetallic neoprene coated fiberglass type.
 - 2) Stop shall be galvanized steel screen or expanded metal, 1/2 inch mesh.
 - 3) Frame shall be galvanized steel or extruded aluminum alloy.
 - 4) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Air-Rite: Model BDD-3.
 - b) American Warming: BD-15.
 - c) C & S: BD31.
 - d) Pottorff: BD-51.
 - e) Ruskin: NMS2.
 - f) Utemp: BFEA.
5. Air Turns:
- a. Single thickness vanes. Double thickness vanes not acceptable.
 - b. 4-1/2 inch wide vane rail. Junior vane rail not acceptable.
- C. Fabrication:
1. Duct Liner:
 - a. Install mat finish surface on airstream side. Secure insulation to cleaned sheet metal duct with continuous 100 percent coat of adhesive and with 3/4 inch long mechanical fasteners 12 inches on center maximum unless detailed otherwise on Drawings. Pin all duct liner.
 - b. Accurately cut liner and thoroughly coat ends with adhesive. Butt joints tightly. Top and bottom sections of insulation shall overlap sides. If liner is all one piece, folded corners shall be tight against metal. Ends shall butt tightly together.
 - c. Coat longitudinal and transverse edges of liner with adhesive.
 2. Air Turns:
 - a. Permanently install vanes arranged to permit air to make abrupt turn without appreciable turbulence, in 90 degree elbows of above ground supply and return ductwork.
 - b. Quiet and free from vibration when system is in operation.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Duct Liner:
1. Furnish and install acoustic lining in following types of rectangular ducts unless noted otherwise on Contract Documents:
 - a. Supply air.
 - b. Return air.
 - c. Mixed air.
 - d. Transfer air.
 - e. Elbows, fittings, and diffuser drops greater than 12 inches in length.
 2. Do not install acoustic lining in round ducts.
- B. Flexible Connections: Install flexible inlet and outlet duct connections to each fan coil unit.
- C. Access Doors In Ducts:
1. Install between manual and motorized outside air damper at each system. Locate doors within 6 inches of installed dampers.
 2. Install within 6 inches of fire dampers and in Mechanical Room if possible. Install on side of duct that allows easiest access to damper.
- D. Dampers And Damper Accessories:
1. Install concealed ceiling damper regulators.
 - a. Paint cover plates to match ceiling tile.
 - b. Do not install damper regulators for dampers located directly above removable ceilings or in Mechanical Rooms.
 2. Provide each take-off with an adjustable volume damper to balance that branch.
 - a. Anchor dampers securely to duct.
 - b. Install dampers in main ducts within insulation.
 - c. Dampers in branch ducts shall fit against sheet metal walls, bottom and top of duct, and be securely fastened. Cut duct liner to allow damper to fit against sheet metal.
 - d. Where concealed ceiling damper regulators are installed, provide cover plate.
 3. Install motorized dampers.

END OF SECTION

SECTION 23 3316**FIRE DAMPERS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install fire and smoke dampers described in Contract Documents.
- B. Related Requirements:
 - 1. Section 15 3001: 'Common Duct Requirements'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. Underwriters Laboratories (UL):
 - a. UL 555: 'Fire Dampers' (7th Edition).
 - b. UL 555C, 'Ceiling Dampers' (3rd Edition).

1.3 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Dampers shall conform to NFPA and SMACNA requirements and bear UL label.
 - 2. Dampers shall be approved by fire authorities having jurisdiction where so required.
 - 3. Wall and floor fire dampers shall conform to UL 555 Fire Damper Test Standard.
 - 4. Ceiling fire dampers shall conform to UL 555C Ceiling Damper Test Standard.
 - 5. Smoke Dampers shall conform to UL 555S Leakage Rated Damper Test Standard.
 - 6. Combination fire / smoke dampers shall conform to UL 555 Fire Damper Test Standard and to UL 555S Leakage Rated Damper Test Standard.

1.4 SUBMITTALS

- A. Maintenance Material Submittals:
 - 1. Extra Stock Materials:
 - a. Leave six (6) fusible links of each rating type used on Project with Owner.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Air Balance Inc, Holland, OH www.airbalance.com.
 - b. Cesco Products, Florence, KY www.cescoproducts.com.
 - c. Greenheck Corp, Schofield, WI www.greenheck.com or Greenheck Corp/ E H Price Ltd, Winnipeg, MB (204) 669-4220.
 - d. Honeywell Inc, Minneapolis, MN www.honeywell.com.
 - e. Nailor Industries, Houston, TX www.nailor.com.
 - f. Pottorff, Fort Worth, TN www.pottorff-hvac.com.
 - g. Prefco Products Inc, Buckingham, PA www.prefco-hvac.com.

- h. Ruskin Manufacturing, Kansas City, MO www.ruskin.com.
 - i. Safe-Air / Dowco, Cicero, IL www.safeair-dowco.com.
 - j. United Enertech Corp, Chattanooga, TN www.unitedenertech.com.
- B. Manufactured Units:
- 1. Fire Dampers:
 - a. Walls And Floors (Type 1):
 - 1) Type 'B.'
 - 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Air Balance: Model 119B.
 - b) Cesco: Model 15SB.
 - c) Greenheck: Model FD150XB.
 - d) Nailor: Model 0120H.
 - e) Pottorff: Model VFD-10.
 - f) Ruskin: Model DIBD20.
 - g) Safe-Air: Model 150B Sleeved.
 - h) United Enertech: FDD-SB.
 - b. Ceilings (Type 2):
 - 1) Radiation type ceiling fire damper.
 - 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Air Balance: Model 289.
 - b) Cesco: Model RCI.
 - c) Greenheck: Model CRD-60B.
 - d) Nailor: Model 0716 or 0722.
 - e) Pottorff: Model CFD-20.
 - f) Ruskin: Model CFD-LDS Series.
 - g) Safe-Air: Model 410A.
 - h) United Enertech: C-S/R.
- C. Fabrication:
- 1. General:
 - a. 16 ga frames.
 - b. Integral sleeves, except for Type 2 Fire Dampers.
 - 2. Type 1 Dampers: Fabricate with blades out of airstream.
- D. Operation Sequences:
- 1. Types 1 And 2: Dampers shall close when temperatures at damper exceed 165 deg F (74 deg C) link unless indicated otherwise on Drawings.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Placement:
- 1. Fire Dampers (Types 1 and 2): Install in ducts where ducts penetrate fire-rated walls and floors and at registers, grilles, and diffusers penetrating fire rated assemblies.

END OF SECTION

SECTION 23 3713**DIFFUSERS, REGISTERS, AND GRILLES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install diffusers, registers, and grilles connected to ductwork as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 23 3001: 'General Duct Requirements'.

1.2 SUBMITTALS

- A. Maintenance Material Submittals:
 - 1. Tools: Leave tool for removing core of each different type of grille for building custodian.

PART 2 - PRODUCTS**2.1 MANUFACTURERS**

- A. Manufacturer Contact List:
 - 1. Carnes Co, Verona, MI www.carnes.com.
 - 2. Krueger Air System Components, Richardson, TX www.krueger-hvac.com.
 - 3. Metal*Aire by Metal Industries Inc, Clearwater, FL www.metalaire.com.
 - 4. Nailor Industries Inc, Houston, TX or Weston, ON www.nailor.com.
 - 5. Price Industries Inc, Suwanee, GA www.price-hvac.com or E H Price Ltd, Winnipeg, MB (204) 669-4220.
 - 6. Titus, Richardson, TX www.titus-hvac.com.
 - 7. Tuttle & Bailey, Richardson, TX www.tuttleandbailey.com.

2.2 MANUFACTURED UNITS

- A. Ceiling Diffusers:
 - 1. Finish: Off-white baked enamel.
 - 2. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a. Carnes: SKSA.
 - b. Krueger: SH.
 - c. Metal*Aire: 5500S.
 - d. Nailor: 650OB.
 - e. Price: SMD-6.
 - f. Titus: TDC-6.
 - g. Tuttle & Bailey: M.
- B. Floor Return Air Grilles:
 - 1. Finish: Clear anodized.
 - 2. Construction: Aluminum, reinforced for floor use.
 - 3. Frame: 1 inch flange, mitered corners, spring clip fastening.
 - 4. Core: Minimum 3/16 inch bars at ½" spacing. Support bars @ 6" O.C. Removable retainer clips.
 - 5. Category Four Approved Products. See Section 01 6200 for definitions of Categories:

- a. Carnes: CCJB (with mitered corners welded on face and sanded).
- b. J & J: 2500 with Frame 10.
- c. Krueger: 1500F.
- d. Metal*Aire: 2000F.
- e. Nailor: 49-240-FN-MM.
- f. Price: LBPH-25B.
- g. Titus: CT-540.
- h. Tuttle & Bailey: 4000 CO.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Anchor securely into openings. Secure frames to ductwork by using four sheet metal screws, one per side. Level floor registers and anchor securely into floor.

3.2 ADJUSTING

- A. Set sidewall supply register blades at 15 degrees upward deflection.

END OF SECTION

SECTION 23 3723**HVAC GRAVITY VENTILATORS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install roof vents as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 23 3001: 'Common Duct Requirements'.

PART 2 - PRODUCTS**2.1 MANUFACTURERS**

- A. Manufacturer List:
 - 1. Air-Rite Manufacturing, Bountiful, UT (801) 295-2529.
 - 2. Breidert Air Products, Jacksonville, FL www.breidert.com.
 - 3. Carnes Company, Verona, WI www.carnes.com.
 - 4. Greenheck Fan Corporation, Schofield, WI www.greenheck.com.
 - 5. Loren Cook Co, Springfield, MO www.lorencook.com.
 - 6. United Enertech Corporation, Chattanooga, TN www.unitedenertech.com.
 - 7. Vent Products Co, Inc, Chicago, IL www.ventprod.com.

2.2 MANUFACTURED UNITS

- A. Louvered Penthouses:
 - 1. Fabricated from (0.081 inch **2.15 mm**) extruded aluminum.
 - a. All welded construction.
 - b. Screws or rivets will not be allowed.
 - 2. Blades:
 - a. Horizontal at 45 degree angle with return bends at upper edges.
 - b. Welded, mitered corners for continuous blade effect.
 - 3. Bird Screens: 1/2 inch (**13 mm**) square mesh 16 ga (**1.6 mm**) aluminum in extruded aluminum, rewirable frames on interior of louvers.
 - 4. Penthouse Finish: Clear anodized aluminum.
 - 5. Curbs:
 - a. Galvanized steel, insulated, factory-fabricated curb.
 - b. Insulation: Minimum 1-1/2 inches (**38 mm**) thick, 3 lb **48 kg per cubic m** density fiber glass.
 - c. Curb Extension: 8 inches (**200 mm**) above finished roof level.
 - 6. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a. Air-Rite Manufacturing: Model LPE-1.
 - b. Breidert: Model RLX.
 - c. Carnes: GLAB.
 - d. Cook: Type TRE.
 - e. Greenheck: WIH/WRH.
 - f. United Enertech: Model PEL-4.
 - g. Vent Products: Model 7100.

PART 3 - EXECUTION: Not Used

END OF SECTION

SECTION 23 4100

AIR FILTERS

PART 1 - GENERAL

1.1 SUMMARY

- A. Includes But Not Limited To:
 - 1. Furnish and install filters used in mechanical equipment.
- B. Related Requirements:
 - 1. Section 23 3001: 'Common Duct Requirements'.

1.2 REFERENCES

- A. Reference Standard:
 - 1. American National Standards Institute (ANSI) / American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE):
 - a. ANSI/ASHRAE 52.2-2017, 'Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size'.

PART 2 - PRODUCTS

2.1 MANUFACTURED UNITS

- A. Furnace Filters: One inch thick throw-away type as recommended by Furnace Manufacturer.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Provide ample access for filter removal.

3.2 FIELD QUALITY CONTROL

- A. Inspection: At date of Substantial Completion, air filters shall be new, clean, and approved by Owner's representative.

END OF SECTION

SECTION 23 5135**AIR PIPING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install heating equipment exhaust piping and combustion air intake piping as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 07 6310: 'Steep Slope Roof Flashing: Asphalt Tile' for pipe flashing used on steep slope asphalt tile roofs only.
 - 2. Sections Under 09 9000 Heading: Painting.
 - 3. Section 23 0501: 'Common HVAC Requirements'.
 - 4. Section 23 5417: 'Gas-Fired Furnaces'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. ASTM International:
 - a. ASTM D1785-12, 'Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120'.
 - b. ASTM D2564-12, 'Standard Specification for Solvent Cements for Poly (Vinyl Chloride) (PVC) Plastic Piping Systems'.
 - c. ASTM D2661-11, 'Standard Specification for Acrylonitrile-Butadiene-Styrene (ABS) Schedule 40 Plastic Drain, Waste, and Vent Pipe and Fittings'.
 - d. ASTM D2665-14, 'Standard Specification for Poly (Vinyl Chloride) (PVC) Plastic Drain, Waste, and Vent Pipe and Fittings'.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Armaflex by Armacell, Mebane, NC www.armaflex.com.
 - b. Nomaco, Youngsville, NC www.nomacokflex.com.
- B. Materials:
 - 1. Air Piping: Schedule 40 pipe and fittings meeting requirements of ASTM D1785, ASTM D2661, or ASTM D2665.
 - 2. Solvent Cement and Adhesive Primer:
 - a. Meet requirements of ASTM F656 for cement primer and ASTM D2564 for pipe cement.
 - 3. Flexible Foamed Pipe Insulation:
 - a. Thickness:
 - 1) 1/2 inch (13 mm) for 2 through 3 inch (50 through 75 mm) outside diameter pipe.
 - 2) 1/2 inch (13 mm) sheet for fittings as recommended by Manufacturer.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Tubolit by Armaflex.
 - 2) ImcoLock or Therma-Cel by Nomaco K-Flex.
 - 4. Insulation Joint Sealer:

- a. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) 520 by Armaflex.
 - 2) R-320 by Nomaco K-Flex.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Installation For Condensing Furnaces:
 1. Run individual vent and individual combustion intake piping from each furnace to concentric roof termination kit provided by Furnace Manufacturer. Slope lines downward toward furnace.
 2. Slope combustion chamber drain downward to funnel drain. Anchor to wall with wall clamps, allowing free movement through clamp for expansion.
 3. Use concentric roof termination kit provided by Furnace Manufacturer. Install vent and combustion air intake piping at clearance and distances required by Furnace Manufacturer.
 4. Attach factory-supplied neoprene coupling to combustion-air inlet connection and secure with clamp.
 5. Ensure that factory-supplied perforated metal disc is installed in flexible coupling, unless its removal is required.
- B. Support:
 1. Support concentric roof termination kit at ceiling or roof line with 20 ga (0.912 mm) sheet metal straps as detailed on Drawings.
 2. Support horizontal and sloping sections of pipe with 1 inch (25 mm) wide 20 ga (1.0058 mm) galvanized steel straps. Anchor securely to structure, not allowing pipe to sway.
- C. Insulation:
 1. General:
 - a. Install insulation in snug contact with pipe and in accordance with Manufacturer's recommendations.
 - b. Slip insulation on piping before piping sections and fittings are assembled keeping slitting of insulation to a minimum.
 - c. Joints:
 - 1) Place 'slit' joint seams of insulation exposed outside building on bottom of pipe.
 - 2) Stagger joints on layered insulation.
 - 3) Seal joints in insulation.
 - d. Paint exterior exposed insulation with two coats of finish recommended by Insulation Manufacturer, color selected by Architect.
 2. Install specified insulation on PVC air piping serving mechanical equipment as follows
 - a. Combustion air PVC piping in truss space and in attic.
 - b. Combustion vent PVC piping in attic, in truss space, and above roof.
 - c. Insulate fittings with sheet insulation and as recommended by Manufacturer.

END OF SECTION

SECTION 23 5417**GAS-FIRED FURNACES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Furnish and install horizontal/vertical gas-fired condensing furnaces as described in Contract Documents.
- B. Related Sections:
1. Section 23 0501: 'Common HVAC Requirements'.
 2. Section 23 1123: 'Facility Natural Gas Piping'.
 3. Section 23 2300: 'Refrigerant Piping'.
 4. Section 23 4100: 'Air Filters'.
 5. Section 23 5135: 'Air Piping'.
 6. Section 23 6214: 'Compressor Units: Air Conditioning (5 Ton or less)' for DX Cooling.

1.2 SUBMITTALS

- A. Informational Submittals:
1. Manufacturer Reports: Equipment check-out sheets.
- B. Special Procedure Submittals:
1. Installer must register with Manufacturer before submitting Manufacturer Warranty:
 - a. Installer to contact Owner's Representative (FM Group or Project Manager) for following MANDATORY information to be given to Manufacturer before Manufacturer will issue Manufacturer's 'Special LDS Warranty' included with Closing Submittal:
 - 1) This must be given to Manufacturer:
 - a) Name of Owner (name of FM Group) _____
 - b) Mailing Address (FM office address) _____
 - c) Building Property ID (unique 7 digit identifier) _____
 - d) Project site address: _____
 - e) Model Number of each Unit _____
 - f) Serial Number of each Unit _____
 - g) Date of Installation / Startup _____
- C. Closeout Submittals:
1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Warranty Documentation:
 - 1) Final, executed copy of Warranty.
 - b. Record Documentation:
 - 1) Manufacturers Documentation:
 - a) Equipment checkout sheet: Complete and sign all items for each unit.

1.3 WARRANTY

- A. Manufacturer's Warranty:
1. Provide Manufacturer's 'Special LDS Warranty' for the following:
 - a. Provide fifteen (15) year minimum limited warranty of heat exchanger.
 - b. Provide five (5) year limited warranty on parts.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
1. Manufacturer Contact List:
 - a. Carrier Corporation:
 - 1) Carrier National: Bradley Brunner (270) 282-1241 Bradley.M.Brunner@Carrier.com.
 - 2) Carrier Utah: Bret Adams (Contractors Heating/Cooling Supply) (801) 224-1020 ext. 2527 bret.adams@mc.supply
 - b. Lennox Industries:
 - 1) For pricing and information contact: Lennox Mountain Commercial @ 1-800-972-3283.
 - 2) Lennox National Contact: Jeff Barrett (801) 556-6114 jeff.barrett@lennoxind.com
 - c. York (US Air Conditioning Distributors):
 - 1) Nick Filimoehala (801) 463-5323 n.filimoehala@us-ac.com.
- B. Design Criteria:
1. Rated at 92 percent minimum AFUE (Annual Fuel Utilization Efficiency) calculated in accordance with DOE test procedures.
- C. Manufactured Units:
1. Furnaces:
 - a. Factory assembled units certified by AGA complete with blower section, furnace section, steel casing, piped, and wired.
 - b. Blower section shall consist of cabinet, blower, and motor.
 - 1) Cabinet shall be of 22 ga (0.8 mm) minimum cold rolled steel and have finish coat of baked-on enamel.
 - 2) Blower shall be Class 1, full DIDW, statically and dynamically balanced.
 - c. Automatic controls shall consist of:
 - 1) Manual gas shut-off valve.
 - 2) Operating automatic gas valve.
 - 3) Solid-state type fan and thermal limit controls.
 - 4) 24-volt transformer.
 - 5) Hot surface ignition system.
 - d. Blower shall be driven by multi-speed direct driven motor.
 - e. Furnace section shall be enclosed in 22 ga (0.8 mm) minimum enameled steel casing lined with foil covered insulation.
 - f. Heat Exchanger: Aluminized steel.
 - g. Gas Burners: Aluminized steel.
 - h. PVC intake of outside air and PVC combustion product exhaust, with sealed combustion, direct vent system.
 - i. Concentric roof termination kit for roof mounting.
 - j. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Standard Furnaces with ECM motor:
 - a) Carrier: 59SC5B.
 - b) Lennox: ML196E
 - c) York: TM9E
 - 2) Two Stage Heat with ECM motor:
 - a) Carrier: 59TN6.
 - b) Lennox: EL296V.
 - c) York: TM9V.
 2. Cooling Coil:
 - a. Cooling coil shall consist of heavy gauge steel cabinet with baked-on enamel finish to match furnace:
 - 1) Coil shall have aluminum fins bonded to seamless copper or aluminum tubing.
 - 2) Coil shall be ARI rated. Provide drain pans with connections at one end.
 - 3) Use thermal expansion valve.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Vertical:

- a) Carrier: CNPVP.
- b) Lennox: CX35.
- c) York: CF.

2.2 ACCESSORIES

- A. Filter Frame:
 - 1. Build filter frame external to furnace as detailed on Contract Drawings.
- B. Vibration Isolators:
 - 1. Vertical Installation: 4 inches (100 mm) square by 1/2 inch (13 mm) thick minimum neoprene type vibration isolation pads.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Vibration Isolators:
 - 1. Install vibration isolator under each corner of vertical furnace.

3.2 FIELD QUALITY CONTROL

- A. Manufacturer Services:
 - 1. Furnace installer shall:
 - a. Verify proper gas orifice size.
 - b. Clock gas meter for rated input.
 - c. Verify and set gas pressure at furnace.
 - d. Check and measure temperature rise.
 - e. Check safety controls for proper operation.
 - f. Check combustion vent sizes and combustion air sizes.
 - 2. In addition, furnace installer shall start up, check out, and adjust furnaces using equipment check-out sheet provided by Manufacturer. Complete and sign all items on sheet.

END OF SECTION

BLANK PAGE

SECTION 23 6214**COMPRESSOR UNITS: Air Conditioning (5 Ton or less)****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install compressor units as described in contract documents.
- B. Related Sections:
 - 1. Section 23 0501: 'Common HVAC Requirements'.
 - 2. Section 23 2300: 'Refrigerant Piping'.
 - 3. Section 23 5417: 'Gas-Fired Furnaces'.

1.2 REFERENCES

- A. Definitions:
 - 1. Compressor: Pump that increases vapor (refrigerant or air) pressure from one level to a higher level of pressure.
 - 2. Compressor Unit: Outside section of an air conditioning system which pumps vaporized refrigerant from the evaporator, compresses it, liquefies it in the condenser and returns it to the evaporator coil. The outdoor portion of a split system air conditioner contains the compressor and outdoor coil.
 - 3. Condenser: Device used to condense refrigerant in a cooling system.
 - 4. Condenser Coils: In a compressor unit, the coil dissipates heat from the refrigerant, changing the refrigerant from vapor to liquid.
 - 5. Refrigerant: Absorbs heat by a change of state (evaporation) from liquid to a gas, and releases heat by a change of state (condenses) from gas back to a liquid.
 - 6. SEER (Seasonal Energy Efficiency Ratio): Measure of cooling efficiency for air conditioners and heat pumps. A ratio of total cooling in comparison to electrical energy input in watts per hour. Higher the seer, the more energy efficient the unit. Since 2006, the minimum SEER required by the Department of Energy is 13.00 and 15.00+ SEER is considered high efficiency.
 - 7. Split System: Combination of an outdoor unit (air conditioner or heat pump) with an indoor unit (furnace or air handler). Split systems must be matched for optimum efficiency.
- B. Reference Standards:
 - 1. American National Standards Institute / Air-Conditioning, Heating, and Refrigeration Institute:
 - a. ANSI/AHRI Standard 210/240-2017, 'Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment' (formerly ARI Standard 210/240).
 - 2. American National Standards Institute / American Society of Heating, Refrigerating and Air-Conditioning Engineers:
 - a. ANSI/ASHRAE 15-2016 and 34-2016, 'Safety Standard and Designation and Classification of Refrigerants'.

1.3 SUBMITTALS

- A. Informational Submittals:
 - 1. Tests and Evaluation Reports:
 - a. Manufacturer Reports: Equipment check-out sheets.
- B. Special Procedure Submittals:
 - 1. Installer must register with Manufacturer before submitting Manufacturer Warranty:

- a. Installer to contact Owner’s Representative (FM Group or Project Manager) for following MANDATORY information to be given to Manufacturer before Manufacturer will issue Manufacturer’s ‘Special LDS Warranty’ included with Closing Submittal:
 - 1) This must be given to Manufacturer:
 - a) Name of Owner (name of FM Group) _____
 - b) Mailing Address (FM office address) _____
 - c) Building Property ID (unique 7 digit identifier) _____
 - d) Project site address: _____
 - e) Model Number of each Unit _____
 - f) Serial Number of each Unit _____
 - g) Date of Installation / Startup _____
 - 2. Qualification Statements:
 - a. Technician certificate for use in HFC and HCFC refrigerants.

C. Closeout Submittals:

- 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Warranty Documentation:
 - 1) Final, executed copy of Manufacturer’s ‘Special LDS Warranty’ including required Owner / Manufacturer mandatory information.
 - b. Record Documentation:
 - 1) Manufacturers Documentation:
 - a) Equipment checkout sheet: Complete and sign all items for each unit.

1.4 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Each unit shall be UL / ULC or ETL labeled.
 - 2. Comply with ANSI/AHRI Standard 210/240.
 - 3. Refrigeration compressor, coils, and specialties shall be designed to operate with CFC-free refrigerants.
- B. Qualifications. Section 01 4301 applies, but is not limited to the following:
 - 1. Installer: Refrigerant piping shall be installed by refrigeration contractor licensed by State and by technicians certified in use of HFC and HCFC refrigerants.

1.5 WARRANTY

- A. Manufacturer’s Warranty:
 - 1. Provide Manufacturer’s Special LDS Warranty for the following:
 - a. Provide ten (10) year limited warranty on compressor and five (5) year limited warranty on parts from date of ‘start-up’.
 - b. Record ‘start-up’ date on warranty certificate for each unit.

PART 2 - PRODUCTS

2.1 ASSEMBLIES

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Carrier Corporation:
 - 1) Carrier National: Bradley Brunner (270) 282-1241 Bradley.M.Brunner@Carrier.utc.com.
 - 2) Carrier Utah: Bret Adams ([Contractors Heating/Cooling Supply](mailto:bret.adams@mc.supply)) (801) 224-1020 ext. 2527 bret.adams@mc.supply.
 - b. Lennox Industries:
 - 1) For pricing and information call Lennox Mountain Commercial at (800) 972-3283.

- 2) Lennox National Contact: Jeff Barrett (801) 556-6114 jeff.barrett@lennoxind.com.
- c. York (US Air Conditioning Distributors):
 - 1) Nick Filimoehala (801) 463-5323 n.filimoehala@us-ac.com.
- B. Performance:
 1. Capacities: SEER rating as defined by AHRI shall be 13.0 or greater.
- C. Manufactured Units:
 1. Compressor Units (5 Tons or Less):
 - a. General:
 - 1) Units shall be operable down to 0 deg F (minus 18 deg C) outdoor temperature.
 - 2) Use R-410a refrigerant.
 - 3) Only one liquid line, one suction line, and one power connection shall be made to each compressor. Provide charging valves.
 - b. Condenser Coils:
 - 1) Aluminum plate fins mechanically bonded to seamless copper tubes or 'Spine Fin' trade mark system which has aluminum fins epoxy bonded to aluminum tubes or micro-channel.
 - 2) Provide stamped louver coil guard for unit.
 - c. Fans:
 - 1) Direct driven propeller type.
 - 2) Fan motor shall be single or two speed, thermostatically controlled, permanently lubricated, and designed with permanent protection.
 - 3) Motors shall be resiliently mounted.
 - 4) Each fan shall have a safety guard.
 - d. Compressor:
 - 1) Each condenser unit shall have only one compressor.
 - 2) Design with following features:
 - a) Externally mounted brass service valves with charging connections.
 - b) Crankcase heater.
 - c) Resilient rubber mounts.
 - d) Compressor motor-overload protection.
 - e) Single speed.
 - e. Controls:
 - 1) Factory wired and located in separate enclosure.
 - 2) Following three paragraphs may not be factory installed and will therefore have to be field installed.
 - 3) Safety devices:
 - a) High and low pressure cutout.
 - b) Condenser fan motor-overload devices.
 - 4) Anti-cycle timers to prevent units from starting up again for five minutes after any power interruption.
 - 5) Head pressure type low ambient kit.
 - f. Casing:
 - 1) Fully weatherproof for outdoor installation. Finish shall be weather resistant.
 - g. Openings shall be provided for power and refrigerant connections.
 - h. Panels shall be removable for servicing.
 - i. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) North Region:
 - a) Carrier: 24ABB3.
 - b) Lennox: 13ACXN.
 - c) York: YCD.

2.2 ACCESSORIES

- A. Vibration Isolators:
 1. 4 inches (100 mm) square by 3/4 inch (19 mm) thick minimum neoprene type vibration isolation pads anchored solidly to concrete slab.

PART 3 - EXECUTION

3.1 INSTALLATION

A. General:

1. Set compressor units level on concrete slab on vibration isolation pads located at each corner of unit. This does not apply to compressor units that have composite non-metal bottom.
2. Do not use capillary tube and piston type refrigerant metering devices.

3.2 FIELD QUALITY CONTROL

A. Manufacturer Services:

1. Compressor units shall be started up, checked out, and adjusted by compressor unit Installer.
2. Use equipment checkout sheet provided by Manufacturer:
 - a. Complete and sign all items on sheet.

END OF SECTION

DIVISION 26: ELECTRICAL

26 0500 COMMON WORK RESULTS FOR ELECTRICAL

- 26 0501 COMMON ELECTRICAL REQUIREMENTS
- 26 0519 LINE-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES
- 26 0523 CONTROL-VOLTAGE ELECTRICAL CABLES
- 26 0526 GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS
- 26 0533 RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS SCHEDULE
- 26 0613 ELECTRICAL EQUIPMENT MOUNTING HEIGHT SCHEDULE

26 2000 LOW-VOLTAGE ELECTRICAL TRANSMISSION

- 26 2417 CIRCUIT-BREAKER PANELBOARDS
- 26 2726 WIRING DEVICES
- 26 2816 ENCLOSED SWITCHES AND CIRCUIT BREAKERS

26 5000 LIGHTING

- 26 5100 INTERIOR LIGHTING
- 26 5200 EMERGENCY LIGHTING

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 26 0501**COMMON ELECTRICAL REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. General electrical system requirements and procedures.
 2. Perform excavating and backfilling work required by work of this Division as described in Contract Documents.
 3. Make electrical connections to equipment provided under other Sections.

1.2 REFERENCES

- A. Reference Standards:
1. National Fire Protection Association / American National Standards Institute:
 - a. NFPA 70, National Electric Code (NEC).
 2. National Electrical Manufacturing Association Standards (NEMA):
 - a. NEMA 250, 'Enclosure for Electrical Equipment (1000 Volts Maximum)'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
1. Coordinate with Owner for equipment and materials to be removed by Owner.
 2. Coordinate with Mechanical Drawings for schematic wiring diagrams under Division 26 installation requirements.

1.4 SUBMITTALS

- A. Action Submittals:
1. Product Data:
 - a. Provide following information for each item of equipment:
 - 1) Catalog Sheets.
 - 2) Assembly details or dimension drawings.
 - 3) Installation instructions.
 - 4) Manufacturer's name and catalog number.
 - 5) Name of local supplier.
 - b. Furnish such information for following equipment:
 - 1) Section 26 2816: Enclosed switches and circuit breakers.
 - 2) Motor starters
 - c. Do not purchase equipment before approval of product data.
 2. Shop Drawings:
 - a. Indicate precise equipment to be used, including all options specified. Indicate wording and format of nameplates where applicable. Submit in three-ring binder with hard cover.
- B. Informational Submittals:
1. Test And Evaluation Reports:
 - a. Report of site tests, before Substantial Completion.
- C. Closeout Submittals:
1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Operations and Maintenance Data:

- 1) Provide operating and maintenance instructions for each item of equipment submitted under Product Data.
- b. Record Documentation:
 - 1) Manufacturers documentation:
 - a) Manufacturer's literature.
 - b) Include copy of approved shop drawings.

1.5 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 1. NEC and local ordinances and regulations shall govern unless more stringent requirements are specified.
 2. Material and equipment provided shall meet standards of NEMA or UL and bear their label wherever standards have been established and label service is available.
- B. Qualifications: Requirements of Section 01 4301 applies, but not limited to following:
 1. Electrical Subcontractor:
 - a. Company specializing in performing work of this section.
 - 1) Minimum five (5) years experience in electrical installations.
 - 2) Minimum five (5) satisfactorily completed installations in past three (3) years of projects similar in size, scope, and complexity required for this project before bidding.
 - b. Upon request, submit documentation.
 2. Installer:
 - a. Licensed for area of Project.
 - b. Designate one (1) individual as project foremen who shall be on site at all times during installation and experienced with installation procedures required for this project.
 - c. Upon request, submit documentation.

1.6 TEMPORARY POWER:

- A. Provide temporary power, including and wiring for lighting and power outlets so that scheduled use of the building is not interrupted. Verify requirements with General Conditions. Comply with NEC for temporary power requirements.

PART 2 - PRODUCTS

2.1 SYSTEMS

- A. Performance:
 1. Design Criteria:
 - a. Materials and equipment provided under following Sections shall be by same Manufacturer:
 - 1) Section 26 2816: Enclosed Switches And Circuit Breakers.
 - 2) Motor starters

PART 3 - EXECUTION

3.1 INSTALLERS

- A. Acceptable Installers:
 1. Meet Quality Assurance Installer Qualifications as specified in Part 1 of this specification.

3.2 EXAMINATION

- A. Verification Of Conditions:
 - 1. Confirm dimensions, ratings, and specifications of equipment to be installed and coordinate these with site dimensions and with other Sections.
- B. Evaluation And Assessment:
 - 1. All relocations, reconnections, and removals are not necessarily indicated on Drawings. Include such work without additional cost to Owner.

3.3 PREPARATION

- A. Disconnect equipment that is to be removed or relocated. Carefully remove, disassemble, or dismantle as required, and store in approved location on site, existing items to be reused in completed work.
- B. Where affected by demolition or new construction, relocate, extend, or repair raceways, conductors, outlets, and apparatus to allow continued use of electrical system. Use methods and materials as specified for new construction.
- C. Perform drilling, cutting, block-offs, and demolition work required for removal of necessary portions of electrical system. Do not cut joists, beams, girders, trusses, or columns without prior written permission from Architect. Locating hidden items such as conduit, rebar etc. in concrete, walls and ceilings shall be done by non-destructive methods such as X-ray before any work begins.
- D. Remove concealed wiring and conduit abandoned due to demolition or new construction. Remove circuits, conduits, and conductors that are not to be re-used back to next active fixture, device, or junction box.
- E. Patch, repair, and finish surfaces affected by electrical demolition work, unless work is specifically specified to be performed under other Sections of the specifications.

3.4 INSTALLATION

- A. General:
 - 1. Locations of electrical equipment shown on Drawings are approximate only. Field verify actual locations for proper installation.
 - 2. Coordinate electrical equipment locations and conduit runs with those providing equipment to be served before installation or rough in.
 - a. Notify Architect of conflicts before beginning work.
 - b. Coordinate locations of power and lighting outlets in mechanical rooms and other areas with mechanical equipment, piping, ductwork, cabinets, etc, so they will be readily accessible and functional.
 - 3. Work related to other trades which is required under this Division, such as cutting and patching, trenching, and backfilling, shall be performed according to standards specified in applicable Sections.

3.5 FIELD QUALITY CONTROL

- A. Field Tests:
 - 1. Test systems and demonstrate equipment as working and operating properly. Notify Architect before test. Rectify defects at no additional cost to Owner.
 - 2. Measure current for each phase of each motor under actual final load operation, i.e. after air balance is completed for fan units, etc. Record this information along with full-load nameplate current rating and size of thermal overload unit installed for each motor.

3.6 CLEANING

- A. Remove obsolete raceways, conductors, apparatus, and lighting fixtures promptly from site and dispose of legally.

3.7 CLOSEOUT ACTIVITIES

- A. Training:
 - 1. Provide competent instructor for three days to train Owner's maintenance personnel in operation and maintenance of electrical equipment and systems. Factory representatives shall assist this instruction as necessary. Schedule instruction period at time of final inspection.

END OF SECTION

SECTION 26 0519**LINE-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Quality of conductors used on Project except as excluded below.
- B. Related Requirements:
 - 1. Section 23 0933: 'Electric and Electronic Control System for HVAC' for conductors and cables for temperature control system.
 - 2. Section 26 0501: 'Common Electrical Requirements'.

1.2 REFERENCES

- A. Definitions:
 - 1. Line Voltage: Over 70 Volts.
- B. Reference Standards:
 - 1. National Fire Protection Association:
 - a. NFPA (Fire) 70, 'National Electric Code (NEC)' (2014 Edition or most recent edition adopted by AHJ including all applicable amendments and supplements).

PART 2 - PRODUCTS**2.1 SYSTEMS**

- A. Line Voltage Conductors:
 - 1. Copper with AWG sizes as shown:
 - a. Minimum size shall be No. 12 except where specified otherwise.
 - b. Conductor size No. 8 and larger shall be stranded.
 - 2. Insulation:
 - a. Standard Conductor Size No. 10 And Smaller: 600V type THWN or XHHW (75 deg C).
 - b. Standard Conductor Size No. 8 And Larger: 600V Type THW, THWN, or XHHW (75 deg C).
 - c. Higher temperature insulation as required by NEC or local codes.
 - 3. Colors:
 - a. 208Y / 120 V System:
 - 1) Black: Phase A.
 - 2) Red: Phase B.
 - 3) Blue: Phase C.
 - 4) Green: Ground.
 - 5) White: Neutral.
 - b. 480Y / 277 Volt System:
 - 1) Brown: Phase A.
 - 2) Orange: Phase B.
 - 3) Yellow: Phase C.
 - 4) Gray: Neutral.
 - 5) Green: Ground.
 - c. Conductors size No. 10 and smaller shall be colored full length. Tagging or other methods for coding of conductors size No. 10 and smaller not allowed.

- d. For feeder conductors larger than No. 10 at pull boxes, gutters, and panels, use painted or taped band or color tag color-coded as specified above.
- B. Line Voltage Cables:
1. Metal Clad Cable (MC) may be used as restricted below:
 - a. Copper conductors.
 - b. Sizes #12 through #8.
 - c. Use only in indoor dry locations where:
 - 1) Not subject to damage.
 - 2) Not in contact with earth.
 - 3) Not in concrete.
 - 4) Not exposed.
- C. Standard Connectors:
1. Conductors No. 8 And Smaller: Steel spring wire connectors.
 2. Conductors Larger Than No. 8: Pressure type terminal lugs.
 3. Connections Outside Building: Watertight steel spring wire connections with waterproof, non-hardening sealant.
- D. Terminal blocks for tapping conductors:
1. Terminals shall be suitable for use with 75 deg C copper conductors.
 2. Acceptable Products:
 - a. 16323 by Cooper Bussmann, Ellisville, MO www.bussmann.com
 - b. LBA363106 by Square D Co, Palatine, IL www.us.squared.com.
 - c. Equal as approved by Architect before bidding. See Section 01 6200.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General:
1. Conductors and cables shall be continuous from outlet to outlet.
 2. Do not use direct burial cable.
- B. Line Voltage Conductors:
1. Install conductors in raceway where indicated on Drawings. Run conductors of different voltage systems in separate conduits.
 2. Route circuits at own discretion, however, circuiting shall be as shown in Panel Schedules. Group circuit homeruns to panels as shown on Drawings.
 3. Neutrals:
 - a. On three-phase, 4-wire systems, do not use common neutral for more than three circuits.
 - b. On single-phase, 3-wire systems, do not use common neutral for more than two circuits.
 - c. Run separate neutrals for each circuit where specifically noted on Drawings.
 - d. Where common neutral is run for two or three home run circuits, connect phase conductors to breakers in panel which are attached to separate phase legs:
 - 1) Provide breaker tie so that all circuits that share common neutral are simultaneously disconnected.
 - 2) Neutral conductors shall be of same size as phase conductors unless specifically noted otherwise.
 4. Pulling Conductors:
 - a. Do not pull conductors into conduit until raceway system is complete and cabinets and outlet boxes are free of foreign matter and moisture.
 - b. Do not use heavy mechanical means for pulling conductors.
 - c. Use only listed wire pulling lubricants.
- C. Line Voltage Cables:

1. Route circuits at own discretion, however, circuiting and numbering shall be as shown in Panel Schedules.
2. Support cables using approved staples, cable ties, straps, hangers, or similar fittings, spaced as required.
3. Where installing in framing, do not bore holes in joists or beams outside center 1/3 of member depth or within 24 inches (600 mm) of bearing points. Do not bore holes in vertical framing members outside center 1/3 of member width. Holes shall be one inch diameter maximum.
4. Conceal cables within ceilings and walls of finished areas. Cables may be exposed in unfinished areas but not run on floors of mechanical equipment spaces or in such a way that they obstruct access to, operation of, or servicing of equipment.
5. Install exposed cables parallel to or at right angles to building structure lines.
6. Keep cables 6 inches (150 mm) minimum from hot water pipes.
7. Do not support cables from mechanical ducts or duct supports without Architect's written approval.
8. Prohibited procedures:
 - a. Boring holes for installation of cables in vertical truss members.
 - b. Notching of structural members for installation of cables.

END OF SECTION

BLANK PAGE

SECTION 26 0523**CONTROL-VOLTAGE ELECTRICAL CABLES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install control-voltage electrical cables as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 23 0933: Cables for Temperature Control System.
 - 2. Section 26 0501: Common Electrical Requirements.

1.2 REFERENCES

- A. Definitions:
 - 1. Control Voltage: 70 Volts and under.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories.
 - a. Alpha Wire Co, Elizabeth, NJ www.alphawire.com.
 - b. Belden Wire & Cable Co, Richmond, IN www.belden.com.
 - c. Liberty Wire & Cable, Colorado Springs, CO www.libertycable.com.
 - d. West Penn Wire Corp, Washington, PA www.westpenn-cdt.com.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. General:
 - 1. Cables shall be continuous and without splices from source to outlet.
 - 2. Install cables in raceway. Run cables of different systems in separate conduits.
 - 3. Pulling cables into conduit:
 - a. Do not pull cables until raceway system is complete and cabinets and outlet boxes are free of foreign matter and moisture.
 - b. Do not use heavy mechanical means for pulling cables.
 - c. Use only listed wire pulling lubricants.
 - 4. Prohibited procedures:
 - a. Boring holes for installation of cables in vertical truss members.
 - b. Notching of structural members for installation of cables.

END OF SECTION

BLANK PAGE

SECTION 26 0526**GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install grounding for electrical installation as described in Contract Documents except as excluded below.
- B. Related Requirements:
 - 1. Section 26 0501: Common Electrical Requirements.

1.2 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals: Requirements of Section 27 1501 applies, but is not limited to following:
 - 1. Cable assemblies shall be UL / CE Listed and CSA Certified. Cables shall be a distinctive green or green/yellow in color, and all jackets shall be UL, VW-1 flame rated.
 - 2. Grounding shall conform to all required Commercial Building Grounding and Bonding Requirements for Telecommunications, Electrical Codes, and Manufacturer's grounding requirements.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Type One Acceptable Products:
 - a. 'Cadweld' by Erico International, Solon, OH www.erico.com.
 - b. 'ThermOweld' by Continental Industries, Tulsa, NE www.conind.com.
 - c. Equal as approved by Architect before bidding. See Section 01 6200.
- B. Performance:
 - 1. Design Criteria:
 - a. Size materials as shown on Drawings and in accordance with applicable codes.
- C. Materials:
 - 1. Grounding And Bonding Jumper Conductors: Bare copper with green insulation.
 - 2. Make grounding conductor connections to ground rods and water pipes using approved bolted clamps listed for such use.
 - 3. Service Grounding Connections and Cable Splices: Make by exothermic process.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Interface with Other Work: Coordinate with Section 03 3111 in installing grounding conductor and placing concrete. Do not allow placement of concrete before Architect's inspection of grounding conductor installation.
- B. Grounding conductors and bonding jumper conductors shall be continuous from terminal to terminal without splice. Provide grounding for following.
 - 1. Conduits and other conductor enclosures.
 - 2. Neutral or identified conductor of interior wiring system.
 - 3. Non-current-carrying metal parts of fixed equipment such as motors, starter and controller cabinets, instrument cases, and lighting fixtures.
- C. Pull grounding conductors in non-metallic raceways, in flexible steel conduit exceeding **72 inches** in length, and in flexible conduit connecting to mechanical equipment.
- D. Provide grounding bushings on all feeder conduit entrances into panelboards and equipment enclosures.
- E. Bond conduit grounding bushings to enclosures with minimum #10 AWG conductor.
- F. Connect equipment grounds to building system ground.
 - 1. Use same size equipment grounding conductors as Phased conductors up through #10 AWG.
 - 2. Use NEC Table 250.122 for others unless noted otherwise in Drawings.
- G. Run separate insulated grounding cable from each equipment cabinet to electrical panel. Do not use intermediate connections or splices. Affix directly to cabinet.
- H. On motors, connect ground conductors to conduit with approved grounding bushing and to metal frame with bolted solderless lug.
- I. Ground cabinet of transformers to conduit and ground wires, if installed. Bond transformer secondary neutral conductor to cabinet.

3.2 FIELD QUALITY CONTROL

- A. Field Inspections:
 - 1. Notify Architect for inspection two days minimum before placing concrete over grounding conductor.

END OF SECTION

SECTION 26 0533**RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Quality of material and installation procedures for raceway, boxes, and fittings used on Project but furnished under other Divisions.
 - 2. Furnish and install raceway, conduit, and boxes used on Project not specified to be installed under other Divisions.
 - 3. Furnish and install air-vapor barrier boxes as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 26 0501: General Electrical Requirements.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Cooper B-Line, Highland, IL www.b-line.com.
 - b. Hubbell Incorporated, Milford, CT www.hubbell-wiring.com or Hubbell Canada Inc, Pickering, ON (905) 839-4332.
 - c. Square D, Palatine, IL www.squared.com.
 - d. Thomas & Betts, Memphis, TN www.tnb.com or Thomas & Betts Ltd, Iberville, PQ (450) 347-5318.
 - e. Walker Systems Inc, Williamstown, WV (800) 240-2601 or Walker Systems Inc / Wiremold Canada Inc, Fergus, ON (519) 843-4332.
 - f. Wiremold Co, West Hartford, CT www.wiremold.com.
- B. Performance:
 - 1. Design Criteria: All aspects of design of sound system have been included as requirements of Owner. Do not make changes to any aspects of installation, design, or equipment pertaining to sound system without Owner's approval through Architect and Sound Consultant.
- C. Materials:
 - 1. Raceway And Conduit:
 - a. Sizes:
 - 1) Minimum 3/4 inch (19 mm) above ground unless indicated otherwise.
 - 2) Minimum 1" underground or under slab unless indicated otherwise.
 - b. Types: Usage of each type is restricted as specified below by product.
 - 1) Galvanized rigid steel or galvanized intermediate metal conduit (IMC) is allowed for use in all areas. Where in contact with earth or concrete, wrap buried galvanized rigid steel and galvanized IMC conduit and fittings completely with vinyl tape.
 - 2) Galvanized Electrical Metallic Tubing (EMT) Conduit:
 - a) Allowed for use only in indoor dry locations where it is:
 - (1) Not subject to damage.
 - (2) Not in contact with earth.
 - (3) Not in concrete.

- b) For metal conduit systems, flexible steel conduit is required for final connections to indoor mechanical equipment.
- 3) Schedule 40 Polyvinyl Chloride (PVC) Conduit:
 - a) Allowed for use only underground or below concrete with galvanized rigid steel or IMC elbows and risers. Minimum underground PVC conduit size shall be One inch.
- 4) Listed, Liquid-Tight Flexible Metal Conduit:
 - a) Use in outdoor final connections to mechanical equipment, length not to exceed 36 inches (900 mm).
- c. Prohibited Raceway Materials:
 - 1) Aluminum conduit.
 - 2) Armored cable type AC (BX) cable.
 - 3) MC (metal clad) cable (except for connections less than 4ft)
 - 4) Romex cable
- 2. Raceway And Conduit Fittings:
 - a. Rigid Steel Conduit And IMC: Threaded and designed for conduit use.
 - b. EMT:
 - 1) Steel set screw housing type.
 - c. PVC Conduit:
 - 1) PVC type. Use PVC adapters at all boxes.
 - 2) PVC components, (conduit, fittings, cement) shall be from same Manufacturer.
 - d. Flexible Steel Conduit: Screw-in type.
 - e. Liquid-tight Flexible Metal Conduit: Sealite type.
 - f. Expansion fittings shall be equal to OZ Type AX sized to raceway and including bonding jumper.
 - g. Prohibited Fitting Materials:
 - 1) Crimp-on, tap-on, indenter type fittings.
 - 2) Cast set-screw fittings for EMT.
 - 3) Spray (aerosol) PVC cement.
- 3. Seal Devices: OZ Type WSK.
- 4. Outlet Boxes:
 - a. Galvanized steel of proper size and shape are acceptable for all systems. Where metal boxes are used, provide following:
 - 1) Provide metal supports and other accessories for installation of each box.
 - 2) Equip ceiling and bracket fixture boxes with fixture studs where required.
 - 3) Equip outlets in plastered, paneled, and furred finishes with plaster rings and extensions to bring box flush with finish surface.
 - b. Non-metallic boxes may be used only for control voltage wiring systems.
 - c. HVAC Instrumentation And Control:
 - 1) Junction boxes in mechanical equipment areas shall be 4 inches (100 mm) square.
 - 2) Boxes for remote temperature sensor devices shall be recessed single device.
 - 3) Boxes for thermostats shall be 4 inches (100 mm) square with raised single device cover.
- 5. Air-Vapor Barrier Boxes:
 - a. Pre-molded polyethylene box installed in all exterior framing walls (thermal envelope) around recessed outlet boxes.
 - b. Class Two Quality Standard:
 - 1) Approved Manufacturer. See Section 01 6200 for definitions of Classes.
 - a) Lessco Low Energy Systems Supply Company, Inc., Campbellsport, WI
www.lessco-airtight.com.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification Of Conditions:
 - 1. Confirm dimensions, ratings, and specifications of materials to be installed and coordinate these with site dimensions and with other Sections.

3.2 INSTALLATION

- A. Interface With Other Work:
1. Coordinate with Divisions 22 and 23 for installation of raceway for control of plumbing and HVAC equipment.
 2. Before rough-in, verify locations of boxes with work of other trades to insure that they are properly located for purpose intended.
- B. Conduit And Raceway:
1. Conceal raceways within ceilings, walls, and floors, except at Contractor's option, conduit may be exposed on walls or ceilings of mechanical equipment areas and above acoustical panel suspension ceiling systems. Install exposed raceway runs parallel to or at right angles to building structure lines.
 2. Keep raceway runs 6 inches (150 mm) minimum from hot water pipes.
 3. Make no more than four quarter bends, 360 degrees total, in any conduit run between outlet and outlet, fitting and fitting, or outlet and fitting.
 - a. Make bends and offsets so conduit is not injured and internal diameter of conduit is not effectively reduced.
 - b. Radius of curve shall be at least minimum indicated by NEC.
 4. Cut conduit smooth and square with run and ream to remove rough edges. Cap raceway ends during construction. Clean or replace raceway in which water or foreign matter have accumulated.
 5. Installation in Concrete:
 - a. Install no conduit in concrete unless outside diameter is less than 1/3 of slab, wall, or beam thickness in which it is embedded.
 - b. Position conduits in center of concrete below reinforcing steel, and separated by minimum lateral spacing of three diameters.
 - c. Elbows embedded in concrete shall be rigid steel or IMC and stubouts from concrete slabs shall extend 3 inches (75 mm) minimum before making connection to EMT.
 - d. Separate conduits penetrating structural slabs in buildings by 2 inches (50 mm) minimum.
 - e. Install seal device where underground raceways penetrate concrete building wall.
 6. Installation In Framing:
 - a. Do not bore holes in joists or beams outside center 1/3 of member depth or within 24 inches (600 mm) of bearing points. Do not bore holes in vertical framing members outside center 1/3 of member width.
 - b. Holes shall be one inch (25 mm) diameter maximum.
 7. Underground Raceway And Conduit:
 - a. Bury underground raceway installed outside building 24 inches (600 mm) deep minimum.
 - b. Bury underground conduit in planting areas 18 inches (450 mm) deep minimum. It is permissible to install conduit directly below concrete sidewalks, however, conduit must be buried 18 inches (450 mm) deep at point of exit from planting areas.
 8. Conduit And Raceway Support:
 - a. Securely support raceway with approved straps, clamps, or hangers, spaced as required.
 - b. Do not support from mechanical ducts or duct supports without Architect's written approval. Securely mount raceway supports, boxes, and cabinets in an approved manner by:
 - 1) Expansion shields in concrete or solid masonry.
 - 2) Toggle bolts on hollow masonry units.
 - 3) Wood screws on wood.
 - 4) Metal screws on metal.
 9. Prohibited Procedures:
 - a. Use of wooden plugs inserted in concrete or masonry units for mounting raceway, supports, boxes, cabinets, or other equipment.
 - b. Installation of raceway that has been crushed or deformed.
 - c. Use of torches for bending PVC.
 - d. Spray applied PVC cement.
 - e. Boring holes in truss members.
 - f. Notching of structural members.
 - g. Supporting raceway from ceiling system support wires.
 - h. Nail drive straps or tie wire for supporting raceway.

C. Boxes:

1. Boxes shall be accessible and installed with approved cover.
2. Do not locate device boxes that are on opposite sides of framed walls in the same stud space. In other wall construction, do not install boxes back to back.
3. Locate boxes so pipes, ducts, or other items do not obstruct outlets.
4. Install outlets flush with finished surface and level and plumb.
5. Support switch boxes larger than two-gang with side brackets and steel bar hangers in framed walls.
6. At time of substantial completion, install blank plates on uncovered outlet boxes that are for future use.
7. Install air-vapor barrier boxes.
 - a. Follow Manufacturer's installation instructions.

END OF SECTION

SECTION 26 0613**ELECTRICAL EQUIPMENT MOUNTING HEIGHT SCHEDULE****PART 1 - GENERAL: Not Used****PART 2 - PRODUCTS: Not Used****PART 3 - EXECUTION****3.1 INSTALLATION**

- A. Unless otherwise indicated, mount center of outlets or boxes at following heights above finish floor. Refer special conditions to Architect before rough-in and locate outlet under his direction.
- B. Mounting Heights:
1. HVAC:
 - a. Temperature Control Junction Boxes: As indicated on Drawings.
 - b. Thermostats not mounted in occupied space: As indicated on Drawings.
 - c. Remote Temperature Sensors and thermostats mounted in occupied space:
 - 1) Wall-Mounted 50 inches (1 270 mm) to top.
 - d. Indoor Motor Disconnects: 60 inches (1 525 mm).
 - e. Outdoor Motor Disconnects: As indicated on Drawings.
 - f. Motor Controls: 60 inches (1 525 mm).
 2. Plumbing:
 - a. Electric Water Cooler Outlets: Mount so outlet and cord are hidden by water cooler and outlet is accessible for resetting for GFCI trip.
 3. Electrical:
 - a. Distribution Panels: 72 inches (1 830 mm) to top.
 - b. Receptacles: 18 inches (450 mm).
 - c. Wall Switches: 42 inches (1 065 mm).

END OF SECTION

BLANK PAGE

SECTION 26 2417**CIRCUIT-BREAKER PANELBOARDS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install circuit-breaker panelboards as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 26 0501: 'Common Electrical Requirements'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. National Fire Protection Association:
 - a. NFPA 70E: 'Standard for Electrical Safety in the Workplace' (2018 or most recent edition adopted by AHJ).

PART 2 - PRODUCTS**2.1 EQUIPMENT**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Cutler-Hammer Inc, Pittsburgh, PA www.eatonelectric.com.
 - b. General Electric Industrial Systems, Charlotte, NC www.geindustrial.com.
 - c. Siemens Energy & Automation, Alphrata, GA www.sea.siemens.com.
 - d. Square D Co, Palatine, IL www.us.squared.com.
- B. Performance:
 - 1. Capacities:
 - a. Panelboard:
 - 1) Minimum integrated equipment short circuit rating of 22,000 amperes for 120 / 208 Volts.
 - 2) Minimum integrated equipment short circuit rating of 50,000 amperes for 277 / 280 Volts.
 - 3) Rated for use as service entrance equipment.
 - b. Lighting And Appliance Panelboards:
 - 1) Minimum integrated equipment short circuit rating of 10,000 amperes for 120 / 208 Volts.
 - 2) Minimum integrated equipment short circuit rating of 14,000 amperes for 277 / 480 Volts.
 - c. Load Centers:
 - 1) 125 Amp main lugs, 120 / 208 Volt, three-phase.
 - 2) Minimum integrated equipment short circuit rating of 10,000 Amps.
- C. Material:
 - 1. Circuit-breaker type.
 - 2. Galvanized steel cabinets
 - 3. Bussing and lugs arranged as required.
 - 4. Multi-pole circuit-breakers shall be common trip.

5. Circuit-breakers shall be molded case thermal magnetic type with inverse time characteristics.
6. Main Panelboard:
 - a. Surface-mounted and front accessible.
 - b. Enclosures:
 - 1) Exterior of Building:
 - a) NEMA / CEMA Type 3R with locking door.
 - 2) Interior of Building:
 - a) NEMA / CEMA Type 1.
 - c. Minimum dimensions of 32 inches (800 mm) wide by 8 inches (200 mm) deep.
 - d. Space designation on Drawings indicates bus hardware and panelboard capacity for future acceptance of one 100 Amp, three-pole circuit-breaker.
 - e. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Type PRL4B by Cutler-Hammer.
 - 2) Spectra Series by General Electric.
 - 3) Type P4 by Siemens.
 - 4) I-Line by Square D.
7. Lighting And Appliance Panelboards:
 - a. Plug-on or bolt-on breakers. Multi-pole breakers shall be common trip.
 - b. Factory installed or provided circuit number identification for each breaker and space.
 - c. Cabinets shall be locking type with no exposed latches or screws when door is closed. Key panels alike and provide minimum of three keys.
 - d. Minimum dimensions of 20 inches (500 mm) wide by 5-3/4 inches (146 mm) deep.
 - e. Space designation on Drawings indicates bus hardware and panelboard capacity for future acceptance of one 20 Amp, single-pole circuit-breaker.
 - f. Breakers specified to be shunt trip and shall include shunt trip accessories to remotely trip breaker using separate 120 V power source. Trip coil shall include coil-clearing contact to break coil current when breaker opens.
 - g. Use equipment from same manufacturer as main panelboard.
 - h. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Type PRL1a by Cutler-Hammer.
 - 2) Type AL or AQ by General Electric.
 - 3) Type P1 by Siemens.
 - 4) Type NQOD by Square D.
8. Load Centers:
 - a. Surface-mounted, outdoor NEMA Type 3R enclosure with padlocking provisions. 12-1/2 inches (318 mm) wide by 4-1/2 inch (115 mm) deep minimum.
 - b. HACR type circuit breakers.
 - c. Use equipment from same manufacturer as main panelboard.
 - d. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Type CH by Eaton.
 - 2) Type PowerMark Plus by General Electric.
 - 3) Type PL by Siemens.
 - 4) Type QO by Square D.
9. Labels:
 - a. All Switchboards shall be labeled with Arc-Flash Hazard Information per NFPA 70E 130.5 including:
 - 1) Nominal system voltage.
 - 2) Arc flash boundary.
 - 3) Available incident energy.
 - 4) Working distance.
 - 5) Minimum arc rating of clothing.
 - 6) Level of PPE.

PART 3 - EXECUTION

3.1 EXAMINATION

A. Verification Of Conditions:

1. Examine wall framing and verify framing for proper spacing for installation of panelboard(s).
 - a. Notify Architect of improper spacing in writing.
- B. Contractor shall be responsible for performing required calculations to determine ARC Flash Hazards and providing all appropriate labeling per NFPA 70E.

3.2 INSTALLATION

- A. Label panelboards, load centers, and each breaker in main panelboard with **1/16 inch (1.6 mm)** thick laminated plastic composition material with contrasting color core. Engraved letters shall be **1/4 inch (6 mm)** high.
- B. Provide typewritten circuit schedules in lighting and distribution panelboards and load centers to identify panelboard and load served by each branch breaker.
- C. Arrange conductors neatly within panelboards and load centers.
- D. Secure to structure in accordance with requirements of Project seismic design category.

3.3 PROTECTION

- A. Protect panelboards, load centers, and interior components from paint, gypsum board compound, dirt, dust, and other foreign matter during construction.

END OF SECTION

BLANK PAGE

SECTION 26 2726**WIRING DEVICES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install wiring devices complete with plates as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 26 0501: 'Common Electrical Requirements'.

PART 2 - PRODUCTS**2.1 COMPONENTS**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Cooper Wiring Devices, Peachtree City, GA www.cooperwiringdevices.com.
 - b. General Electric Industrial Systems, Charlotte, NC www.geindustrial.com.
 - c. Hubbell Building Automation, Austin, TX www.hubbell-automation.com.
 - d. Hubbell Inc, Milford, CT www.hubbell-wiring.com or Hubbell Canada Inc, Pickering, ON (800) 263-4622 or (905) 839-4332.
 - e. Hunt Control Systems Inc, Fort Collins, CO www.huntdimming.com.
 - f. Intermatic Inc, Spring Grove, IL www.intermatic.com.
 - g. IR-TEC America, Inc., Brea, CA www.irtec.com/en-ira/.
 - h. Leviton Manufacturing Co, Little Neck, NY www.leviton.com or Leviton Manufacturing of Canada Ltd, Pointe-Claire, QB (800) 461-2002 or (514) 954-1840.
 - i. Legrand, West Hartford, CT www.legrand.us.com or Vaughan, ON www.legrand.ca.com.
 - j. Lutron Electronics Co Inc, Coopersburg, PA www.lutron.com.
 - k. Ortronics, New London, CT www.ortronics.com.
 - l. Paragon Electric Co Inc, Carol Stream, IL www.icca.invensys.com/paragon or Paragon Electric, Mississauga, ON (800) 951-5526 or (905) 890-5956.
 - m. Pass & Seymour, Syracuse, NY www.passandseymour.com or Pass & Seymour Canada Inc, Concord, ON (905) 738-9195.
 - n. Philips Lighting Co, Somerset, NJ www.lighting.philips.com/nam or Philips Lighting Canada, Scarborough, ON (416) 292-3000.
 - o. Red Dot div of Thomas & Betts, Memphis, TN www.tnbcom.
 - p. Schneider Electric North America, Palatine, IL www.schneider-electric.com (847) 397-2600.
 - q. Sensorswitch, Wallingford, CT www.sensorswitch.com.
 - r. Siemon Company, Watertown, CT www.siemon.com.
 - s. Square D Co, Palatine, IL www.squared.com.
 - t. Suttle, Hector, MN www.suttleonline.com.
 - u. Tork Inc, Mount Vernon, NY www.tork.com.
 - v. Watt Stopper Inc, Santa Clara, CA www.wattstopper.com.
 - 2. Product Options:
 - a. Faces shall be nylon where available.
 - b. Devices of single type shall be from same Manufacturer.
 - c. Devices are listed as white. Use white devices on light colored walls, brown on dark colored walls, and black on black walls.
- B. Switches:
 - 1. Standard Style:

- a. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) 20 AMP, single pole:
 - a) Cooper: 2221V.
 - b) Hubbell: HBL1221-I.
 - c) Pass & Seymour: 20AC1-I.
 - d) Leviton: 1221-2I.
 - 2) Two Pole:
 - a) Cooper: 2222V.
 - b) Hubbell: HBL1222-I.
 - c) Pass & Seymour: 20AC2-I.
 - d) Leviton: 1222-2I.
 - 3) Three Way:
 - a) Cooper: 2223V.
 - b) Hubbell: HBL1223-I.
 - c) Pass & Seymour: 20AC3-I.
 - d) Leviton: 1223-2I.
 - 4) Four Way:
 - a) Cooper: 2224V.
 - b) Hubbell: HBL1224-I.
 - c) Pass & Seymour: 20AC4-I.
 - d) Leviton: 1224-2I.
 - 5) Pilot Switch:
 - a) Hubbell: HBL1221-PL.
 - b) Pass & Seymour: 20AC1-RPL.
 - c) Leviton: 1221-PLR.
 - 6) Lighted Toggle Switch:
 - a) Single Pole:
 - (1) Cooper: 2221-LTV.
 - (2) Hubbell: HBL1221-IL.
 - (3) Pass & Seymour: 20AC1-ISL.
 - (4) Leviton: 1221-LHI.
 - b) Three Way:
 - (1) Cooper: 2223-LTV.
 - (2) Hubbell: HBL1223-IL.
 - (3) Pass & Seymour: 20AC3-ISL.
 - (4) Leviton: 1223-7LC.
 - b. Custodian Room:
 - 1) 24-hour, in-wall, multiple automatic ON-OFF settings.
 - 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Intermatic: E1020.
 - b) Tork: 701A.
2. Digital Time/Timer Switch:
 - a. As shown in small Storage, Mechanical and Electrical Rooms.
 - b. Automatic countdown type:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Leviton: LTT60-1L.
 - b) Hubbell: TD200.
 - c) Pass & Seymour: RT1W.
 - d) Tork: SSA100.
 - e) Watt Stopper: TS-400-W.
 3. Momentary Switches:
 - a. 15 AMP, specification grade.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Cooper: 1895W.
 - 2) Hubbell: HBL1556W.
 - 3) Legrand: 1250W.
- C. Receptacles:
1. Standard Style:
 - a. 15 AMP, specification grade, back and side wired, self grounding, tamper resistant.

- b. Verified by UL to meet Fed Spec WC-596F.
 - c. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Cooper: TR5262.
 - 2) Hubbell: BR20.
 - 3) Leviton: TBR20.
 - 4) Pass & Seymour: TR20.
 - 2. Ground Fault Circuit Interrupter (GFCI):
 - a. 15 AMP, specification grade.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Cooper: GF15W.
 - 2) Hubbell: GF5252WA.
 - 3) Leviton: 8599-W.
 - 4) Pass & Seymour: 1594-W.
- D. Plates:
- 1. Standard Cover Plates:
 - a. Office / Occupied Areas:
 - 1) Nylon or high impact resistant thermoplastic.
 - 2) Color shall match wiring device.
 - b. All Other: Steel.
 - c. Ganged switches shall have gang plates.
 - d. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - 1) Cooper.
 - 2) Hubbell.
 - 3) Leviton.
 - 4) Pass & Seymour.
 - 2. Weatherproof In-Use Receptacle Covers:
 - a. NEMA 3R rated.
 - b. Cast aluminum.
 - c. Compatible with GFCI receptacles.
 - d. Complete with weather resistant gaskets and stainless steel screws.
 - e. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Hubbell: WP26MH, horizontal; WP26M, vertical.
 - 2) Intermatic: WP1010HMC, horizontal; WP1010MC, vertical.
 - 3) Red Dot: CKMG, horizontal; CKMGV, vertical.
- E. Occupancy Sensors:
- 1. Ceiling, ultrasonic type.
 - a. Complete with sensor and combined relay / control transformer.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - 1) Cooper Controls:
 - a) Sensor: OAC-U-0501-R.
 - b) Relay / Transformer: SP20-MV.
 - 2) IR-TEC America:
 - a) Sensor: OS-361DT.
 - b) Relay / Transformer: PPU-300.
 - 3) Leviton:
 - a) Sensor: OSC05-RUW.
 - b) Relay / Transformer: OPP20-D2.
 - 4) Sensorswitch:
 - a) Sensor: CMPDT9.
 - b) Relay / Transformer: MP-20-SP0DM.
 - 5) Watt Stopper:
 - a) Sensor: W-500A.
 - b) Relay / Transformer: BZ-150.
 - c. Provide manual ON and OFF momentary override switches. Refer to Contract Drawings for number of switches.
 - 2. Ceiling, dual technology type.
 - a. Complete with sensor and relay / transformer.
 - b. Category Four Approved Products. See Section 01 6200 for definitions of Categories:

- 1) Cooper Controls:
 - a) Sensor: OAC-DT-0501-R.
 - b) Relay / Transformer: SP20-MV.
 - 2) IR-TEC America:
 - a) Sensor: OS-361DT.
 - b) Relay / Transformer: PPU-300.
 - 3) Leviton:
 - a) Sensor: OSC05-RMW.
 - b) Relay / Transformer: OPP20-D2.
 - 4) Sensorswitch:
 - a) Sensor: CMPDT9.
 - b) Relay / Transformer: MP-20-SP0DM.
 - 5) Watt Stopper:
 - a) Sensor: DT-305.
 - b) Relay / Transformer: BZ-150.
- c. Provide manual ON and OFF momentary override switches. Refer to Contract Drawings for number of switches.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install devices flush with walls, straight, and solid to box.

END OF SECTION

SECTION 26 2816**ENCLOSED SWITCHES AND CIRCUIT BREAKERS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install disconnects as described in Contract Documents, except those provided integral with equipment.
- B. Related Requirements:
 - 1. Section 26 0501: Common Electrical Requirements.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
 - 1. Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories.
 - a. Disconnects: Same as Manufacturer of Project's main panelboard.
 - b. Fuses.
 - 1) Cooper Bussmann, Ellisville, IL www.cooperbussmann.com.
 - 2) Edison Fuse, Ellisville, IL (314) 391-3443.
 - 3) Ferraz Shawmut, Newburyport, MA www.ferrazshawmut.com.
 - 4) Littelfuse Inc, Des Plaines, IL www.littelfuse.com.
- B. Disconnects:
 - 1. Heavy-duty quick-make, quick-break type, non-fused unless indicated otherwise.
 - 2. Provide interlock to prevent opening of door when switch is in ON position.
 - 3. Provide means to lock switch in OFF position with padlock.
 - 4. Disconnects for motor circuits shall be horsepower rated.
 - 5. Disconnects For Furnace Units And Unit Heaters: Provide manual starter with thermal overload relay. Provide overload relay to match motor full load amps.
 - 6. Enclosures:
 - a. Interior: NEMA / CEMA Type 1.
 - b. Exterior: NEMA / CEMA Type 3R.
 - 7. Fuses:
 - a. Fuse fused disconnects with dual-element time delay fuses and equip with rejection type fuse holders.
 - b. Fuses on Project shall be from single manufacturer.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Label disconnects to indicate equipment served, such as Condensing Unit CU-1. Labeling shall include panel and circuit number used to feed power to motors or device. Use **1/16 inch (1.6 mm)** thick laminated plastic composition material with contrasting color core. Engraved letters shall be **1/4 inch (6 mm)** high. Attach labels with screws.

END OF SECTION

BLANK PAGE

SECTION 26 5100**INTERIOR LIGHTING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install lighting system as described in Contract Documents, complete with lamps.
- B. Related Requirements:
 - 1. Section 26 0501: 'Common Electrical Requirements'.
 - 2. Section 26 5121: 'Interior Lighting: LED Dimming Drivers'.
 - 3. Section 09 5116: 'Acoustical Tile Ceilings'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. American National Standards Institute (ANSI):
 - a. ANSI C78.377-2017, 'American National Standard for Electric Lamps: Specification for the Chromaticity of Solid State Lighting Products'.
 - 2. Federal Communications Commission (FCC):
 - a. Code of Federal Regulations (CFR):
 - 1) FCC 47 CFR Part 18, 'Industrial, Scientific, and Medical Equipment'.
 - 3. Institute of Electrical and Electronics Engineers (IEEE):
 - a. IEEE C62.41.1-2002, 'Guide on the Surge Environment in Low-Voltage (1000 V and Less) AC Power Circuits'.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Advance Transformer Co, Rosemont, IL www.advancetransformer.com.
 - b. Cooper Wiring Devices by Eaton, Peachtree City, GA www.cooperindustries.com.
 - c. General Electric Lighting, Hendersonville, NC or General Electric Lighting Canada Inc, Mississauga, ON www.gelighting.com/na.
 - d. Howard Lighting Products, Laurel, MS www.howard-ind.com.
 - e. Novitas Inc, Peachtree City, GA www.novitas.com.
 - f. Osram Sylvania, Danvers, MA www.sylvania.com or Osram Sylvania Ltd, Mississauga, ON (905) 673-6171.
 - g. Philips Lighting Co, Somerset, NJ www.lighting.philips.com/nam or Philips Lighting Canada, Scarborough, ON (416) 292-3000.
 - h. Universal Lighting Technologies, Nashville, TN www.universalballast.com.
 - i. Venture Lighting International, Solon, OH www.venturelighting.com.
 - j. Watt Stopper Inc, Santa Clara, CA www.wattstopper.com.
 - k. Westinghouse Lighting Corp, Philadelphia, PA www.westinghouselightbulbs.com.
 - 2. Product Options: When several lighting fixtures are specified by name for one use on Drawings, select any one of those specified. Do not mix fixtures from different manufacturers specified for one use.
- B. Materials

1. Lighting Fixtures:
 - a. Type One Acceptable Products:
 - 1) See Fixture Schedule on Drawings for acceptable manufacturers and models.
 - 2) Equals as approved by Architect before bidding. See Section 01 6200.
 - b. See 'Light Fixture Schedule' provided by Owner's Representative.
 - 1) Correlated Color Temperature: 3500k.
 - c. Other Lamps:
 - 1) Category Four Approved Manufacturers. See Section 01 6200 for definitions of Categories:
 - a) General Electric.
 - b) North American Philips.
 - c) Osram / Sylvania.
 - d) Westinghouse.
 - d. LED Lamps and Fixtures:
 - 1) Replacement Lamps shall have minimum efficiency of 70 lm / W per LM 79.
 - 2) Integral LED Lamps shall have minimum efficiency of 90 lm / W per LM 79.
 - 3) Provide minimum rated life of 50,000 per LM 80 and LM 70 standards.
 - 4) Color Temperature: 3500k.
 - 5) Provide full spectrum color index of 80.
- C. Factory Assembly:
 1. Fixtures shall be fully assembled complete with necessary wiring, sockets, lamps, reflectors, ballasts, auxiliaries, plaster frames, recessing boxes, hangers, supports, lenses, diffusers, and other accessories essential for complete working installation.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Interface With Other Work:
 1. Coordinate with Sections under 09 5000 heading to obtain symmetrical arrangement of fixtures in acoustic tile ceiling as shown on Reflected Ceiling Plan in Contract.
 2. In mechanical equipment rooms, coordinate locations of light fixtures with equipment locations to provide proper room illumination without obstruction. Suspend fixtures that must be mounted below pipes, ducts, etc, with chains or other Architect approved method.
- B. Securely mount fixtures. Support fixtures weighing **50 lbs (23 kg)** or more from building framing or structural members.

3.2 ADJUSTMENT

- A. Repair scratches or nicks on exposed surfaces of fixtures to match original undamaged conditions.

END OF SECTION

SECTION 26 5200**EMERGENCY LIGHTING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install emergency battery units as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 26 0501: 'Common Electrical Requirements'.

PART 2 - PRODUCTS**2.1 SYSTEMS**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Beghelli, Miramar, FL www.beghelliusa.com.
 - b. Bodine Emergency Lighting, Collierville, TN www.bodine.com
 - c. Dual-Lite, Cheshire, CT www.dual-lite.com.
 - d. Iota Engineering Co, Tucson, AZ www.iotaengineering.com
 - e. Lightolier, Fall River, MA www.lightolier.com.
 - f. Lithonia Lighting, Conyers, GA www.lithonia.com.
 - g. McPhilben / Day-Brite Lighting, Tupelo, MS www.mcphilben.com.
 - h. Sure-Lites / Cooper Lighting, Elk Grove, IL www.cooperlighting.com.
- B. Materials:
 - 1. LED Battery Packs:
 - a. Design Criteria:
 - 1) Batteries shall be long life nickel cadmium type.
 - 2) Complete with charging indicator light and test switch.
 - 3) Components shall be fully concealed and easily accessible for maintenance or replacement.
 - 4) Factory installed in lighting fixture, or field installed to same standards.
 - b. Linear LED Lighting Fixtures:
 - 1) Battery pack shall operate one (1) lamp at approximately 1400 lumens initially and 60 percent minimum of initial lumens after ninety (90) minutes.
 - 2) Charger shall be capable of full recharge in twenty four (24) hours.
 - c. Class Two Quality Products: See Section 01 4301 for Manufacturer Qualifications and Section 01 6200:
 - 1) Any Manufacturer that conforms to Contract Documents requirements.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Battery Packs:
 - 1. General:
 - a. Wire so unit can be tested with lights on.

- b. Wire so lamps in normal mode are switched off with other lighting in area. Connect unit to unswitched conductor of normal lighting circuit.
2. Linear LED Lighting Fixtures:
 - a. Install in ballast channel of fixture with charging indicator light and test switch mounted on fixture end, or visible and accessible through lens.

END OF SECTION

DIVISION 31: EARTHWORK

31 0500 COMMON WORK RESULTS FOR EARTHWORK

31 0501 COMMON EARTHWORK REQUIREMENTS

31 1000 SITE CLEARING

31 1100 CLEARING AND GRUBBING

31 1123 AGGREGATE BASE

31 2000 EARTH MOVING

31 2213 ROUGH GRADING

31 2216 FINE GRADING

31 2316 EXCAVATION

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 31 0501**COMMON EARTHWORK REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited to:
 - 1. General procedures and requirements for earthwork.
- B. Related Requirements:
 - 1. Section 01 1200: 'Multiple Contract Summary' for multiple contracts.
 - 2. Pre-Installation conferences held jointly with Section 31 0501 as described in Administrative Requirements on Part 1 of this specification section:
 - 3. Section 32 9001: 'Common Planting Requirements':
 - a. Pre-installation conference held jointly with other landscape related sections.

1.2 REFERENCES

- A. Definitions:
 - 1. Aggregate Base: Layer of granular material immediately below concrete and asphalt paving or miscellaneous site concrete (sidewalks, curbs, etc) and below interior concrete slabs on grade.
 - 2. Base: See aggregate base.
 - 3. Building Grading: sloping of grounds immediately adjacent to building. Proper grading causes water to flow away from a structure. Grading can be accomplished either with machinery or by hand.
 - 4. Compacted Fill: Placement of soils on building site placed and compacted per Contract Documents. Used to replace soils removed during excavation or to fill in low spot on building site.
 - 5. Excavation: Removal of soil from project site or cavity formed by cutting, digging or scooping on project site.
 - 6. Fine Grading (FG): Preparation of subgrade preceding placement of surfacing materials (aggregate base, asphalt or concrete paving, and topsoil) for contour of building site required. Fine Grading is conducted to ensure that earth forms and surfaces have been properly shaped and subgrade has been brought to correct elevations. It is performed after rough grading and placement of compacted fill but before placement of aggregate base or topsoil.
 - 7. Finish Grading: Completed surface elevation of landscaping areas for seeding, sodding, and planting on building site.
 - 8. Natural Grade: Undisturbed natural surface of ground.
 - 9. Rough Grading (RG): Grading, leveling, moving, removal and placement of existing or imported soil to its generally required location and elevation. Cut and fill is part of rough grading.
 - 10. Subgrade (definition varies depending upon stage of construction and context of work being performed):
 - a. Prepared natural soils on which fill, aggregate base, or topsoil is placed.
 - or
 - b. Prepared soils immediately beneath paving or topsoil.
 - 11. Topsoil Placement and Grading: Topsoil placement and finish grading work required to prepare site for installation of landscaping.

PART 2 - PRODUCTS: Not Used**PART 3 - EXECUTION****3.1 EXAMINATION**

- A. Verification Of Conditions:
1. Forty-eight (48) hours minimum before performing any work on site, contact Blue Stakes to arrange for utility location services.
 2. Perform minor, investigative excavations to verify location of various existing underground facilities at sufficient locations to assure that no conflict with the proposed work exists and sufficient clearance is available to avoid damage to existing facilities.
 3. Perform investigative excavating ten (10) days minimum in advance of performing any excavation or underground work.
 4. Upon discovery of conflicts or problems with existing facilities, notify Architect by phone or fax within twenty-four (24) hours. Follow telephone or fax notification with letter and diagrams indicating conflict or problem and sufficient measurements and details to evaluate problem.

3.2 PREPARATION

- A. Protection:
1. Spillage:
 - a. Avoid spillage by covering and securing loads when hauling on or adjacent to public streets or highways.
 - b. Remove spillage and sweep, wash, or otherwise clean project, streets, and highways.
 2. Dust Control:
 - a. Take precautions necessary to prevent dust nuisance, both on-site and adjacent to public and private properties.
 - b. Correct or repair damage caused by dust.
 3. Existing Plants And Features:
 - a. Do not damage tops, trunks, and roots of existing trees and shrubs on site that are intended to remain.
 - b. Do not use heavy equipment within branch spread.
 - c. Interfering branches may be removed only with permission of Architect.
 - d. Do not damage other plants and features that are to remain.

3.3 REPAIR / RESTORATION

- A. Adjust existing covers, boxes, and vaults to grade.
- B. Replace broken or damaged covers, boxes, and vaults.
- C. Independently confirm size, location, and number of covers, boxes, and vaults that require adjustment.

3.4 FIELD QUALITY CONTROL

- A. Field Tests And Inspections:
1. Civil and structural field tests, laboratory testing, and inspections are provided by Owner's independent Testing Agency as specified in Section 01 4523 'Testing And Inspection Services':
 - a. Quality Control is sole responsibility of Contractor. Owner's employment of an independent Testing Agency does not relieve Contractor of Contractor's obligation to perform The Work or Contractor's own Testing and Inspection services.
 2. Testing and inspection of earthwork operations is required.
 3. Field Tests and Laboratory Tests:

- a. Owner reserves right to require additional testing to re-affirm suitability of completed work including compacted soils that have been exposed to adverse weather conditions.
4. Field Inspections:
 - a. Notify Architect forty-eight (48) hours before performing excavation or fill work.
 - b. If weather, scheduling, or any other circumstance has interrupted work, notify Architect twenty-four (24) hours minimum before intended resumption of grading or compacting.
- B. Non-Conforming Work:
 1. If specified protection precautions are not taken or corrections and repairs not made promptly, Owner may take such steps as may be deemed necessary and deduct costs of such from monies due to Contractor. Such action or lack of action on Owner's part does not relieve Contractor from responsibility for proper protection of The Work.

END OF SECTION

BLANK PAGE

SECTION 31 1100**CLEARING AND GRUBBING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Perform clearing and grubbing as necessary to prepare site for rough grading and structure excavation as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 31 0501: Common Earthwork Requirements:
 - a. General procedures and requirements for earthwork.
 - b. Pre-installation conference held jointly with other common earthwork related sections.
 - c. Pre-installation conference held jointly with other landscape related sections.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 - 1. Participate in pre-installation conferences as specified in Section 31 0501.

PART 2 - PRODUCTS: Not Used**PART 3 - EXECUTION****3.1 PERFORMANCE**

- A. Tree And Brush Removal:
 - 1. Cut off trees, shrubs, brush, and vegetative growth **12 inches (300 mm)** maximum above ground.
 - 2. Do not pull up or rip out roots of trees and shrubs that are to remain. If excavation through roots is required, excavate by hand and cut roots with sharp axe. Make clean, smooth, sloping cuts.
 - 3. Cut roots **6 inches (150 mm)** or larger in diameter only with Architect's written permission.
- B. Grubbing:
 - 1. Grub out stumps and roots **12 inches (300 mm)** minimum below original ground surface, except as follows:
 - a. Under buildings, remove roots one inch and larger entirely.
 - b. Entirely remove roots of plants that normally sprout from roots, as identified by Architect.

3.2 CLEANING

- A. Remove from site trees, shrubs, uprooted stumps, vegetative layer, and surface debris and dispose of legally.
- B. Do not bury cuttings, stumps, roots, and other vegetative matter or burnt waste material on site.

END OF SECTION

BLANK PAGE

SECTION 31 1123**AGGREGATE BASE****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Furnish and install the following as described in Contract Documents:
 - a. Aggregate Base:
 - 1) Interior concrete slabs-on-grade.
 - 2) Miscellaneous exterior concrete (sidewalks, curb, gutter and equipment pads).
- B. Related Requirements:
1. Section 01 1200: 'Multiple Contract Summary' for multiple contracts.
 2. Section 03 3111: 'Cast-In-Place Structural Concrete'.
 3. Section 31 0501: 'Common Earthwork Requirements':
 - a. General procedures and requirements for earthwork.
 - b. Pre-installation conference held jointly with other common earthwork related sections.
 4. Section 31 2213: 'Rough Grading'.
 5. Section 31 2216: 'Fine Grading' for subgrade procedures.
 6. Section 31 2323: 'Fill' for compaction procedures and tolerances.

1.2 REFERENCES

- A. Definitions:
- B. Reference Standards:
1. ASTM International:
 - a. ASTM C131/C131M-14, 'Standard Test Method for Resistance to Degradation of Small-Size Coarse Aggregate by Abrasion and Impact in the Los Angeles Machine'.
 - b. ASTM D1556/D1556M-15, 'Standard Test Method for Density and Unit Weight of Soil in Place by the Sand-Cone Method'.
 - c. ASTM D1557-12, 'Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft³ (2,700 kN-m/m³))'.
 - d. ASTM D1883-16, 'Standard Test Method for California Bearing Ratio (CBR) of Laboratory-Compacted Soils'.
 - e. ASTM D2167-15, 'Standard Test Method for Density and Unit Weight of Soil in Place by the Rubber Balloon Method'.
 - f. ASTM D2419-14, 'Standard Test Method for Sand Equivalent Value of Soils and Fine Aggregate'.
 - g. ASTM D4318-17, 'Standard Test Methods for Liquid Limit, Plastic Limit, and Plasticity Index of Soils'.
 - h. ASTM D6938-17, 'Standard Test Method for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth)'.

1.3 SUBMITTALS

- A. Closeout Submittals:
1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Record Documentation:
 - 1) Testing and Inspection Reports:
 - a) Testing Agency Testing and Inspecting Reports of aggregate base.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 1. Materials shall be delivered in original, unopened packages with labels intact.

1.5 FIELD CONDITIONS

- A. Ambient Conditions:
 1. Do not perform work during unfavorable conditions as specified below:
 - a. Aggregate Base:
 - 1) Presence of free surface water.
 - 2) Over-saturated sub base materials.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Aggregate Base:
 1. Under Interior Slab-On-Grade Concrete (Section 03 3111 'Cast-In-Place Structural Concrete'):
 - a. New Aggregate Base:
 - 1) Gravel: 3/4 inch 18mm minimum to one inch 25 mm maximum well-graded, clean gravel or crushed rock.
 - 2) Do not use recycled concrete as base.
 - 3) Base type gravel or crushed rock, graded by weight as follows (three-quarter to one-inch clean gap-graded gravel):
 - a) Road Base type gravel or crushed stone (slag not allowed), graded as follows:

(1) Sieve		Percent of Weight Passing
(a) 1 inch	(25.4 mm)	100
(b) 3/4 inch	(19.0 mm)	90 - 80
(c) 1/2 inch	(12.7 mm)	20 - 40
(d) 3/8 inch	(9.5 mm)	5 - 10
(e) No. 4	(4.750 mm)	0 - 12
 2. Under Exterior Concrete (Section 03 3111 'Cast-In-Place Structural Concrete') excluding Concrete Paving):
 - a. New Aggregate Base:
 - 1) Road Base to conform to State DOT Specifications.
 - 2) Do not use recycled concrete as base.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Stockpiles:
 1. Provide area for each stockpile of adequate size, reasonably uniform in cross-section, well drained, and cleared of foreign materials.
 2. Locate piles so that there is no contamination by foreign material and no intermingling of aggregates from adjacent piles. Do not use steel-tracked equipment on stockpiles.
 3. Do not store aggregates from different sources, geological classifications, or of different gradings in stockpiles near each other unless bulkhead is placed between different materials.
 4. Do not use washed aggregates sooner than twenty-four (24) hours after washing or until surplus water has drained out and material has uniform moisture content.
 5. Do not stockpile higher than 15 feet (4.57 m). Cover or otherwise protect stockpiles for use in HMA to prevent buildup of moisture.

- B. Surface Preparation (Miscellaneous Exterior Concrete):
 - 1. Subgrade:
 - a. Finish grade to grades required by Contract Documents.
 - b. Compact subgrade as specified in Section 31 2323.

3.2 INSTALLATION

- A. Aggregate Base:
 - 1. General:
 - a. Do not place aggregate base material when subgrade is frozen or unstable.
 - b. Spread aggregate base material with equipment except in limited or restricted areas where use of hand spreading is allowed.
 - c. Spread aggregate base material in manner that does not break down material and eliminates segregation, ruts, and ridges.
 - d. Correct damage to aggregate base caused by construction activities and maintain corrected aggregate base until subsequent course is placed.
 - e. Do not allow traffic on aggregate base.
 - f. Remove all standing storm water.
 - 2. Under interior concrete slab-on-grade aggregate base:
 - a. Place 4 inches (100 mm) minimum of aggregate base under concrete slab, level, and compact with vibratory plate compactor.
 - 3. Under miscellaneous exterior concrete aggregate base:
 - a. Except under mow strips, place 4 inches (100 mm) minimum of aggregate base, level, and compact as specified in Section 31 2323.
- B. Tolerances:

END OF SECTION

BLANK PAGE

SECTION 31 2213**ROUGH GRADING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Perform rough grading work required to prepare site for construction as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 03 3053: Miscellaneous Exterior Cast-In-Place Concrete.
 - 2. Section 31 0501: 'Common Earthwork Requirements' for:
 - a. General procedures and requirements for earthwork.
 - b. Pre-installation conference held jointly with other common earthwork related sections.
 - 3. Section 31 1123: 'Aggregate Base' for aggregate base requirements.
 - 4. Section 31 2216: 'Fine Grading' for grading of subgrade below aggregate base and topsoil.
 - 5. Section 31 2316: 'Excavation'.
 - 6. Section 31 2323: 'Fill' for compaction procedures and tolerances for base.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 - 1. Participate in MANDATORY pre-installation conference as specified in Section 31 0501:
 - 2. In addition to agenda items specified in Section 01 3100 and Section 31 0501, review following:
 - a. Identify benchmark to be used in establishing grades and review Contract Document requirements for grades, fill materials, and topsoil.
 - b. Examine site to pre-plan procedures for making cuts, placing fills, and other necessary work.

PART 2 - PRODUCTS**2.1 MATERIALS**

- A. Materials used for fill shall be as specified for backfill in Section 31 2323 'Fill'.

PART 3 - EXECUTION**3.1 EXAMINATION**

- A. Verification Of Conditions:
 - 1. Verify elevations of rough grading are correct before compacted fill, fine grading, aggregate base or landscape grading are placed.

3.2 PREPARATION

- A. Protection Of In-Place Conditions:
 - 1. When existing grade around existing plants to remain is higher than new finish grade, perform regrading by hand.
 - 2. Do not expose or damage shrub or tree roots.

3.3 PERFORMANCE

- A. Subgrade (Natural Soils):
 - 1. Subgrade beneath compacted fill or aggregate base under asphalt or concrete paving shall be constructed smooth and even.

- B. Special Techniques:
 - 1. Compact fills as specified in Section 31 2323 'Fill'.
 - 2. If soft spots, water, or other unusual and unforeseen conditions affecting grading requirements are encountered, stop work and notify Architect.

- C. Tolerances:
 - 1. Maximum variation from required grades shall be **1/10 of one foot (28 mm)**.

END OF SECTION

SECTION 31 2216**FINE GRADING****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Perform fine grading of subgrade work required to prepare site for paving finish grading and for placement of topsoil as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 01 1200: 'Multiple Contract Summary' for multiple contracts.
 - 2. Section 31 0501: 'Common Earthwork Requirements' for:
 - a. General procedures and requirements for earthwork.
 - b. Pre-installation conference held jointly with other common earthwork related sections.
 - 3. Section 31 1123: 'Aggregate Base' for aggregate base requirements.
 - 4. Section 31 2213: 'Rough Grading' for grading and preparation of natural soil subgrades below fill and aggregate base materials.
 - 5. Section 31 2316: 'Excavation'.

1.2 SUBMITTALS

- A. Closeout Submittals:
 - 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Record Documentation:
 - 1) Testing and Inspection Reports:
 - a) Testing Agency Testing and Inspecting Reports of fill / engineered fill.

PART 2 - PRODUCTS: Not Used**PART 3 - EXECUTION****3.1 PREPARATION**

- A. Protection Of In-Place Conditions: Protect utilities and site elements from damage.
- B. General:
 - 1. Limit use of heavy equipment to areas no closer than **6 feet (1.80 meter)** from building or other permanent structures.
- C. Surface Preparation:
 - 1. Landscaping and Planting Areas:
 - a. Before grading, dig out weeds from planting areas by their roots and remove from site. Remove rocks larger than **1-1/2 inches (38 mm)** in size and foreign matter such as building rubble, wire, cans, sticks, concrete, etc.
 - b. Remove imported paving base material present in planting areas down to natural subgrade or other material acceptable to Architect.

3.2 PERFORMANCE

- A. Interface With Other Work: Do not commence work of this Section until grading tolerances specified in Section 31 2213 are met.
- B. General:
 - 1. Do not expose or damage existing shrub or tree roots.
- C. Tolerances:
 - 1. Site Tolerances:
 - a. Subgrade (material immediately below aggregate base):
 - 1) 0.00 inches (0.00 mm) high.
 - 2) Measure using string line from curb to curb, gutter, flat drainage structure, or grade break.
 - b. Maximum variation from required grades shall be 1/10 of one foot (28 mm).
 - 2. Aggregate Base (Asphalt Paving) Tolerances:
 - a. Aggregate base shall be 6 inches (150 mm) thick minimum after compaction, except where shown thicker on Drawings.
 - b. Measure using string line from curb to curb, gutter, flat drainage structure, or grade break.

END OF SECTION

SECTION 31 2316**EXCAVATION****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Perform Project excavating and trenching as described in Contract Documents, except as specified below.
 - 2. Procedure and quality for excavating and trenching performed on Project under other Sections unless specifically specified otherwise.

- B. Related Requirements:
 - 1. Section 31 0501: 'Common Earthwork Requirements' for:
 - a. General procedures and requirements for earthwork.
 - b. Pre-installation conference held jointly with other common earthwork related sections.
 - 2. Section 31 1100: Clearing and Grubbing.
 - 3. Section 31 1123: 'Aggregate Base'.
 - 4. Section 31 2213: 'Rough Grading' for rough grading and preparation of natural soil subgrades below fill and aggregate base materials.
 - 5. Section 31 2216: 'Fine Grading' for grading of subgrade below aggregate base and topsoil.
 - 6. Performance of excavating inside and outside of building required for electrical and mechanical work is responsibility of respective Section doing work unless arranged differently by Contractor.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 - 1. Participate in MANDATORY pre-installation conference as specified in Section 31 0501:
 - 2. In addition to agenda items specified in Section 01 3100 and Section 31 0501, review following:
 - a. Review protection of existing utilities requirements.

PART 2 - PRODUCTS: Not Used**PART 3 - EXECUTION****3.1 EXAMINATION**

- A. Verification Of Conditions:
 - 1. Carefully examine site and available information to determine type soil to be encountered.
 - 2. Discuss problems with Architect before proceeding with work.

3.2 PREPARATION

- A. Protection of Existing Utilities:
 - 1. Protect existing utilities identified in Contract Documents during excavation.
 - 2. If existing utility lines not identified in Contract Documents are encountered, contact Architect before proceeding.

3.3 PERFORMANCE

- A. Interface With Other Work:
 - 1. Section 31 2213: 'Rough Grading' for rough grading and preparation of natural soil subgrades below fill and aggregate base materials.
 - 2. Section 31 2216: 'Fine Grading' for grading of subgrade below aggregate base and topsoil.
- B. Excavation:
 - 1. Pavement And Miscellaneous Cast-In-Place Concrete:
 - a. Excavate as necessary for proper placement and forming of concrete site elements and pavement structure. Remove vegetation and deleterious material and remove from site.
 - b. Backfill over-excavated areas with compacted base material specified in Section 31 1123.
 - c. Remove and replace exposed material that becomes soft or unstable.
 - 2. If unusual excavating conditions are encountered, stop work and notify Architect.

3.4 REPAIR / RESTORATION

- A. Repair damage to other portions of the Work resulting from work of this Section at no additional cost to Owner. On new work, arrange for damage to be repaired by original installer.

3.5 CLEANING

- A. Debris and material not necessary for Project are property of Contractor and are to be removed before completion of Project. However, if material necessary for Project is hauled away, replace with specified fill / backfill material.

END OF SECTION

DIVISION 32: EXTERIOR IMPROVEMENTS

32 3000 SITE IMPROVEMENTS

32 3113 CHAIN LINK FENCES AND GATES

32 8000 IRRIGATION

32 8423 UNDERGROUND SPRINKLERS

END OF TABLE OF CONTENTS

BLANK PAGE

SECTION 32 3113**CHAIN LINK FENCES AND GATES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install complete fence and gates as described in Contract Documents.
- B. Products Furnished But Not Installed Under This Section:
 - 1. Chain link gate complete with mounting hardware.
- C. Related Requirements:
 - 1. Section 03 3111: 'Cast-In-Place Structural Concrete' for mow strips at fencing and setting sleeves in concrete retaining walls.
 - 2. Sections Under 04 2000 Heading: Installation of gate and hardware built into masonry mechanical equipment enclosures.
 - 3. Section 05 0503: 'Shop-Applied Metal Coatings' for priming and galvanizing repair.
 - 4. Section 05 0523: 'Metal Fastening' for welding requirements.

1.2 REFERENCES

- A. Association Publications: / Organizations:
 - 1. Chain Link Fence Manufacturers Institute (CLFMI), Columbia, MD www.chainlinkinfo.org.
 - a. WLG 2445, '*Chain Link Fence Wind Load Guide for the Selection of Line Post and Line Post Spacing*' (2012).
 - b. CLF-SFR0111, '*Chain Link Fence Manufacturers Institute Security Fencing Recommendations*'.
 - c. CLF-PM0610, '*Field Inspection Guide*'.
 - d. CLF-TP0211, '*Tested and Proven Performance of Security Grade Chain Link Fencing Systems*'.
- B. Reference Standards:
 - 1. ASTM International:
 - a. ASTM A123/A123M-17, 'Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products'.
 - b. ASTM A153/A153M-16a, 'Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware'.
 - c. ASTM A392-11a(2017), 'Standard Specification for Zinc-Coated Steel Chain-Link Fence Fabric'.
 - d. ASTM A1011/A1011M-18a, 'Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength'.
 - e. ASTM C1107/C1107M-17, 'Standard Specification for Packaged Dry, Hydraulic-Cement Grout (Nonshrink)'.
 - f. ASTM F1043-18, 'Standard Specification for Strength and Protective Coatings on Steel Industrial Chain Link Fence Framework'.
 - g. ASTM F1083-18, 'Standard Specification for Pipe, Steel, Hot-Dipped Zinc-Coated (Galvanized) Welded, for Fence Structures'.
 - h. ASTM F3000/F3000M-13(2018), 'Standard Specification for Polymer Privacy Insert Slats for Chain Link Fabric and Privacy Chain Link Fabric Manufactured Containing Pre-Installed Privacy Slats'.

1.3 SUBMITTALS

- A. Action Submittals:
1. Product Data: Manufacturer literature or cut sheets on fence components.

PART 2 - PRODUCTS

2.1 ASSEMBLIES

- A. Materials:
1. Fabric:
 - a. Chain Link Fabric of 9 ga (3.7 mm) wire, galvanized before or after weaving with 1.2 ounce (34 grams) zinc coating conforming to requirements of ASTM A392, Class I.
 - b. Mesh:
 - 1) Without Visual Privacy / Security Slats at mechanical enclosure:
 - a) 2 inch (50 mm) square mesh as selected by Architect.
 - c. Knuckle both selvages.
 2. Framework:
 - a. Posts and Rails shall be roll-formed, self-draining shapes meeting strength requirements of ASTM F1043, Table 3, and with 2 ounce (56.7 grams) zinc coating per 1 sq ft (0.0929 sq meter) of surface area conforming to ASTM A123/A123M.
 - b. Line Posts:
 - 1) Line Posts 8 feet (2.45 m) and under:
 - a) 1.875 by 1.625 inch (48 by 41 mm) C-section roll formed from steel conforming to ASTM A1011/A1011M, Grade 45, with minimum theoretical bending strength of 247 lbs (112 kg) under 6 foot (1.80 m) cantilever load.
 - b) 2.375 inch (60 mm) outside diameter Schedule 40 tubular section weighing 3.65 lbs (1.6 kg) per lineal 1 ft (305 mm) meeting requirements of ASTM F1083.
 - c) 2.375 inch (60 mm) outside diameter Schedule 40 tubular section weighing 3.12 lbs (1.42 kg) per lineal 1 ft (305 mm) formed from steel meeting requirements of ASTM A1011/A1011M.
 - c. Terminal And Gate Posts:
 - 1) Gate Posts and gate posts for gate leaves under 6 feet (1.80 m) wide:
 - a) 3.5 by 3.5 inch (89 by 89 mm) roll formed section with minimum theoretical bending strength of 486 pounds (220.5 kg) under 6 foot (1.80 m) cantilever load.
 - b) 3 inch (76 mm) outside diameter Schedule 40 pipe weighing 5.79 lbs (2.63 kg) per lineal 1 ft (305 mm) meeting requirements of ASTM F1083.
 - c) 3 inch (76 mm) outside diameter Schedule 40 tubular section weighing 4.64 lbs (2.11 kg) per lineal 1 ft (305 mm) formed from steel meeting requirements of ASTM A1011/A1011M.
 - d. Top And Brace Rail:
 - 1) 1.625 by 1.25 inch (41 by 32 mm) roll formed section of 45,000 psi (310 MPa) yield strength channel shaped rail with minimum theoretical bending strength of 247 lbs (112 kg) on 10 foot (3.050 m) midpoint load.
 - 2) 1.660 inch 42 mm outside diameter Schedule 40 pipe weighing 2.27 lbs (1.03 kg) per lineal 1 ft (305 mm) meeting requirements of ASTM F1083.
 - 3) 1.660 inch 42 mm outside diameter Schedule 40 tubular section weighing 1.84 lbs (0.83 kg) per lineal 1 ft (305 mm) formed from steel meeting requirements of ASTM A1011/A1011M.
 - e. Fittings:
 - 1) Pressed steel or malleable iron, hot-dip galvanized conforming to ASTM A153/A153M.
 - 2) Tie wires shall be 12 ga (2.05 mm) minimum galvanized steel or 9 ga (3 mm) minimum aluminum wire.
 - f. Tension Wire: 7 ga (3.66 mm) minimum galvanized spring steel.
 3. Gate Leafs Wider Than 6 Feet (1.80 Meters):

- a. Fabricate perimeter frames from metal and finish to match fence framework. Assemble frames by welding or with special fittings and rivets, for rigid connections, providing security against removal or breakage connections.
 - 1) Provide same fabric as for fence. Install fabric with stretcher bars at vertical edges and at top and bottom edges. Attach stretchers bars to frame at not more than **15 inches (380 mm)** on center.
 - 2) Install diagonal cross-bracing consisting of **3/8 inch (9.5 mm)** diameter adjustable length truss rods to ensure frame rigidity without sag or twist.
- b. Swing Gates: Fabricate perimeter frames of minimum **1.90 inches (48.26 mm)** OD pipe.
- c. Gate Hardware: Provide hardware and accessories for each gate, galvanized per ASTM A153/A153M, and in accordance with following:
 - 1) Hinges: Size and material to suit gate size, non-lift-off type, offset to permit 180 degree gate opening. Provide 1-1/2 pair of hinges for each leaf over **6 foot (1.80 m)** nominal height.
 - 2) Latch At Paving: Forked type or plunger-bar type to permit operation from either side of gate, with padlock eye as integral part of latch.
- d. Keeper: Provide keeper for vehicle gates, which automatically engages gate leaf and holds it in open position until manually released.
- e. Double Gates:
 - 1) Provide gate stops for double gates, consisting of mushroom type flush plate with anchors, set in concrete, and designed to engage center drop rod or plunger bar.
 - 2) Include locking device and padlock eyes as integral part of latch, permitting both gate leaves to be locked with single padlock.
- f. Sliding Gates: Provide Manufacturer's standard heavy-duty inverted channel track, ball-bearing hanger sheaves, overhead framing and supports, guides, stays, bracing, hardware, and accessories as required.

B. Mixes:

1. Post Foundation Concrete:
 - a. One cu ft cement, **2 cu ft (0.0566 cu m)** sand, **4 cu ft (0.1132 cu m)** gravel, and **5 gallons (18.93 liters)** minimum to **6 gallons (22.71 liters)** maximum water.
 - b. Mix thoroughly before placing.

2.2 ACCESSORIES**A. Post Setting Grout at Sleeves:**

1. Commercial nonshrink grout conforming to requirements of ASTM C1107/C1107M, Type B or C.
2. Type Two Approved Products:
 - a. Normal Construction Grout A by W R Bonsal, Charlotte, NC www.bonsal.com.
 - b. Advantage 1107 Grout by Dayton Superior, Miamisburg, OH www.daytonrichmond.com.
 - c. NS Grout by Euclid Chemical Co, Cleveland, OH www.euclidchemical.com.
 - d. 5 Star Special Grout 110 by Five Star Products Inc, Fairfield, CT www.fivestarprouducts.com.
 - e. Duragrout by L&M Construction Chemicals Inc, Omaha, NE www.lmcc.com.
 - f. Masterflow 713 Pre-mixed Grout by Master Builders, Cleveland, OH www.masterbuilders.com.
 - g. Tamms Grout 621 by TAMMS Industries, Mentor, OH www.tamms.com.
 - h. U S Spec MP Grout by U S Mix Products Co www.usspec.com.
 - i. CG-86 Grout by W R Meadows, Elgin, IL www.wrmeadows.com.
 - j. Equal as approved by Architect before use. See Section 01 6200.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Fence shall be installed by mechanics skilled and experienced in erecting fences of this type and in accordance with Contract Documents.

1. When general ground contour is to be followed, make changes of grade in gradual, rolling manner.
 2. Evenly space posts in line of fence a maximum of **10 feet (3.050 meter)** center to center.
- B. Post Foundations:
1. Except atop retaining walls, set posts with concrete post foundations as specified below:
 - a. Line Posts:
 - 1) Diameter **8 inch (200 mm)**
 - 2) Depth **36 inch (915 mm)**.
 - b. Gate, End, And Corner Posts:
 - 1) Diameter **12 inch (305 mm)**
 - 2) Depth **42 inch (1 065 mm)**.
 - c. At mow strips, set top of post foundation below grade sufficient to allow for placing of mow strip. Measure post foundation depth from top of mow strip.
 - d. Where fences are incorporated into slabs, measure post foundation depth from top of slab. Extend bottom of slab footing sufficient to allow specified amount of concrete around post. At existing slabs, install fence outside perimeter of slab.
 - e. For fences on retaining walls, provide **12 inch (305 mm)** long sleeves to be cast into retaining wall. Set pipe in sleeve and grout space between sleeve and post full.
- C. Fence:
1. After posts have been permanently positioned and concrete cured for one (1) week minimum, install framework, braces, and top rail. Join top rail with **6 inch (150 mm)** minimum couplings at not more than **21 foot (6.40 meter)** centers.
 2. Stretch fabric by attaching one end to terminal post and supplying sufficient tension to other end of stretch so slack is removed.
 - a. Fasten fabric to line posts with tie wires. Pass ties over one strand of fabric and hook under line post flange.
 - b. Place one tie as close to bottom of fabric as is possible with additional ties equally spaced between top and bottom band on approximately equal spacing not to exceed **14 inches (355 mm)** on center.
 - c. Attach fabric to roll formed terminals by weaving fabric into integral lock loops formed in post. Attach fabric to tubular terminals with tension bars and bands.
 - d. Hold fabric approximately **2 inches (50 mm)** above finish grade line.
 - e. On top rail, space tie wires at no more than **24 inches (610 mm)** on center.
 - f. Securely attach fittings and firmly tighten nuts.
- D. Gates:
1. Weld gate frames and provide for free and easy operation.
 2. Provide gate latching device with padlocking capabilities. Provide cane bolt to engage sleeve set in concrete at double gates.
 3. Align top bar of gates with top rail of fence.
 4. Gates shall be plumb and on same plane as fence, both vertically and horizontally.
 5. Set gate stops and other catches in concrete.

3.2 CLEANING

- A. Spread dirt from foundation excavations evenly around surrounding area unless otherwise directed. Leave area free of excess dribbles of concrete, pieces of wire, and other scrap materials.

END OF SECTION

SECTION 32 8423**UNDERGROUND SPRINKLERS – NO CONTROLLERS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Locate existing irrigation main line, laterals and heads. Modify existing irrigation system in areas disturbed by new construction by furnishing and installing landscape irrigation system as described in Contract Documents complete with accessories necessary for proper function.
- B. Related Requirements:
1. Section 01 4301: 'Quality Assurance – Qualifications'.
 2. Section 31 2213: 'Rough Grading'.
 3. Section 31 2216: 'Fine Grading'.
 4. Section 31 2316: 'Excavation'.

1.2 REFERENCES

- A. Definitions:
1. Automated Self Flushing Filter: Filter located immediately downstream from point of connection in-lieu of backflow prevention device for irrigation systems that utilize non-potable, secondary and/or reclaimed water that is automatically self flushing to control unwanted debris from infiltrating remaining irrigation system.
 2. Dielectric Fittings: Special type of fitting used between dissimilar metals to prevent galvanic action from causing corrosion failure.
 3. High Wind Area: As defined in this specification, area with average sustained wind speed of over **7.5 mph (12 km/hr)**.
 4. Low Voltage: As defined in NFPA 70 for circuits and equipment operating at less than 50 V or for remote-control, signaling power-limited circuits.
 5. Landscape Management Plan (LMP): See Section 32 9001 for definition.
 6. Lateral Line: Downstream from electric control valves to application devices, heads and emitters. Piping or tubing is under pressure during flow. In areas where potable or secondary water are used, line shall be white. In areas where non-potable or reclaimed water are used, line shall be purple.
 7. Main Line: Downstream from point of connection to electric control valves. Piping is under water-distribution-system pressure when activated by master valve or hydrometer. In areas where potable or secondary water are used, line shall be white. In areas where non-potable or reclaimed water are used, line shall be purple.
 8. Peak Flow: Maximum required flow for given month based on six (6) day week, nine (9) hour day watering window to be used for irrigation system design and to be used in hydraulic analysis.
 9. Plant Establishment Period: See Section 32 9001 for definition.
 10. Point of Connection: Location where water enters irrigation system.
 11. Static Water Pressure: Pressure at point of connection when system is not in operation.
 12. Source Pressure Test: Test to determine water source pressure.
 13. System Pressure Test: Test to evaluate system pressure when pressurized.
 14. Two-Wire Path: Conducts power to solenoid valves, and also conducts communications signals from Controller to each device on system.
 15. Working Pressure: Pressure at point of connection when system is in operation.
- B. Reference Standards:
1. ASTM International:
 - a. ASTM D2564-12, 'Standard Specification for Solvent Cements for Poly (Vinyl Chloride) (PVC) Plastic Piping Systems'.

- b. ASTM F656-15, 'Standard Specification for Primers for Use in Solvent Cement Joints of Poly (Vinyl Chloride) (PVC) Plastic Pipe and Fittings'.

1.3 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference:
 1. Participate in pre-installation conference as specified in Section 32 9001 held jointly with following sections:
 - a. Section 32: 8466: 'Underground Sprinklers: Controllers'.
 2. Schedule pre-installation conference before irrigation system installation begins:
 - a. In addition to agenda items specified in Section 01 3100, review following:
 - 1) Review mockup requirements.
 - 2) Review required tests and inspections and submittal requirements.
 - 3) Review Landscape Management Plan (LMP) requirements.
- B. Sequencing:
 1. Install sleeves and conduit before installation of cast-in-place concrete site elements and paving.

1.4 SUBMITTALS

- A. Action Submittals:
 1. Product Data:
 - a. Manufacturer's cut sheets for each element of system.

1.5 QUALITY ASSURANCE

- A. Regulatory Requirements:
 1. General:
 - a. Work and materials shall be in accordance with latest rules and regulations, and other applicable state or local laws.
 - b. Nothing in Contract Documents is to be construed to permit work not conforming to these codes.
- B. Qualifications: Requirements of Section 01 4301 applies, but not limited to following:
 1. Irrigation Subcontractor:
 - a. Company specializing in performing work of this section.
 - b. Minimum five (5) years experience in irrigation sprinkler installations.
 - c. Minimum five (5) satisfactorily completed irrigation sprinkler installations in past three (3) years of projects similar in size, scope, and complexity required for this project before bidding.
 - d. Use trained personnel familiar with required irrigation sprinkler procedures and with Contract Documents.
 - e. Foreman or supervisor required to attend pre-installation conference.
 - f. Upon request, submit documentation.
 2. Irrigation Installer:
 - a. Perform installation under direction of foreman or supervisor.
 - b. Minimum three (3) years experience in irrigation sprinkler installations similar in size, scope, and complexity.
 - c. Upon request, submit documentation.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Storage And Handling Requirements:
 1. Protect materials from damage and prolonged exposure to sunlight.

1.7 WARRANTY

A. Warranty:

1. Irrigation System:

- a. Warranty irrigation system for period of one (1) year from date of Substantial Completion.

As part of warranty, Installer shall perform following:

- 1) Filling and repairing depressions and replacing plantings due to settlement of irrigation system trenches.
- 2) Repairing faulty equipment, wiring and pipe installations.
- 3) Repairing equipment and pipe not properly winterized.

PART 2 - PRODUCTS

2.1 SYSTEM

A. Manufacturers:

1. Manufacturer Contact List:

- a. 3M, Austin, TX www.3m.com/elpd.
- b. Action Machining Inc, Bountiful, UT www.actionfilters.com.
- c. Amiad www.amiadusa.com.
- d. Carson by Oldcastle Enclosure Solutions, Auburn, WA www.oldcastleenclosures.com.
- e. GPH Irrigation Products, Fontana, CA www.gphirrigation.com.
- f. Harrington Corporation (Harco), Lynchburg, VA www.harcofittings.com.
- g. Hunter Industries, San Marcos, CA www.hunterindustries.com.
- h. HydroRain, North Salt Lake, UT www.hydorain.com.
- i. King Innovation, St Charles, MO www.kinginovation.com.
- j. IPS Corporation, Compton, CA www.ipscorp.com.
- k. Leemco, Colton, CA www.leemco.com.
- l. Matco-Norca, Inc. Brewster, NY www.matco-norca.com
- m. Mueller Company, Atlanta, GA www.muellercompany.com
- n. Netafim, Inc. www.netafimusa.com.
- o. Nibco Inc, Elkhart, IN www.nibco.com.
- p. Northstar Industries, LLC, Riverside, CA www.suresplice.com.
- q. Orbit Irrigation Products, Inc. Bountiful, UT www.orbitonline.com.
- r. Paige Electric, Union, NJ www.paigewire.com.
- s. Rain Bird Sprinkler Manufacturing Corp, Glendora, CA www.rainbird.com.
- t. Salco by Weathermatic Irrigation Products, Garland, TX www.weathermatic.com.
- u. Toro Company, Irrigation Div, Riverside, CA www.toro.com.
- v. T. Christy Enterprises, Inc. (Christy's), Anaheim, CA www.tchristy.com.
- w. VAF Filtration Systems, Arvada, CO www.vafusa.com.
- x. Weathermatic Irrigation Products, Garland, TX www.weathermatic.com.
- y. Wilkins a Zurn Company, Paso Robles, CA www.zurn.com.
- z. Substitutions: See Section 01 6000 – Product Requirements

B. Materials:

1. Rock-Free Soil:
 - a. For use as backfill around PVC pipe.
2. Pea Gravel:
 - a. For use around drains, valves, and quick couplers.
 - b. **1/2 inch (13 mm)** maximum dimension, washed rock.
3. Sand: Fine granular material naturally produced by rock disintegration and free from organic material, mica, loam, clay, and other deleterious substances.
4. Native Material: Soil native to project site free of wood and other deleterious materials and rocks over **1-1/2 inches (38 mm)**.
5. Topsoil:
 - a. Use soil as described in Section 32 9120, Section 32 9121, and Section 32 9122.
 - b. Achieve depths as described in Section 32 9122.
6. Pipe, Pipe Fittings, And Connections:

- a. General:
 - 1) Pipe shall be continuously and permanently marked with Manufacturer's name, size, schedule, type, and working pressure.
 - 2) Pipe sizes shown on Contract Drawings are minimum. Larger sizes may be substituted at no additional cost to Owner.
 - b. Piping:
 - 1) Main Line: Schedule 40 PVC.
 - 2) Lateral Lines: Schedule 40 PVC.
 - c. Fittings: Same material as pipe, except where detailed otherwise.
 - 1) Fittings **3 inch (76 mm)** or larger: Harco or Leemco of matching size.
 - 2) Use dielectric union fittings between dissimilar metal pipes and fittings.
 - d. Sleeves:
 - 1) Under Parking Area And Driveway Paving: Schedule 40 PVC Pipe.
 - 2) All Other: Class 200 PVC Pipe.
 - 3) Sleeve diameter shall be two (2) times larger than pipe installed in sleeve.
7. Sprinkler Heads:
- a. Each type of head shall be product of single manufacturer. Match manufacturer of existing sprinkler heads.
 - b. Spray Heads in Lawn Areas:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Hunter: PRS30, Pro-Spray Series with MPR nozzles, optional with CV.
 - b) Hydro-Rain: HRS 200 Series, 04, 06 Model PRHS with MPR nozzle.
 - c) Rainbird: 1804 or 1806 Series with MPR, U-Series, or HE-VAN nozzles. SAM optional.
 - d) Toro: 570 ZPRX series with MPR plus or Precision Series Spray nozzles.
 - e) Weathermatic: LX4 or LX6 series with MPR nozzles.
 - c. Rotary Stream Heads in Lawn and Shrub Areas:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Hunter: PRS40 with MP Rotator nozzle.
 - b) Rainbird: 1806-SAM-P45 with R-VAN nozzles.
 - c) Toro: 570 ZPRX Series with Precision Series Rotating nozzles.
 - d. Rotor Pop-ups:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Hunter: PGP Series, I-10 Series (Shrub) I-20 Series, I-25 or I-40 Series.
 - b) Rainbird: 5000/5000 plus MPR series, 5500 Series, 8005 Series.
 - c) Toro: Mini 8 series, T5P-RS series with **5 inch** pop.
 - d) Weathermatic: T3, CT-70 series.
8. Sprinkler Risers:
- a. Spray Heads (Pre-Manufactured Swing Assemblies):
 - 1) Type Two Acceptable Products:
 - a) Hunter: SJ-512 (**12 inch (305 mm) x 1/2 inch (12.7 mm)**) thread) or SJ-7512 (**12 inch (305 mm) x 3/4 inch (19 mm) x 1/2 inch (12.7 mm)**) thread).
 - b) Rain Bird model SA125050.
 - c) Hydorain: Blu-lock model BLJ-050-MC-1..
 - b. Spray Heads (Field Manufactured Assemblies):
 - 1) Three (3) schedule 40 street ells or Marlex street ells connected to lateral tee to form an adjustable riser or pop-up riser as detailed.
 - 2) Risers for sprinkler heads **14 inches (355 mm)** long minimum and **24 inches (610 mm)** maximum.
 - a) Type Two Acceptable Products:
 - (1) Hunter: FLEXsg tubing with HSBE spiral barbed fittings.
 - (2) Hydro-Rain: Blu-lock Swing pipe & fittings.
 - (3) Rainbird: Swing Pipe with barbed fittings.
 - (4) Toro: Super Funny Pipe with barbed fittings, SPFA-5125, SPFA-51275.
 - c. Rotor Pop-Up Sprinklers (Pre-Manufactured Assemblies):
 - 1) Type Two Acceptable Products:
 - a) **3/4 inch (19 mm)** rotor pop-up sprinklers shall have an adjustable pre-assembled swing assembly riser. Swing assemblies shall be **3/4 inch x 12 inch (19 mm x 300 mm)** and shall be threaded both ends. Swing assemblies shall be:
 - (1) Blu-lock: Model BLJ-075-TT-12.

- (2) Rain Bird: Model TSJ-12075.
 - (3) Hunter: SJ-712 12 inch (305 mm) thread.
 - b) 1 inch (25 mm) inlet rotor pop-up sprinklers shall have an adjustable pre-assembled double swing joint riser. Swing joints shall be 1 inch x 12 inch (25 mm x 300 mm) and shall be threaded both ends. Swing joint riser shall be:
 - (1) Rain Bird: Model TSJ-12075.
 - d. Rotor Pop-Up Sprinkler Heads (Field Manufactured Assemblies):
 - 1) Pop-up rotor sprinkler heads shall have adjustable riser assembly, three (3) ell swing joint assembly, unless detailed otherwise on Contract Drawings:
 - a) These swing joint fittings shall be of schedule 40 PVC plastic and nipples schedule 80 gray PVC unless otherwise designated on Contract Drawings.
 - b) Horizontal nipple parallel to side of lateral line shall be 8 inches (200 mm) long minimum.
 - c) All other nipples on swing joint riser shall be of length required for proper installation of sprinkler heads.
9. Control Wiring:
- a. Control Wiring:
 - 1) Wiring:
 - a) Traditional control wire shall be UF-UL listed, color coded PE insulated copper conductor direct burial size 14. For wire runs exceeding 3,300 feet (1 005.84 meter), use 12 AWG wire. Do not use green color-coded wire.
 - b) Aside from connectivity to automatic control valves, this material will be used to connect to master valve portion of hydrometer.
 - 2) Communication:
 - a) Communication wire between controller and flow sensor portion of hydrometer to be Paige Electric PE-39 (WeatherTRAK) or PE-54 (Rain Master). Run underground communication wire in gray electrical conduit.
 - b) Class Two Quality Standards. See Section 01 6200:
 - (1) Paige Electric Cadweld Connection.
 - 3) Waterproof Wire Connectors:
 - a) Control wire connections shall consist of properly-sized wire nut inserted in waterproof grease cap:
 - b) Type Two Acceptable Products:
 - (1) DBY or DBR by 3M.
 - (2) 'One Step' 20111SP by King Innovation.
 - (3) DB 57905, 57505 by Orbit.
 - b. Conduit:
 - 1) Exterior applications or inside mechanical shed:
 - a) Galvanized IMC. Where in contact with earth or concrete, wrap galvanized IMC conduit and fittings completely with vinyl tape.
 - 2) Controller grounding wire conduit: commercial grade PVC Sch. 40 grey conduit.
 - 3) In-ground: commercial grade grey conduit.
 - 4) Size conduit as follows:
 - 5) Traditional Wiring:

Galvanized IMC Conduit						
Wire Size (AWG)	Number of Wires					
14	7	13	22	32	47	67
12	6	8	18	25	38	59
Conduit Size	3/4 inch (19 mm)	1 inch (25 mm)	1 1/4 inch (32 mm)	1 1/2 inch (38 mm)	2 inch (50 mm)	2 1/2 inch (64 mm)

PVC Sch. 40 Conduit						
Wire Size (AWG)	Number of Wires					
14	6	11	20	29	43	61
12	5	7	17	23	35	54
Conduit Size	3/4 inch (19 mm)	1 inch (25 mm)	1 1/4 inch (32 mm)	1 1/2 inch (38 mm)	2 inch (50 mm)	2 1/2 inch (64 mm)
PVC Sch. 80 Conduit						
Wire Size (AWG)	Number of Wires					
14	5	9	17	24	39	55
12	4	6	14	19	32	49
Conduit Size	3/4 inch (19 mm)	1 inch (25 mm)	1 1/4 inch (32 mm)	1 1/2 inch (38 mm)	2 inch (50 mm)	2 1/2 inch (64 mm)

10. Valve Accessories:

a. Valve Boxes And Extensions:

1) Lid Colors:

- a) Green: Lawn areas (potable and secondary water).
- b) Tan: Bare soil and rock areas (potable and secondary water).
- c) Purple: Reclaimed water.

2) Type Two Acceptable Products:

a) Carson:

- (1) 12 Inch (300 mm) Model 1324-12.
- (2) 12 Inch (300 mm) Model 1419-12.
- (3) 10 Inch (255 mm) Model 0910.

b. Valve Box Supports:

- 1) Standard size fired clay paving bricks without holes.
- 2) Standard size 6 inch x 8 inch x 16 inch (150 mm x 200 mm x 400 mm) CMU Block.

11. Solvent Cement:

a. Category Four Approved Products. See Section 01 6200 for definitions of Categories:

1) Primer:

- a) Meet ASTM F656 standard and applicable sections of latest edition of 'Uniform Plumbing Code'.
- b) Meet NSF/ANSI standard for use on potable water applications.
- c) Low VOC emissions and compliant with LEED.
- d) Product: Weld-On P-70 primer by IPS.

2) PVC Solvent Cement:

a) Heavy bodied, medium setting, high strength:

- (1) Meet ASTM D2564 standard and applicable sections of latest edition of 'Uniform Plumbing Code'.
- (2) Meet NSF/ANSI standard for use on potable water applications.
- (3) Meet CSA standards for use in pressure and non-pressure potable water applications.
- (4) Low VOC emissions and compliant with LEED.
- (5) Product: Weld-On 711 Low VOC PVC Cement by IPS.

b) Flexible, medium bodied, fast setting, high strength (flexible pipe only):

- (1) Meet ASTM D2564 standard and applicable sections of latest edition of 'Uniform Plumbing Code'.
- (2) Meet NSF/ANSI standard for use on potable water applications.
- (3) Low VOC emissions and compliant with LEED.

- (4) Product: Weld-On 795 Low VOC Flex PVC Cement by IPS.
12. Other Components:
- a. Recommended by Manufacturer and subject to Architect's review and approval before installation.
 - b. Provide components necessary to complete system and make operational.

PART 3 - EXECUTION

3.1 INSTALLERS

- A. Acceptable Installers:
1. Meet Quality Assurance Installer Qualifications as specified in Part 1 of this specification.

3.2 EXAMINATION

- A. Verification Of Conditions:
1. Perform source pressure test at stub-out on main water line provided for irrigation system, or at near-by fire hydrant.
 2. Notify Architect if pressures over **70 psi (480 kPA)** or under **55 psi (379 kPA)** are found to determine if some re-design of system is necessary before beginning work on system.

3.3 PREPARATION

- A. Protection:
1. Protection Of In-Place Conditions:
 - a. Repair or replace work damaged during course of Work at no additional cost to Owner. If damaged work is new, installer of original work shall perform repair or replacement.
 - b. Do not cut existing tree roots measuring over **2 inches (50 mm)** in diameter in order to install irrigation lines.
- B. Surface Preparation:
1. Layout of Irrigation Heads:
 - a. Location of heads and piping shown on Contract Drawings is approximate. Actual placement may vary slightly as is required to achieve full, even coverage without spraying onto buildings, sidewalks, fences, etc.
 - b. During layout, consult with Architect to verify proper placement and make recommendations, where revisions are advisable.
 - c. Minor adjustments in system layout will be permitted to avoid existing fixed obstructions.
 - d. Make certain changes from Contract Documents are shown on Record Drawings.

3.4 INSTALLATION

- A. Trenching And Backfilling:
1. Pulling of pipe is not permitted.
 2. Excavate trenches to specified depth. Remove rocks larger than **1-1/2 inch (38 mm)** in any direction from bottom of trench. Separate out rocks larger than **1-1/2 inch (38 mm)** in any direction uncovered in trenching operation from excavated material and remove from areas to receive landscaping.
 3. Cover pipe both top and sides with **2 inches (50 mm)** of rock-free soil or sand as specified under PART 2 PRODUCTS. Remainder of backfill to topsoil depth as specified in Section 32 9122 using native material as specified under PART 2 PRODUCTS and topsoil as specified in Section 32 9120, Section 32 9121 and Section 32 9122.
 4. Do not cover pressure main, irrigation pipe, or fittings until Landscape Architect has inspected and approved system.

- B. Sleeving:
1. Sleeve water lines and control wires under walks and paving. Extend sleeves **6 inches (150 mm)** minimum beyond walk or pavement edge. Cover sleeve ends until pipes and wires are installed to keep sleeve clean and free of dirt and debris.
 2. Position sleeves with respect to buildings and other obstructions so pipe can be easily removed.
- C. Grades And Draining:
1. In localities where winterization is required, grade piping so system can be completely drained or blown out with compressed air. If system is not designed to be blown out with compressed air:
 - a. Slope pipe to drain to control valve box where possible.
 - b. Where this is not possible, slope pipe to minimum number of low points. At these low points, install:
 - 1) **3/4 inch (19 mm)** brass ball valve for manual drain. Do not use automatic drain valves.
 - 2) Install **2 inch (50 mm)** Class 200 PVC pipe over top of drain and cut at finish grade.
 - 3) Provide rubber valve cap marker.
 - 4) Provide **one cu ft (0.03 cu m)** pea gravel sump at outlet of each drain.
 - c. Slope pipes under parking areas or driveways to drain outside these areas.
 - d. Provide and install quick-coupling valve or valves in location for easy blowout of entire system. Install quick coupler valves with **2 lineal feet (0.60 m)** minimum of galvanized pipe between valve and main line.
- D. Installation of Pipe:
1. Install pipe in manner to provide for expansion and contraction as recommended by Manufacturer.
 2. Unless otherwise indicated on Contract Drawings, install main lines with minimum cover of **18 inches (450 mm)** based on finished grade. Install lateral lines, including those connecting drip tubing, with minimum of **12 inches (300 mm)** of cover based on finish grade.
 3. Install pipe and wires under driveways or parking areas in specified sleeves **18 inches (450 mm)** below finish grade or as shown on Contract Drawings.
 4. Locate pipe so no sprinkler head will be closer than **12 inches (300 mm)** from building foundation.
 5. Cut plastic pipe square. Remove burrs at cut ends before installation so unobstructed flow will result.
 6. Make solvent weld joints as follows:
 - a. Do not make solvent weld joints if ambient temperature is below **35 deg F (2 deg C)**.
 - b. Clean mating pipe and fitting with clean, dry cloth and apply one (1) coat of primer to each surface.
 - c. Apply uniform coat of solvent cement to outside of pipe.
 - d. Apply solvent cement to fitting in similar manner.
 - e. Insert pipe completely into fitting.
 - f. Give pipe or fitting quarter turn to insure even distribution of solvent and make sure pipe is inserted to full depth of fitting socket.
 - g. Allow joints to set at least twenty-four (24) hours before applying pressure to PVC pipe.
 7. Tape threaded connections with teflon tape.
- E. Control Valve Wiring:
1. Wiring:
 - a. Use waterproof wire connectors consisting of properly-sized wire nut and grease cap at splices and locate all splices within valve boxes.
 - b. Traditional Wiring:
 - 1) Tape control wire to side of main line every **10 feet (3.050 m)**. Where control wire leaves main or lateral line, enclose it in gray conduit:
 - 2) Use white or gray color for common wire and other colors for all other wire. Each common wire may serve only one (1) controller.
 - 3) Run one (1) spare control wire from panel continuously from valve to valve throughout system similar to common wire for use as replacement if wire fails:
 - a) Run spare wire to each branch of system.
 - b) Spare wire shall be different color than other wires. Use of green wire is not acceptable.

- c) Mark spare control wire visibly within valve box as an 'Un-Connected Wire'. Extend spare control wires **24 inches (600 mm)** and leave coiled in each valve box. Mark spare wire visibly within controller as 'Un-Connected Wire'.

F. Sprinkler Heads And Rotor Pop-ups:

1. Set sprinkler heads and quick-coupling valves perpendicular to finish grade.
2. Do not install sprinklers using side inlets. Install using base inlets only.
3. Heads immediately adjacent to mow strips, walks, or curbs shall be **one inch (25 mm)** below top of mow strip, walk, or curb and have **one inch (25 mm) to 3 inch (75 mm)** clearance between head and mow strip, walk, or curb.
4. Set sprinkler heads at consistent distance from walks, curbs, and other paved areas and to grade by using specified components or other method demonstrated in Pre-Construction Conference.

3.5 FIELD QUALITY CONTROL

A. Field Tests and Inspections:

1. Substantial Completion Walkthrough:
 - a. Architect or designated representative(s) will inspect site and create list of non-conforming items to be resolved prior to Landscape Final Acceptance. Date on this list will act as date of Landscape Substantial Completion.
 - b. Installations completed after water source has been turned off for season, as determined by Landscape Architect, will be inspected following spring after system can be checked for proper operation.
2. Irrigation Approval:
 - a. Irrigation will be approved when all non-conforming work is brought into conformance.

B. Non-Conforming Work: Non-conforming work as covered in General Conditions applies, but is not limited to following:

1. Underground Sprinkler System:
 - a. Correct any work found defective or not complying with Contract Document requirements at no additional cost to Owner.

3.6 ADJUSTING

A. Sprinkler Heads:

1. Adjust sprinkler heads to proper grade when turf is sufficiently established to allow walking on it without appreciable harm. Such lowering and raising of sprinkler heads shall be part of original contract with no additional cost to Owner.
2. Adjust sprinkler heads for proper distribution and trim so spray does not fall on building.

3.7 CLOSEOUT ACTIVITIES

END OF SECTION

BLANK PAGE