

ADDENDUM

Project: Orem 1.2.9

Project No.: 513023918020101

Addendum No.: 02

Project Address: 80 S. 280 E. Orem, UT 84058

Date: 5-22-19

Owner: Corporation of the Presiding Bishop of The Church of Jesus Christ of Latter-day Saints, a Utah corporation sole

From (Architect): Trio Design Inc.

Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of 1 page and the attached drawing "Fixture Schedule".

1. Changes to prior Addenda: None
2. Changes to Bidding Requirements: None
3. Changes to Conditions of the Contract: None
4. Changes to Specifications: None
5. Changes to Drawings: (Sheet A101)
 - a. Install one (1) light fixture and connect to existing circuit (see attached schedule)
 - b. Provide one (1) GFCI outlet near sink
 - c. Restroom door to be LDS Standard Hardware: Group 32

End of Addendum

FIXTURE SCHEDULE

TYPE	MANUFACTURER		LOAD (VA)	LAMPS TYPE	MOUNTING	REMARKS
	NAME	CATALOG NUMBER				
FI	DAY-BRITE METALUX H.E. WILLIAMS LSI LITHONIA COLUMBIA	OWN232-UNV-1/2-EB WN-232A-UNV-GE-GE232MAXLULTRA-U 17-4-232-A-LDS-AD-BD-UNV WNA10-232-SSOLR-UE SB232 MVOLT APLP AWN-232	56	2-28W T8 3000K	SURFACE	4'x10" FIXTURE WITH WRAP AROUND ACRYLIC LENS, ELECTRONIC BALLAST.